

Your P.O. #: BN501012
Your Project #: HOLY SPIRIT
Site:500012104
Your C.O.C. #: n/a

Attention: Roland Lawton
Dufferin-Peel Catholic District School Board
40 Matheson Blvd
Mississauga, ON
CANADA L5R 1C5

Report Date: 2009/07/30

CERTIFICATE OF ANALYSIS

MAXXAM JOB #: A993303
Received: 2009/07/23, 10:14

Sample Matrix: Water
Samples Received: 2

Analyses	Quantity	Date Extracted	Date Analyzed	Laboratory Method	Method Reference
Metals Analysis by ICPMS (as received) ¶	2	2009/07/30	2009/07/30	CAM SOP-00447	EPA 6020

* RPDs calculated using raw data. The rounding of final results may result in the apparent difference.

(1) Metals analysis was performed on the sample 'as received'.

Encryption Key

Please direct all questions regarding this Certificate of Analysis to your Project Manager.

JAMES ASPIN, Project Manager
Email: James.Aspin@maxxamAnalytics.com
Phone# (905) 817-5700 Ext:5771

=====
Maxxam has procedures in place to guard against improper use of the electronic signature and have the required "signatories", as per section 5.10.2 of ISO/IEC 17025:2005(E), signing the reports. SCC and CALA have approved this reporting process and electronic report format.

For Service Group specific validation please refer to the Validation Signature Page

Total cover pages: 1

Maxxam Job #: A993303
 Report Date: 2009/07/30

Dufferin-Peel Catholic District School Board
 Client Project #: HOLY SPIRIT
 Project name: 500012104
 Your P.O. #: BN501012

ELEMENTS BY ATOMIC SPECTROSCOPY (WATER)

Maxxam ID			DE0828		
Sampling Date			2009/06/19 07:00		
COC Number			n/a		
	Units	Criteria	HOLY SPIRIT-KITCHEN-STAFFROOM(STAN DING)	RDL	QC Batch

Metals					
. Lead (Pb)	mg/L	0.01	ND	0.0005	1893677
ND = Not detected N/A = Not Applicable RDL = Reportable Detection Limit QC Batch = Quality Control Batch Criteria: Ontario Regulation 243/07 made under the Safe Drinking Water Act, 2002. Released June 7, 2007					

Maxxam ID			DE0829		
Sampling Date			2009/06/19 07:35		
COC Number			n/a		
	Units	Criteria	HOLY SPIRIT-KITCHEN-STAFFROOM(FLUS HED)	RDL	QC Batch

Metals					
. Lead (Pb)	mg/L	0.01	ND	0.0005	1893677
ND = Not detected N/A = Not Applicable RDL = Reportable Detection Limit QC Batch = Quality Control Batch Criteria: Ontario Regulation 243/07 made under the Safe Drinking Water Act, 2002. Released June 7, 2007					

Maxxam Job #: A993303
Report Date: 2009/07/30

Dufferin-Peel Catholic District School Board
Client Project #: HOLY SPIRIT
Project name: 500012104
Your P.O. #: BN501012

Package 1	13.0°C
-----------	--------

Each temperature is the average of up to three cooler temperatures taken at receipt

GENERAL COMMENTS

Results relate only to the items tested.

Dufferin-Peel Catholic District School Board
 Attention: Roland Lawton
 Client Project #: HOLY SPIRIT
 P.O. #: BN501012
 Project name: 500012104

Quality Assurance Report
 Maxxam Job Number: MA993303

QA/QC Batch	QC Type	Parameter	Date Analyzed yyyy/mm/dd	Value	Recovery	Units	QC Limits
1893677 HRE	MATRIX SPIKE	. Lead (Pb)	2009/07/30		99	%	80 - 120
	Spiked Blank	. Lead (Pb)	2009/07/30		102	%	90 - 110
	Method Blank	. Lead (Pb)	2009/07/30	ND, RDL=0.0005		mg/L	
	RPD	. Lead (Pb)	2009/07/30	3.2		%	25

ND = Not detected
 RPD = Relative Percent Difference
 SPIKE = Fortified sample

Notification Log

Maxxam Job #: A993303
Report Date: 2009/07/30

Dufferin-Peel Catholic District School Board
PROJECT #: HOLY SPIRIT
Site: 500012104

No Reportable Regulation Exceedences Noted.

Validation Signature Page

Maxxam Job #: A993303

The analytical data and all QC contained in this report were reviewed and validated by the following individual(s).

Cristina Nervo

CRISTINA NERVO, Scientific Services

=====

Maxxam has procedures in place to guard against improper use of the electronic signature and have the required "signatories", as per section 5.10.2 of ISO/IEC 17025:2005(E), signing the reports. SCC and CALA have approved this reporting process and electronic report format.

23-Jul-09 10:14

JAMES ASPIN



A993303

AKP ENV-950



REGULATION 243 DRINKING WATER SUBMISSION CHAIN OF CUSTODY RECORD

Tel: 905-817-5700
Fax: 905-817-5779
Toll Free: 1-800-563-6266

Samples are Regulated
Under Reg 243

Maxxam Analytics
CAM FCD-00196/5
Page 1 of 1

Report to:

Company Name: Dufferin-Peel Catholic District School Board
Client Contact: Roland Lawton, General Manager of Physical Plant Facilities
Address: 5685 Keaton Cres., Mississauga ON L5R 3H5
E-Mail: roland.lawton@dpcdsb.org Tel: 905-890-0708 ext. 23204
Project: Regulation 243 Fax: 905-890-5841
Quote #: A54027 P.O.#: BN501012
Lab Service Rep.: James Aspen

Invoice to:

Tapped In

PAGE OF
CHECK ANALYSIS REQUESTED
Specify School Type
M.O.E. Assigned Water System Number
School Private School Day nursery

Sample Identification	Sample Type (Please Specify Standing / Flushed)	Date Sampled	Time Sampled	Field Chlorine		No. of Bottles	Lead	School	Private School	Day nursery	M.O.E. Assigned Water System Number
				Total	Free						
Holy Spirit											500012104
Kitchen - Staffroom	Standing	JUNE 19 2009	7:00 AM			1	x				
Kitchen - Staffroom	Flushed	JUNE 19 2009	7:35 AM			1	x				

DW METALS PRESERVATION CHECKED

In accordance with the Safe Drinking Water Act (2002), notification of adverse results must be reported to the SAC, MOH & Waterworks. Failure to do so is an offence under the act. It is IMPERATIVE that the shaded areas be filled out completely before submitting to Maxxam Analytics.

TAT (Turnaround Time)	Notification Information for School, Private Schools & Day Nurseries			LABORATORY USE ONLY	
RUSH TAT MUST HAVE PRIOR APPROVAL	Facility Name: Holy Spirit	Medical Officer of Health		Received By: <u>Alisa Pote</u>	
	Facility Address: 25 Bloomsbury Ave.	Region: Peel, Region		Date: <u>09/17/23</u>	Time: <u>10/9</u>
<input checked="" type="checkbox"/> Normal (5-15 Working Days)	Brampton L6P 1W9			Comments:	
<input type="checkbox"/> RUSH (Specify Below)	Contact: Holy Spirit	Tel #:			
Date Due:	Tel: 794-1285 Fax: 794-1285	Fax #:			
PN #	E-mail:				
Sampled By (Print Name): <u>NICOLA - TOBIN</u>	Sampled By (Sign Name): <u>[Signature]</u>		Receiving Temp <input type="checkbox"/> 11 <input type="checkbox"/> 17 <input checked="" type="checkbox"/> 11°C		
Relinquished by (Print Name): Tapped In Consulting	Date: <u>JUNE 19 - 2009</u>		Laboratory Prepared Container		
Relinquished by (Sign Name): Tapped In Consulting	Time:		<input checked="" type="checkbox"/> Yes <input type="checkbox"/> No		

***Samples submitted to Maxxam Analytics must be received below 10°C. It is the Sampler's responsibility to ensure adequate cooling is provided so that this receiving temperature is met.

***A separate COC document must be used for each individual water sample. Page 7 of 7

***All shaded areas must be filled out. Samples accompanied by an incomplete COC will not be processed.

09 JUL 23 10:14