

Your P.O. #: BN501012  
Your Project #: SAN LORENZO RUIZ  
Site:500019020  
Your C.O.C. #: n/a

**Attention: Roland Lawton**  
Dufferin-Peel Catholic District School Board  
40 Matheson Blvd  
Mississauga, ON  
CANADA L5R 1C5

**Report Date: 2009/06/30**

**CERTIFICATE OF ANALYSIS**

**MAXXAM JOB #: A974799**  
**Received: 2009/06/18, 13:17**

Sample Matrix: Water  
# Samples Received: 2

Analyses	Quantity	Date Extracted	Date Analyzed	Laboratory Method	Method Reference
Metals Analysis by ICPMS (as received) ¶	2	2009/06/27	2009/06/29	CAM SOP-00447	EPA 6020

\* RPDs calculated using raw data. The rounding of final results may result in the apparent difference.

(1) Metals analysis was performed on the sample 'as received'.

**Encryption Key**

Please direct all questions regarding this Certificate of Analysis to your Project Manager.

JAMES ASPIN, Project Manager  
Email: James.Aspin@maxxamAnalytics.com  
Phone# (905) 817-5700 Ext:5771

=====

Maxxam has procedures in place to guard against improper use of the electronic signature and have the required "signatories", as per section 5.10.2 of ISO/IEC 17025:2005(E), signing the reports. SCC and CALA have approved this reporting process and electronic report format.

For Service Group specific validation please refer to the Validation Signature Page

Total cover pages: 1

Maxxam Job #: A974799  
 Report Date: 2009/06/30

Dufferin-Peel Catholic District School Board  
 Client Project #: SAN LORENZO RUIZ  
 Project name: 500019020  
 Your P.O. #: BN501012

**ELEMENTS BY ATOMIC SPECTROSCOPY (WATER)**

Maxxam ID			CV2963	CV2964		
Sampling Date			2009/06/17 06:08	2009/06/17 06:43		
COC Number			n/a	n/a		
	<b>Units</b>	<b>Criteria</b>	<b>SAN LORENZO RUIZ KITCHEN STAFFROOM(STANDING)</b>	<b>SAN LORENZO RUIZ KITCHEN STAFFROOM(FLUSHED)</b>	<b>RDL</b>	<b>QC Batch</b>

<b>Metals</b>						
. Lead (Pb)	mg/L	<b>0.01</b>	0.0026	0.0044	0.0005	1861500

N/A = Not Applicable  
 RDL = Reportable Detection Limit  
 QC Batch = Quality Control Batch  
 Criteria: Ontario Regulation 243/07 made under the Safe Drinking Water Act, 2002.  
 Released June 7, 2007

Maxxam Job #: A974799  
Report Date: 2009/06/30

Dufferin-Peel Catholic District School Board  
Client Project #: SAN LORENZO RUIZ  
Project name: 500019020  
Your P.O. #: BN501012

Package 1	7.0°C
-----------	-------

Each temperature is the average of up to three cooler temperatures taken at receipt

**GENERAL COMMENTS**

**Results relate only to the items tested.**

Dufferin-Peel Catholic District School Board  
 Attention: Roland Lawton  
 Client Project #: SAN LORENZO RUIZ  
 P.O. #: BN501012  
 Project name: 500019020

Quality Assurance Report  
 Maxxam Job Number: MA974799

QA/QC Batch	QC Type	Parameter	Date Analyzed yyyy/mm/dd	Value	Recovery	Units	QC Limits
1861500 GBU	MATRIX SPIKE	. Lead (Pb)	2009/06/29		100	%	80 - 120
	Spiked Blank	. Lead (Pb)	2009/06/29		96	%	90 - 110
	Method Blank	. Lead (Pb)	2009/06/29	ND, RDL=0.0005		mg/L	
	RPD	. Lead (Pb)	2009/06/29	NC		%	25

ND = Not detected  
 NC = Non-calculable  
 RPD = Relative Percent Difference  
 SPIKE = Fortified sample

**Notification Log**

Maxxam Job #: A974799  
Report Date: 2009/06/30

Dufferin-Peel Catholic District School Board  
PROJECT #: SAN LORENZO RUIZ  
Site: 500019020



No Reportable Regulation Exceedences Noted.

## Validation Signature Page

**Maxxam Job #: A974799**

---

The analytical data and all QC contained in this report were reviewed and validated by the following individual(s).



---

TROY CARRIERE, B.Sc., C.Chem, Scientific Specialist

=====

Maxxam has procedures in place to guard against improper use of the electronic signature and have the required "signatories", as per section 5.10.2 of ISO/IEC 17025:2005(E), signing the reports. SCC and CALA have approved this reporting process and electronic report format.