

Your Project #: ST. BONAVENTURE
Site:500124554
Your C.O.C. #: n/a

Attention: Roland Lawton
Dufferin-Peel Catholic District School Board
40 Matheson Blvd
Mississauga, ON
CANADA L5R 1C5

Report Date: 2009/07/29

CERTIFICATE OF ANALYSIS

MAXXAM JOB #: A993316
Received: 2009/07/23, 10:15

Sample Matrix: Water
Samples Received: 2

Analyses	Quantity	Date Extracted	Date Analyzed	Laboratory Method	Method Reference
Metals Analysis by ICPMS (as received) 0	2	2009/07/29	2009/07/29	CAM SOP-00447	EPA 6020

* RPDs calculated using raw data. The rounding of final results may result in the apparent difference.

(1) Metals analysis was performed on the sample 'as received'.

Encryption Key

Please direct all questions regarding this Certificate of Analysis to your Project Manager.

JAMES ASPIN, Project Manager
Email: James.Aspin@maxxamAnalytics.com
Phone# (905) 817-5700 Ext:5771

=====
Maxxam has procedures in place to guard against improper use of the electronic signature and have the required "signatories", as per section 5.10.2 of ISO/IEC 17025:2005(E), signing the reports. SCC and CALA have approved this reporting process and electronic report format.

For Service Group specific validation please refer to the Validation Signature Page

Total cover pages: 1

Maxxam Job #: A993316
 Report Date: 2009/07/29

Dufferin-Peel Catholic District School Board
 Client Project #: ST. BONAVENTURE
 Project name: 500124554

ELEMENTS BY ATOMIC SPECTROSCOPY (WATER)

Maxxam ID			DE0868		DE0869		
Sampling Date			2009/07/07		2009/07/07		
			08:05		08:45		
COC Number			n/a		n/a		
	Units	Criteria	ST.	QC Batch	ST.	RDL	QC Batch
			BONAVENTURE(STANDING)		BONAVENTURE(FLUSHED)		

Metals							
. Lead (Pb)	mg/L	0.01	0.0019	1891980	0.0031	0.0005	1891935

N/A = Not Applicable
 RDL = Reportable Detection Limit
 QC Batch = Quality Control Batch
 Criteria: Ontario Regulation 243/07 made under the Safe Drinking Water Act, 2002.
 Released June 7, 2007

Maxxam Job #: A993316
Report Date: 2009/07/29

Dufferin-Peel Catholic District School Board
Client Project #: ST. BONAVENTURE
Project name: 500124554

Package 1	13.0°C
-----------	--------

Each temperature is the average of up to three cooler temperatures taken at receipt

GENERAL COMMENTS

Results relate only to the items tested.

Dufferin-Peel Catholic District School Board
 Attention: Roland Lawton
 Client Project #: ST. BONAVENTURE
 P.O. #:
 Project name: 500124554

Quality Assurance Report
 Maxxam Job Number: MA993316

QA/QC Batch	QC Type	Parameter	Date Analyzed yyyy/mm/dd	Value	Recovery	Units	QC Limits
1891935 ADA	MATRIX SPIKE	. Lead (Pb)	2009/07/29		98	%	80 - 120
	Spiked Blank	. Lead (Pb)	2009/07/29		96	%	90 - 110
	Method Blank	. Lead (Pb)	2009/07/29	ND, RDL=0.0005		mg/L	
	RPD	. Lead (Pb)	2009/07/29	0.8		%	25
1891980 ADA	MATRIX SPIKE	. Lead (Pb)	2009/07/29		99	%	80 - 120
	Spiked Blank	. Lead (Pb)	2009/07/29		95	%	90 - 110
	Method Blank	. Lead (Pb)	2009/07/29	ND, RDL=0.0005		mg/L	
	RPD	. Lead (Pb)	2009/07/29	1.6		%	25

ND = Not detected
 RPD = Relative Percent Difference
 SPIKE = Fortified sample

Notification Log

Maxxam Job #: A993316
Report Date: 2009/07/29

Dufferin-Peel Catholic District School Board
PROJECT #: ST. BONAVENTURE
Site: 500124554

No Reportable Regulation Exceedences Noted.

Validation Signature Page

Maxxam Job #: A993316

The analytical data and all QC contained in this report were reviewed and validated by the following individual(s).

Cristina Nervo

CRISTINA NERVO, Scientific Services

Eva Pranjic



EWA PRANJIC, M.Sc., C.Chem, Scientific Specialist

=====

Maxxam has procedures in place to guard against improper use of the electronic signature and have the required "signatories", as per section 5.10.2 of ISO/IEC 17025:2005(E), signing the reports. SCC and CALA have approved this reporting process and electronic report format.

23-Jul-09 10:15

JAMES ASPIN



A993316

AKP

ENV-950

REGULATION 243 DRINKING WATER SUBMISSION CHAIN OF CUSTODY RECORD

Tel: 905-817-5700
Fax: 905-817-5779
Toll Free: 1-800-563-6266

Samples are Regulated
Under Reg 243

Maxxam Analytics
CAM FCD-00196/5
Page 1 of 1

Report to:

Company Name: Dufferin-Peel Catholic District School Board
Client Contact: Roland Lawton, General Manager of Physical Plant Facilities
Address: 5685 Keaton Cres., Mississauga ON L5R 3H5
E-Mail: roland.lawton@dpcdsb.org Tel: 905-890-0708 ext. 23204
Project: Regulation 243 Fax: 905-890-5841
Quote #: A54027 P.O.#: BN501012
Lab Service Rep.: James Aspen

Invoice to:

Tapped In

PAGE		OF		
CHECK ANALYSIS REQUESTED				
Specify School Type	School	Private School	Day nursery	M.O.E. Assigned Water System Number
				500124554

Sample Identification	Sample Type (Please Specify Standing / Flushed)	Date Sampled	Time Sampled	Field Chlorine		No. of Bottles	Lead	School	Private School	Day nursery
				Total	Free					
St. Bonaventure										
Kitchen - Staffroom	Standing	July 2009	9:05			1	X			
Kitchen - Staffroom	Flushed	July 2009	8:45			1	X			

DW METALS PRESERVATION CHECKED

In accordance with the Safe Drinking Water Act (2002), notification of adverse results must be reported to the SAC, MOH & Waterworks. Failure to do so is an offence under the act. It is IMPERATIVE that the shaded areas be filled out completely before submitting to Maxxam Analytics.

TAT (Turnaround Time)	Notification Information for School, Private Schools & Day Nurseries		LABORATORY USE ONLY
RUSH TAT MUST HAVE PRIOR APPROVAL	Facility Name: St. Bonaventure	Medical Officer of Health	Received By: <i>Allea Polie</i>
	Facility Address: 35 McCrimmon Drive	Region: Peel Region	Date: 09/07/23 Time: 10:15
<input checked="" type="checkbox"/> Normal (5-15 Working Days)	Brampton L7A 2Z5		Comments:
<input type="checkbox"/> RUSH (Specify Below)	Contact: St. Bonaventure	Tel #:	
Date Due:	Tel: 925-970-9069 Fax: 454-8447	Fax #:	
PN #	E-mail:		
Sampled By (Print Name): <i>Phil Lawton</i>	Sampled By (Sign Name): <i>[Signature]</i>		Receiving Temp: <input type="checkbox"/> 11 <input checked="" type="checkbox"/> 17 <input type="checkbox"/> 11C Laboratory Prepared Container <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No
Relinquished by (Print Name): Tapped In Consulting	Date:		
Relinquished by (Sign Name): Tapped In Consulting	Time:		

SIF: Sample Inspection Resolved By: _____ Date: _____

***Samples submitted to Maxxam Analytics must be used for each individual water sample accompanied by an incomplete COC will not be processed. Page 7 of 7