

Your P.O. #: BN501012
Your Project #: ST. JOSEPH BR ES
Site:500012130
Your C.O.C. #: N/A

Attention: Roland Lawton
Dufferin-Peel Catholic District School Board
40 Matheson Blvd
Mississauga, ON
CANADA L5R 1C5

Report Date: 2009/06/29

CERTIFICATE OF ANALYSIS

MAXXAM JOB #: A974948
Received: 2009/06/18, 15:27

Sample Matrix: Water
Samples Received: 2

| Analyses | Quantity | Date Extracted | Date Analyzed | Laboratory Method | Method Reference |
|--|----------|-------------------|------------------|-------------------|---------------------|
| Metals Analysis by ICPMS (as received) ¶ | 2 | 2009/06/27 | 2009/06/28 | CAM SOP-00447 | EPA 6020 |

* RPDs calculated using raw data. The rounding of final results may result in the apparent difference.

(1) Metals analysis was performed on the sample 'as received'.

Encryption Key

Please direct all questions regarding this Certificate of Analysis to your Project Manager.

JAMES ASPIN, Project Manager
Email: James.Aspin@maxxamAnalytics.com
Phone# (905) 817-5700 Ext:5771

=====
Maxxam has procedures in place to guard against improper use of the electronic signature and have the required "signatories", as per section 5.10.2 of ISO/IEC 17025:2005(E), signing the reports. SCC and CALA have approved this reporting process and electronic report format.

For Service Group specific validation please refer to the Validation Signature Page

Total cover pages: 1

Maxxam Job #: A974948
 Report Date: 2009/06/29

Dufferin-Peel Catholic District School Board
 Client Project #: ST. JOSEPH BR ES
 Project name: 500012130
 Your P.O. #: BN501012

ELEMENTS BY ATOMIC SPECTROSCOPY (WATER)

| | | | | | | | |
|---------------|--------------|-----------------|--|-----------------|---|------------|-----------------|
| Maxxam ID | | | CV3764 | | CV3766 | | |
| Sampling Date | | | 2009/06/15 07:30 | | 2009/06/15 08:05 | | |
| COC Number | | | N/A | | N/A | | |
| | Units | Criteria | ST. JOSEPH BR ES KITCHEN-STAFFROOM STANDING | QC Batch | ST. JOSEPH BR ES KITCHEN-STAFFROOM FLUSHED | RDL | QC Batch |

| | | | | | | | |
|---------------|------|-------------|----|---------|----|--------|---------|
| Metals | | | | | | | |
| . Lead (Pb) | mg/L | 0.01 | ND | 1861457 | ND | 0.0005 | 1861447 |

ND = Not detected
 N/A = Not Applicable
 RDL = Reportable Detection Limit
 QC Batch = Quality Control Batch
 Criteria: Ontario Regulation 243/07 made under the Safe Drinking Water Act, 2002.

Released June 7, 2007

Maxxam Job #: A974948
Report Date: 2009/06/29

Dufferin-Peel Catholic District School Board
Client Project #: ST. JOSEPH BR ES
Project name: 500012130
Your P.O. #: BN501012

| | |
|-----------|-------|
| Package 1 | 4.7°C |
|-----------|-------|

Each temperature is the average of up to three cooler temperatures taken at receipt

GENERAL COMMENTS

Results relate only to the items tested.

Dufferin-Peel Catholic District School Board
 Attention: Roland Lawton
 Client Project #: ST. JOSEPH BR ES
 P.O. #: BN501012
 Project name: 500012130

Quality Assurance Report
 Maxxam Job Number: MA974948

| QA/QC Batch | QC Type | Parameter | Date Analyzed yyyy/mm/dd | Value | Recovery | Units | QC Limits |
|-------------|--------------|-------------|-----------------------------|----------------|----------|-------|-----------|
| 1861447 ADA | MATRIX SPIKE | . Lead (Pb) | 2009/06/28 | | 109 | % | 80 - 120 |
| | Spiked Blank | . Lead (Pb) | 2009/06/28 | | 103 | % | 90 - 110 |
| | Method Blank | . Lead (Pb) | 2009/06/28 | ND, RDL=0.0005 | | mg/L | |
| | RPD | . Lead (Pb) | 2009/06/28 | NC | | % | 25 |
| 1861457 ADA | MATRIX SPIKE | . Lead (Pb) | 2009/06/28 | | 103 | % | 80 - 120 |
| | Spiked Blank | . Lead (Pb) | 2009/06/28 | | 101 | % | 90 - 110 |
| | Method Blank | . Lead (Pb) | 2009/06/28 | ND, RDL=0.0005 | | mg/L | |
| | RPD | . Lead (Pb) | 2009/06/28 | NC | | % | 25 |

ND = Not detected
 NC = Non-calculable
 RPD = Relative Percent Difference
 SPIKE = Fortified sample

Notification Log

Maxxam Job #: A974948
Report Date: 2009/06/29

Dufferin-Peel Catholic District School Board
PROJECT #: ST. JOSEPH BR ES
Site: 500012130

No Reportable Regulation Exceedences Noted.

Validation Signature Page

Maxxam Job #: A974948

The analytical data and all QC contained in this report were reviewed and validated by the following individual(s).

Cristina Nervo

CRISTINA NERVO, Scientific Services

=====

Maxxam has procedures in place to guard against improper use of the electronic signature and have the required "signatories", as per section 5.10.2 of ISO/IEC 17025:2005(E), signing the reports. SCC and CALA have approved this reporting process and electronic report format.