

Your Project #: ST JOSEPHINE BAKHITA
 Site:500162202
 Your C.O.C. #: n/a

Attention: Roland Lawton
 Dufferin-Peel Catholic District School Board
 40 Matheson Blvd
 Mississauga, ON
 CANADA L5R 1C5

Report Date: 2009/07/31

CERTIFICATE OF ANALYSIS

MAXXAM JOB #: A993471
Received: 2009/07/23, 10:14

Sample Matrix: Water
 # Samples Received: 2

Analyses	Quantity	Date Extracted	Date Analyzed	Laboratory Method	Method Reference
Metals Analysis by ICPMS (as received) ¶	2	2009/07/30	2009/07/31	CAM SOP-00447	EPA 6020

* RPDs calculated using raw data. The rounding of final results may result in the apparent difference.

(1) Metals analysis was performed on the sample 'as received'.

Encryption Key

Please direct all questions regarding this Certificate of Analysis to your Project Manager.

JAMES ASPIN, Project Manager
 Email: James.Aspin@maxxamAnalytics.com
 Phone# (905) 817-5700 Ext:5771

=====

Maxxam has procedures in place to guard against improper use of the electronic signature and have the required "signatories", as per section 5.10.2 of ISO/IEC 17025:2005(E), signing the reports. SCC and CALA have approved this reporting process and electronic report format.

For Service Group specific validation please refer to the Validation Signature Page

Total cover pages: 1

Maxxam Job #: A993471
 Report Date: 2009/07/31

Dufferin-Peel Catholic District School Board
 Client Project #: ST JOSEPHINE BAKHITA
 Project name: 500162202

ELEMENTS BY ATOMIC SPECTROSCOPY (WATER)

Maxxam ID			DE1685	DE1686		
Sampling Date			2009/06/24 07:30	2009/06/24 08:08		
COC Number			n/a	n/a		
	Units	Criteria	ST. JOSEPHINE BAKHITA KITCHEN STAFFROOM(STANDING)	ST. JOSEPHINE BAKHITA KITCHEN STAFFROOM(FLUSHED)	RDL	QC Batch

Metals						
. Lead (Pb)	mg/L	0.01	0.0013	0.0013	0.0005	1894048

N/A = Not Applicable
 RDL = Reportable Detection Limit
 QC Batch = Quality Control Batch
 Criteria: Ontario Regulation 243/07 made under the Safe Drinking Water Act, 2002.
 Released June 7, 2007

Maxxam Job #: A993471
Report Date: 2009/07/31

Dufferin-Peel Catholic District School Board
Client Project #: ST JOSEPHINE BAKHITA
Project name: 500162202

Package 1	13.0°C
-----------	--------

Each temperature is the average of up to three cooler temperatures taken at receipt

GENERAL COMMENTS

Results relate only to the items tested.

Dufferin-Peel Catholic District School Board
 Attention: Roland Lawton
 Client Project #: ST JOSEPHINE BAKHITA
 P.O. #:
 Project name: 500162202

Quality Assurance Report
 Maxxam Job Number: MA993471

QA/QC Batch	QC Type	Parameter	Date Analyzed yyyy/mm/dd	Value	Recovery	Units	QC Limits
1894048 ADA	MATRIX SPIKE	. Lead (Pb)	2009/07/31		102	%	80 - 120
	Spiked Blank	. Lead (Pb)	2009/07/31		98	%	90 - 110
	Method Blank	. Lead (Pb)	2009/07/31	ND, RDL=0.0005		mg/L	
	RPD	. Lead (Pb)	2009/07/31	0.8		%	25

ND = Not detected
 RPD = Relative Percent Difference
 SPIKE = Fortified sample

Notification Log

Maxxam Job #: A993471
Report Date: 2009/07/31

Dufferin-Peel Catholic District School Board
PROJECT #: ST JOSEPHINE BAKHITA
Site: 500162202

No Reportable Regulation Exceedences Noted.

Validation Signature Page

Maxxam Job #: A993471

The analytical data and all QC contained in this report were reviewed and validated by the following individual(s).

Cristina Nervo

CRISTINA NERVO, Scientific Services

=====

Maxxam has procedures in place to guard against improper use of the electronic signature and have the required "signatories", as per section 5.10.2 of ISO/IEC 17025:2005(E), signing the reports. SCC and CALA have approved this reporting process and electronic report format.

23-Jul-09 10:14

JAMES ASPIN



A993471

AKP -ENV-950

Ontario L5N 2L8



REGULATION 243 DRINKING WATER SUBMISSION CHAIN OF CUSTODY RECORD

Tel: 905-817-5700
Fax: 905-817-5779
Toll Free: 1-800-563-6266

Samples are Regulated
Under Reg 243

Maxxam Analytics
CAM FCD-00196/3

Report to:

Company Name: Dufferin-Peel Catholic District School Board
 Client Contact: Roland Lawton, General Manager of Physical Plant Facilities
 Address: 5685 Keaton Cres., Mississauga ON L5R 3H5
 E-Mail: roland.lawton@dpcdsb.org Tel: 905-890-0708 ext. 23204
 Project: Regulation 243 Fax: 905-890-5841
 Quote #: A83456 P.O.#: BN500636
 Lab Service Rep.: James Aspen

Invoice to: Same as "Report to"

PAGE _____ OF _____

ANALYSIS REQUESTED

Specify School Type

M.O.E. Assigned Water System Number

School	Private School	Day nursery
<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>

Sample Identification	Sample Type (Please Specify Standing / Flushed)	Date Sampled	Time Sampled	Sampler Initials	Field Chlorine		No. of Bottles	Lead	ANALYSIS REQUESTED		
					Total	Free			School	Private School	Day nursery
Kitchen - Staffroom	Standing	June 24	7:30am	Initial			1	X	X		
Kitchen - Staffroom	Flushed	June 24	8:08am	Initial			1	X	X		

* In accordance with the Safe Drinking Water Act (2002), notification of adverse results must be reported to the SAC, MOH & Waterworks. Failure to do so is an offence under the act. It is **IMPERATIVE** that the areas shaded in grey be filled out completely before submitting to Maxxam Analytics.

TAT (Turnaround Time)	Notification Information for School, Private Schools & Day Nurseries		LABORATORY USE ONLY	
RUSH TAT MUST HAVE PRIOR APPROVAL	Facility Name: SAMPLE	Medical Officer of Health	Received By: <i>Alka Patel</i>	
<input checked="" type="checkbox"/> Normal (5-15 Working Days)	Facility Address:	Region: Peel Region	Date: <i>29/6/23</i>	Time: <i>10:14</i>
<input type="checkbox"/> RUSH (Specify Below)		Tel #:	Comments:	
Date Due:	Tel:	Fax:	<i>16, 17, 11c</i>	
PN #	E-mail:	Email:		
Relinquished by (Sign Name): CUSTODIANS SIGNATURE <i>Michael Narciso</i>	Date: <i>June 24th, 2007</i>	Laboratory Prepared Container:		
Relinquished by (Print Name): CUSTODIAN NAME PRINTED <i>Michael Narciso</i>	Time: <i>7:30am</i>	<input checked="" type="checkbox"/> Yes <input type="checkbox"/> No		

SIF : Sample Inspection
 Resolved By: _____
 Date: _____

NOTE: Samples submitted to Maxxam Analytics is the Sampler's responsibility to ensure adequate cooling is provided. Please ensure that a separate COC document is used.

DW METALS PRESERVATION CHECKED

109 JUL 23 10:14