

Your P.O. #: BN501012
Your Project #: ST. ROSE OF LIMA
Site:500013820
Your C.O.C. #: n/a

Attention: Roland Lawton

Dufferin-Peel Catholic District School Board
40 Matheson Blvd
Mississauga, ON
CANADA L5R 1C5

Report Date: 2009/06/25

CERTIFICATE OF ANALYSIS

MAXXAM JOB #: A974854

Received: 2009/06/18, 12:25

Sample Matrix: Water
Samples Received: 2

| Analyses | Quantity | Date Extracted | Date Analyzed | Laboratory Method | Method Reference |
|--|----------|-------------------|------------------|-------------------|---------------------|
| Metals Analysis by ICPMS (as received) ¶ | 2 | 2009/06/24 | 2009/06/24 | CAM SOP-00447 | EPA 6020 |

* RPDs calculated using raw data. The rounding of final results may result in the apparent difference.

(1) Metals analysis was performed on the sample 'as received'.

Encryption Key

Please direct all questions regarding this Certificate of Analysis to your Project Manager.

JAMES ASPIN, Project Manager
Email: James.Aspin@maxxamAnalytics.com
Phone# (905) 817-5700 Ext:5771

=====
Maxxam has procedures in place to guard against improper use of the electronic signature and have the required "signatories", as per section 5.10.2 of ISO/IEC 17025:2005(E), signing the reports. SCC and CALA have approved this reporting process and electronic report format.

For Service Group specific validation please refer to the Validation Signature Page

Total cover pages: 1

Maxxam Job #: A974854
 Report Date: 2009/06/25

Dufferin-Peel Catholic District School Board
 Client Project #: ST. ROSE OF LIMA
 Project name: 500013820
 Your P.O. #: BN501012

ELEMENTS BY ATOMIC SPECTROSCOPY (WATER)

| | | | | | |
|---------------|--------------|-----------------|--|------------|-----------------|
| Maxxam ID | | | CV3227 | | |
| Sampling Date | | | 2009/06/17 07:00 | | |
| COC Number | | | n/a | | |
| | Units | Criteria | ST.ROSE OF LIMA(KITCHEN-STAFFROOM)STAND ING | RDL | QC Batch |

| | | | | | |
|---|------|-------------|--------|--------|---------|
| Metals | | | | | |
| . Lead (Pb) | mg/L | 0.01 | 0.0031 | 0.0005 | 1857899 |
| <p>N/A = Not Applicable RDL = Reportable Detection Limit QC Batch = Quality Control Batch Criteria: Ontario Regulation 243/07 made under the Safe Drinking Water Act, 2002. Released June 7, 2007</p> | | | | | |

| | | | | | |
|---------------|--------------|-----------------|---|------------|-----------------|
| Maxxam ID | | | CV3228 | | |
| Sampling Date | | | 2009/06/17 07:38 | | |
| COC Number | | | n/a | | |
| | Units | Criteria | ST.ROSE OF LIMA(KITCHEN-STAFFROOM)FLUSH ED | RDL | QC Batch |

| | | | | | |
|---|------|-------------|--------|--------|---------|
| Metals | | | | | |
| . Lead (Pb) | mg/L | 0.01 | 0.0021 | 0.0005 | 1857899 |
| <p>N/A = Not Applicable RDL = Reportable Detection Limit QC Batch = Quality Control Batch Criteria: Ontario Regulation 243/07 made under the Safe Drinking Water Act, 2002. Released June 7, 2007</p> | | | | | |

Maxxam Job #: A974854
Report Date: 2009/06/25

Dufferin-Peel Catholic District School Board
Client Project #: ST. ROSE OF LIMA
Project name: 500013820
Your P.O. #: BN501012

| | |
|-----------|-------|
| Package 1 | 2.3°C |
|-----------|-------|

Each temperature is the average of up to three cooler temperatures taken at receipt

GENERAL COMMENTS

Results relate only to the items tested.

Dufferin-Peel Catholic District School Board
 Attention: Roland Lawton
 Client Project #: ST. ROSE OF LIMA
 P.O. #: BN501012
 Project name: 500013820

Quality Assurance Report
 Maxxam Job Number: MA974854

| QA/QC Batch | QC Type | Parameter | Date Analyzed yyyy/mm/dd | Value | Recovery | Units | QC Limits |
|-------------|--------------|-------------|-----------------------------|----------------|----------|-------|-----------|
| 1857899 HRE | MATRIX SPIKE | . Lead (Pb) | 2009/06/24 | | 99 | % | 80 - 120 |
| | Spiked Blank | . Lead (Pb) | 2009/06/24 | | 97 | % | 90 - 110 |
| | Method Blank | . Lead (Pb) | 2009/06/24 | ND, RDL=0.0005 | | mg/L | |
| | RPD | . Lead (Pb) | 2009/06/24 | NC | | % | 25 |

ND = Not detected
 NC = Non-calculable
 RPD = Relative Percent Difference
 SPIKE = Fortified sample

Notification Log

Maxxam Job #: A974854
Report Date: 2009/06/25



Dufferin-Peel Catholic District School Board
PROJECT #: ST. ROSE OF LIMA
Site: 500013820

No Reportable Regulation Exceedences Noted.

Validation Signature Page

Maxxam Job #: A974854

The analytical data and all QC contained in this report were reviewed and validated by the following individual(s).



TROY CARRIERE, B.Sc., C.Chem, Scientific Specialist

=====

Maxxam has procedures in place to guard against improper use of the electronic signature and have the required "signatories", as per section 5.10.2 of ISO/IEC 17025:2005(E), signing the reports. SCC and CALA have approved this reporting process and electronic report format.