

**The Dufferin-Peel Catholic District School Board**

**Water - Secondary Schools Lead Testing Results 2007**

<b>Maximum Allowable Lead</b>	<b>MG/L</b> 0.01	<b>MG/L</b> 0.01
<b>Results (ND=none detected)</b>	<b>Standing</b>	<b>Flushed</b>
<b>School</b>		
Archbishop Romero-Miss Campus	0.0025	ND
Archbishop Romero Catholic SS	0.0023	ND
Ascension of Our Lord	ND	ND
Cardinal Leger SS	0.0052	0.0015
Fr. Michael Goetz SS	0.0007	ND
Holy Name of Mary SS	0.014	0.0021
IONA SS	0.0007	0.0011
John Cabot Catholic SS	0.0020	0.0007
Loyola Catholic SS	0.0098	0.0012
Notre Dame Catholic SS	0.0078	0.0021
Our Lady of Mt.Carmel SS	0.0047	0.0042
Philip Pocock Catholic	0.0040	0.0012
Robert F. Hall Catholic	0.0007	ND
St. Aloysius Gonzaga SS	0.0016	ND
St. Augustine SS	0.0014	0.0007
St. Edmund Campion S.S.	0.0005	ND
St. Francis Xavier SS	ND	ND
St. Joseph SS	0.0008	ND
St. Joan of Arc Catholic	-	-
St. Marcellinus	ND	ND
St. Marguerite d'Youville SS	0.0018	0.0009
St. Martin SS	ND	0.0012
St. Paul SS	0.0057	0.0024
St. Thomas Aquinas SS	ND	ND