

Your Project #: ALL SAINTS
Site:500018942
Your C.O.C. #: NA

Attention: Roland Lawton
Dufferin Peel Catholic District...
School Board
40 Matheson Blvd W
Mississauga, ON
L5R 1C5

Report Date: 2008/07/28

CERTIFICATE OF ANALYSIS

MAXXAM JOB #: A878039
Received: 2008/07/17, 15:01

Sample Matrix: Water
Samples Received: 2

Analyses	Quantity	Date Extracted	Date Analyzed	Laboratory Method	Method Reference
Metals Analysis by ICPMS (as received) ①	1	2008/07/25	2008/07/25	CAM SOP-00447	EPA 6020
Metals Analysis by ICPMS (as received) ①	1	2008/07/25	2008/07/26	CAM SOP-00447	EPA 6020

* RPDs calculated using raw data. The rounding of final results may result in the apparent difference.

(1) Metals analysis was performed on the sample 'as received'.

Encryption Key

Please direct all questions regarding this Certificate of Analysis to your Project Manager.

JAMES ASPIN, Project Manager
Email: James.Aspin@maxxamAnalytics.com
Phone# (905) 817-5700 Ext:5771

=====
Maxxam has procedures in place to guard against improper use of the electronic signature and have the required "signatories", as per section 5.10.2 of ISO/IEC 17025:2005(E), signing the reports. SCC and CAEAL have approved this reporting process and electronic report format.

For Service Group specific validation please refer to the Validation Signature Page

Total cover pages: 1

Maxxam Job #: A878039
Report Date: 2008/07/28

Dufferin Peel Catholic District...
Client Project #: ALL SAINTS
Project name: 500018942
Sampler Initials: PR

ELEMENTS BY ATOMIC SPECTROSCOPY (WATER)

Maxxam ID			Z95640		
Sampling Date			2008/07/17 06:20		
COC Number			NA		
	Units	Criteria	ALL SAINTS KITCHEN-STAFFROOM/STANDING	RDL	QC Batch

Metals					
. Lead (Pb)	mg/L	0.01	0.0062	0.0005	1571011
RDL = Reportable Detection Limit QC Batch = Quality Control Batch CRITERIA: Ontario Regulation 243/07 made under the Safe Drinking Water Act, 2002. Released June 7, 2007					

Maxxam ID			Z95641		
Sampling Date			2008/07/17 06:55		
COC Number			NA		
	Units	Criteria	ALL SAINTS KITCHEN-STAFFROOM/FLUSHED	RDL	QC Batch

Metals					
. Lead (Pb)	mg/L	0.01	0.0022	0.0005	1570400
RDL = Reportable Detection Limit QC Batch = Quality Control Batch CRITERIA: Ontario Regulation 243/07 made under the Safe Drinking Water Act, 2002. Released June 7, 2007					

Maxxam Job #: A878039
Report Date: 2008/07/28

Dufferin Peel Catholic District...
Client Project #: ALL SAINTS
Project name: 500018942
Sampler Initials: PR

Package 1	10.0°C
-----------	--------

Each temperature is the average of up to three cooler temperatures taken at receipt

GENERAL COMMENTS

Results relate only to the items tested.

Dufferin Peel Catholic District...
Attention: Roland Lawton
Client Project #: ALL SAINTS
P.O. #:
Project name: 500018942

Quality Assurance Report
Maxxam Job Number: MA878039

QA/QC Batch	QC Type	Parameter	Date Analyzed yyyy/mm/dd	Value	Recovery	Units	QC Limits
1570400 HRE	MATRIX SPIKE	. Lead (Pb)	2008/07/25		100	%	80 - 120
	Spiked Blank	. Lead (Pb)	2008/07/25		101	%	85 - 115
	Method Blank	. Lead (Pb)	2008/07/25	ND, RDL=0.5		ug/L	
	RPD	. Lead (Pb)	2008/07/25	NC		%	25
1571011 HRE	MATRIX SPIKE	. Lead (Pb)	2008/07/26		100	%	80 - 120
	[Z95640-01]	. Lead (Pb)	2008/07/26		100	%	85 - 115
	Spiked Blank	. Lead (Pb)	2008/07/26				
	Method Blank	. Lead (Pb)	2008/07/26	ND, RDL=0.5		ug/L	
	RPD [Z95640-01]	. Lead (Pb)	2008/07/26	1.5		%	25

ND = Not detected
NC = Non-calculable
RPD = Relative Percent Difference
SPIKE = Fortified sample

Validation Signature Page

Maxxam Job #: A878039

The analytical data and all QC contained in this report were reviewed and validated by the following individual(s).

 

EWA PRANJIC, M.Sc., C.Chem, Scientific Specialist

=====

Maxxam has procedures in place to guard against improper use of the electronic signature and have the required "signatories", as per section 5.10.2 of ISO/IEC 17025:2005(E), signing the reports. SCC and CAEAL have approved this reporting process and electronic report format.



6740 Campobello Rd
Mississauga
Ontario L5N 2L8

REGULATION 243 DRINKING WATER SUPPLY CHAIN OF CUSTODY RECORD

Tel: 905-817-5700
Fax: 905-817-5779
Toll Free: 1-800-563-6266

Samples are Regulated
Under Reg 243

17-Jul-08 15:01
JAMES ASPIN
 A878039
FW ENV-948
CAM FCD-00196/2

Report to:

Company Name: Dufferin-Peel Catholic District School Board
Client Contact: Roland Lawton, General Manager of Physical Plant Facilities
Address: 5685 Keaton Cres., Mississauga ON L5R 3H5
E-Mail: roland.lawton@dpccdsb.org Tel: 905-890-0708 ext. 23204
Project: Regulation 243 Fax: 905-890-5841
Quote #: A83456 P.O.#: BN500636
Lab Service Rep.: James Aspin

Invoice to: Same as "Report to"

**DW METALS
PRESERVATION
CHECKED**

PAGE ____ OF ____

ANALYSIS REQUESTED

Specify School Type	M.O.E. Assigned Water System Number
School	
Private School Day nursery	
	500018942

Sample Identification	Sample Type (Please Specify Standing / Flushed)	Date Sampled	Time Sampled	Sampler Initials	Field Chlorine		No. of Bottles	Lead
					Total	Free		
All Saints								
Kitchen - Staffroom	Standing	7/17/08	6:20 AM				1	x
Kitchen - Staffroom	Flushed	7/17/08	6:58 AM				1	x

* In accordance with the Safe Drinking Water Act (2002), notification of adverse results must be reported to the SAC, MOH & Waterworks. Failure to do so is an offence under the act. It is **IMPERATIVE** that the areas shaded in grey be filled out completely before submitting to Maxxam Analytics.

TAT (Turnaround Time)	Notification Information for School, Private Schools & Day Nurseries		LABORATORY USE ONLY	
RUSH TAT MUST HAVE PRIOR APPROVAL	Facility Name: All Saints	Medical Officer of Health	Received By: <i>J. JONGWANG</i>	
<input checked="" type="checkbox"/> Normal (5-15 Working Days)	Facility Address: 4105 Colonial Drive	Region: Peel Region	Date: 08/07/17 Time: 15:01	
<input type="checkbox"/> RUSH (Specify Below)	Mississauga, ON L5L 4E8	Tel #:	Comments: 10/10/10	
Date Due:	Tel: 905-828-6348 Fax: 905-828-1744	Fax #:		
PN #	E-mail:	Email:		
Relinquished by (Sign Name):	Date: JULY 17/08	Laboratory Prepared Container: <input type="checkbox"/> Yes <input type="checkbox"/> No		
Relinquished by (Print Name): <i>PHILLIP REALE</i>	Time: 6:20 AM			

NOTE: Samples submitted to Maxxam Analytics must be received below 10°C. It is the Sampler's responsibility to ensure adequate cooling is provided so that this receiving temperature is met. Please ensure that a separate COC document is used for each individual waterworks.