

Your P.O. #: BN500636
Your Project #: CHRIST THE KING
Site:500019475
Your C.O.C. #: NA

Attention: Roland Lawton
Dufferin Peel Catholic District...
School Board
40 Matheson Blvd W
Mississauga, ON
L5R 1C5

Report Date: 2008/07/24

CERTIFICATE OF ANALYSIS

MAXXAM JOB #: A877962
Received: 2008/07/17, 14:17

Sample Matrix: Water
Samples Received: 2

Analyses	Quantity	Date Extracted	Date Analyzed	Laboratory Method	Method Reference
Metals Analysis by ICPMS (as received) 0	2	2008/07/22	2008/07/23	CAM SOP-00447	EPA 6020

* RPDs calculated using raw data. The rounding of final results may result in the apparent difference.

(1) Metals analysis was performed on the sample 'as received'.

Encryption Key

Please direct all questions regarding this Certificate of Analysis to your Project Manager.

JAMES ASPIN, Project Manager
Email: James.Aspin@maxxamAnalytics.com
Phone# (905) 817-5700 Ext:5771

=====
Maxxam has procedures in place to guard against improper use of the electronic signature and have the required "signatories", as per section 5.10.2 of ISO/IEC 17025:2005(E), signing the reports. SCC and CAEAL have approved this reporting process and electronic report format.

For Service Group specific validation please refer to the Validation Signature Page

Total cover pages: 1

Maxxam Job #: A877962
Report Date: 2008/07/24

Dufferin Peel Catholic District...
Client Project #: CHRIST THE KING
Project name: 500019475
Your P.O. #: BN500636

ELEMENTS BY ATOMIC SPECTROSCOPY (WATER)

Maxxam ID			Z95398		
Sampling Date			2008/07/17 06:00		
COC Number			NA		
	Units	Criteria	CHRIST THE KING CATHOLIC/KITCHEN-STAFFROOM/ST ANDING	RDL	QC Batch

Metals					
. Lead (Pb)	mg/L	0.01	0.0023	0.0005	1567343
<p>RDL = Reportable Detection Limit QC Batch = Quality Control Batch CRITERIA: Ontario Regulation 243/07 made under the Safe Drinking Water Act, 2002. Released June 7, 2007</p>					

Maxxam ID			Z95399		
Sampling Date			2008/07/17 06:35		
COC Number			NA		
	Units	Criteria	CHRIST THE KING CATHOLIC/KITCHEN-STAFFROOM/FL USHED	RDL	QC Batch

Metals					
. Lead (Pb)	mg/L	0.01	ND	0.0005	1567343
<p>ND = Not detected RDL = Reportable Detection Limit QC Batch = Quality Control Batch CRITERIA: Ontario Regulation 243/07 made under the Safe Drinking Water Act, 2002. Released June 7, 2007</p>					

Maxxam Job #: A877962
Report Date: 2008/07/24

Dufferin Peel Catholic District...
Client Project #: CHRIST THE KING
Project name: 500019475
Your P.O. #: BN500636

Package 1	10.0°C
-----------	--------

Each temperature is the average of up to three cooler temperatures taken at receipt

GENERAL COMMENTS

Results relate only to the items tested.

Dufferin Peel Catholic District...
Attention: Roland Lawton
Client Project #: CHRIST THE KING
P.O. #: BN500636
Project name: 500019475

Quality Assurance Report
Maxxam Job Number: MA877962

QA/QC Batch	QC Type	Parameter	Date Analyzed yyyy/mm/dd	Value	Recovery	Units	QC Limits
1567343 JBW	MATRIX SPIKE	. Lead (Pb)	2008/07/23		101	%	80 - 120
	Spiked Blank	. Lead (Pb)	2008/07/23		97	%	85 - 115
	Method Blank	. Lead (Pb)	2008/07/23	ND, RDL=0.5		ug/L	
	RPD	. Lead (Pb)	2008/07/23	NC		%	25

ND = Not detected
NC = Non-calculable
RPD = Relative Percent Difference
SPIKE = Fortified sample

Validation Signature Page

Maxxam Job #: A877962

The analytical data and all QC contained in this report were reviewed and validated by the following individual(s).



TROY CARRIERE, B.Sc., C.Chem, Scientific Specialist

=====

Maxxam has procedures in place to guard against improper use of the electronic signature and have the required "signatories", as per section 5.10.2 of ISO/IEC 17025:2005(E), signing the reports. SCC and CAEAL have approved this reporting process and electronic report format.



6740 Campobello Rd
Mississauga
Ontario L5N 2L8

REGULATION 243 DRINKING WATER S CHAIN OF CUSTODY RECO

Tel: 905-817-5700
Fax: 905-817-5779
Toll Free: 1-800-563-6266

Samples are Regular
Under Reg 243

17-Jul-08 14:17
JAMES ASPIN



A877962
FW ENV-756

Maxxam Analytics Inc.
CAM FCD-00196/2

Report to:

Company Name: Dufferin-Peel Catholic District School Board	
Client Contact: Roland Lawton, General Manager of Physical Plant Facilities	
Address: 5685 Keaton Cres., Mississauga ON L5R 3H5	
E-Mail: <u>roland.lawton@dpcdsb.org</u>	Tel: 905-890-0708 ext. 23204
Project: Regulation 243	Fax: 905-890-5841
Quote #: A83456	P.O.#: BN500636
Lab Service Rep.: James Aspin	

Invoice to: Same as "Report to"

**DW METALS
PRESERVATION
CHECKED**

PAGE ____ OF ____

ANALYSIS REQUESTED

Specify
School
Type

M.O.E. Assigned
Water System
Number

500019475

Sample Identification	Sample Type (Please Specify Standing / Flushed)	Date Sampled	Time Sampled	Sampler Initials	Field Chlorine		No. of Bottles	Lead	ANALYSIS REQUESTED			
					Total	Free			School	Private School	Day nursery	
Christ The King Catholic Kitchen - Staffroom	Standing	JULY 17	6:00 AM	A.P.			1	X	X			
Kitchen - Staffroom	Flushed	JULY 17	6:35 AM	A.P.			1	X	X			

* In accordance with the Safe Drinking Water Act (2002), notification of adverse results must be reported to the SAC, MOH & Waterworks. Failure to do so is an offence under the act. It is **IMPERATIVE** that the areas shaded in grey be filled out completely before submitting to Maxxam Analytics.

TAT (Turnaround Time)	Notification Information for School, Private Schools & Day Nurseries		LABORATORY USE ONLY
RUSH TAT MUST HAVE PRIOR APPROVAL	Facility Name: Christ The King	Medical Officer of Health	Received By: <i>JL [Signature]</i>
<input checked="" type="checkbox"/> Normal (5-15 Working Days)	Facility Address: 3240 Garthwood Road	Region: Peel Region	Date: <i>08/07/17</i> Time: <i>15:05</i>
<input type="checkbox"/> RUSH (Specify Below)	Mississauga, ON L5L 5A3	Tel #:	Comments: <i>10/10/10</i>
Date Due:	Tel: 905-569-0220 Fax: 905-569-2797	Fax #:	
PN #	E-mail:	Email:	
Relinquished by (Sign Name): <i>A. Pietrantonio</i>	Date: <i>JULY 17-08</i>	Laboratory Prepared Container:	<input type="checkbox"/> Yes <input type="checkbox"/> No
Relinquished by (Print Name): <i>A. PIETRANTONIO</i>	Time: <i>7:45 AM</i>		

NOTE: Samples submitted to Maxxam Analytics must be received below 10°C.

It is the Sampler's responsibility to ensure adequate cooling is provided. The receiving temperature is met. Please ensure that a separate COC document is used for each individual waterworks.