

Your P.O. #: BN500116  
Your Project #: LESTER B PEARSON  
Site:500012195  
Your C.O.C. #: na

**Attention: Roland Lawton**  
Dufferin Peel Catholic District...  
School Board  
40 Matheson Blvd W  
Mississauga, ON  
L5R 1C5

**Report Date: 2008/07/28**

**CERTIFICATE OF ANALYSIS**

**MAXXAM JOB #: A878305**  
**Received: 2008/07/17, 14:04**

Sample Matrix: Water  
# Samples Received: 2

Analyses	Quantity	Date Extracted	Date Analyzed	Laboratory Method	Method Reference
Metals Analysis by ICPMS (as received) 0	2	2008/07/26	2008/07/26	CAM SOP-00447	EPA 6020

\* RPDs calculated using raw data. The rounding of final results may result in the apparent difference.

(1) Metals analysis was performed on the sample 'as received'.

**Encryption Key**

Please direct all questions regarding this Certificate of Analysis to your Project Manager.

JAMES ASPIN, Project Manager  
Email: James.Aspin@maxxamAnalytics.com  
Phone# (905) 817-5700 Ext:5771

=====

Maxxam has procedures in place to guard against improper use of the electronic signature and have the required "signatories", as per section 5.10.2 of ISO/IEC 17025:2005(E), signing the reports. SCC and CAEAL have approved this reporting process and electronic report format.

For Service Group specific validation please refer to the Validation Signature Page

Total cover pages: 1

Maxxam Job #: A878305  
Report Date: 2008/07/28

Dufferin Peel Catholic District...  
Client Project #: LESTER B PEARSON  
Project name: 500012195  
Your P.O. #: BN500116

**ELEMENTS BY ATOMIC SPECTROSCOPY (WATER)**

Maxxam ID			Z96475		
Sampling Date			2008/07/16 07:05		
COC Number			na		
	<b>Units</b>	<b>Criteria</b>	<b>LESTER B. PEARSON-KITCHEN-STAFFROOM-S TANDING</b>	<b>RDL</b>	<b>QC Batch</b>

<b>Metals</b>					
. Lead (Pb)	mg/L	<b>0.01</b>	0.0014	0.0005	1571435
<p>RDL = Reportable Detection Limit            QC Batch = Quality Control Batch            CRITERIA: Ontario Regulation 243/07 made under the Safe Drinking Water Act, 2002.            Released June 7, 2007</p>					

Maxxam ID			Z96476		
Sampling Date			2008/07/16 07:40		
COC Number			na		
	<b>Units</b>	<b>Criteria</b>	<b>LESTER B. PEARSON-KITCHEN-STAFFROOM-F LUSHED</b>	<b>RDL</b>	<b>QC Batch</b>

<b>Metals</b>					
. Lead (Pb)	mg/L	<b>0.01</b>	0.0007	0.0005	1571435
<p>RDL = Reportable Detection Limit            QC Batch = Quality Control Batch            CRITERIA: Ontario Regulation 243/07 made under the Safe Drinking Water Act, 2002.            Released June 7, 2007</p>					

Maxxam Job #: A878305  
Report Date: 2008/07/28

Dufferin Peel Catholic District...  
Client Project #: LESTER B PEARSON  
Project name: 500012195  
Your P.O. #: BN500116

Package 1	12.0°C
-----------	--------

Each temperature is the average of up to three cooler temperatures taken at receipt

**GENERAL COMMENTS**

**Results relate only to the items tested.**

Dufferin Peel Catholic District...  
Attention: Roland Lawton  
Client Project #: LESTER B PEARSON  
P.O. #: BN500116  
Project name: 500012195

Quality Assurance Report  
Maxxam Job Number: MA878305

QA/QC Batch	QC Type	Parameter	Date Analyzed yyyy/mm/dd	Value	Recovery	Units	QC Limits
1571435 HRE	MATRIX SPIKE	. Lead (Pb)	2008/07/26		98	%	80 - 120
	Spiked Blank	. Lead (Pb)	2008/07/26		99	%	85 - 115
	Method Blank	. Lead (Pb)	2008/07/26	ND, RDL=0.5		ug/L	
	RPD	. Lead (Pb)	2008/07/26	NC		%	25

ND = Not detected  
NC = Non-calculable  
RPD = Relative Percent Difference  
SPIKE = Fortified sample

**Validation Signature Page**

**Maxxam Job #: A878305**

---

The analytical data and all QC contained in this report were reviewed and validated by the following individual(s).



---

TROY CARRIERE, B.Sc., C.Chem, Scientific Specialist

=====

Maxxam has procedures in place to guard against improper use of the electronic signature and have the required "signatories", as per section 5.10.2 of ISO/IEC 17025:2005(E), signing the reports. SCC and CAEAL have approved this reporting process and electronic report format.



6740 Campobello Rd  
Mississauga  
Ontario L5N 2L8


## REGULATION 243 DRINKING WATER SUBM CHAIN OF CUSTODY RECORD

Tel: 905-817-5700  
Fax: 905-817-5779  
Toll Free: 1-800-563-6266

Samples are Regulated  
Under Reg 243

17-Jul-08 14:04

JAMES ASPIN



A878305

CCO ENV-875

### Report to:

Company Name: Dufferin-Peel Catholic District School Board  
Client Contact: Roland Lawton, General Manager of Physical Plant Facilities  
Address: 5685 Keaton Cres., Mississauga ON L5R 3H5  
E-Mail: [roland.lawton@dpcdsb.org](mailto:roland.lawton@dpcdsb.org) Tel: 905-890-0708 ext. 23204  
Project: Regulation 243 Fax: 905-890-5841  
Quote #: A83456 P.O.#: BN500636  
Lab Service Rep.: James Aspen

Invoice to:  Same as "Report to"

PAGE \_\_\_\_ OF \_\_\_\_

### ANALYSIS REQUESTED

Specify School Type

M.O.E. Assigned Water System Number

School Private School Day nursery

Sample Identification	Sample Type (Please Specify Standing / Flushed)	Date Sampled	Time Sampled	Sampler Initials	Field Chlorine		No. of Bottles	Lead	School	Private School	Day nursery	M.O.E. Assigned Water System Number
					Total	Free						
Lester B. Pearson												500012195
Kitchen - Staffroom	Standing	16/07	7:05am				1	X	X			
Kitchen - Staffroom	Flushed	16/07	7:40am				1	X	X			

SIF : Sample Inspection

Resolved  By: \_\_\_\_\_

Date: \_\_\_\_\_

LOW METALS  
PRESERVATION  
CHECKED

\* In accordance with the Safe Drinking Water Act (2002), notification of adverse results must be reported to the Health Department. Failure to do so is an offence under the act. It is IMPERATIVE that the areas shaded in grey be filled out completely before submitting to Maxxam Analytics

TAT (Turnaround Time)	Notification Information for School, Private Schools & Day Nurseries	LABORATORY USE ONLY
<b>RUSH TAT MUST HAVE PRIOR APPROVAL</b>	Facility Name: Lester B. Pearson Facility Address: 140 Howden Blvd., Brampton, ON L6S 2G1	Received By: <i>KOPIA ZEBIA</i> Date: <i>28/07/08</i> Time: <i>14:09</i> Comments:
<input checked="" type="checkbox"/> Normal (5-15 Working Days) <input type="checkbox"/> RUSH (Specify Below)	Region: Peel Region Tel #: Fax #:	
Date Due:	Tel: 905-793-4861 Fax: 905-793-4497	
PN #	E-mail:	
Relinquished by (Sign Name): <i>R Williams</i>	Date: <i>July 17/08</i>	Laboratory Prepared Container: <input type="checkbox"/> Yes <input type="checkbox"/> No
Relinquished by (Print Name): <i>Kim Williams</i>	Time: <i>2:23pm</i>	

NOTE: Samples submitted to Maxxam Analytics must be received below 10°C.  
It is the Sampler's responsibility to ensure adequate cooling is provided so that this receiving temperature is met.  
Please ensure that a separate COC document is used for each individual waterworks.