

Your P.O. #: BN500116
Your Project #: MOTHER MARY WARD
Site:500012650
Your C.O.C. #: na

Attention: Roland Lawton
Dufferin Peel Catholic District...
School Board
40 Matheson Blvd W
Mississauga, ON
L5R 1C5

Report Date: 2008/07/28

CERTIFICATE OF ANALYSIS

MAXXAM JOB #: A878298
Received: 2008/07/17, 14:04

Sample Matrix: Water
Samples Received: 2

Analyses	Quantity	Date Extracted	Date Analyzed	Laboratory Method	Method Reference
Metals Analysis by ICPMS (as received) 0	2	2008/07/26	2008/07/26	CAM SOP-00447	EPA 6020

* RPDs calculated using raw data. The rounding of final results may result in the apparent difference.

(1) Metals analysis was performed on the sample 'as received'.

Encryption Key

Please direct all questions regarding this Certificate of Analysis to your Project Manager.

JAMES ASPIN, Project Manager
Email: James.Aspin@maxxamAnalytics.com
Phone# (905) 817-5700 Ext:5771

=====
Maxxam has procedures in place to guard against improper use of the electronic signature and have the required "signatories", as per section 5.10.2 of ISO/IEC 17025:2005(E), signing the reports. SCC and CAEAL have approved this reporting process and electronic report format.

For Service Group specific validation please refer to the Validation Signature Page

Total cover pages: 1

Maxxam Job #: A878298
Report Date: 2008/07/28

Dufferin Peel Catholic District...
Client Project #: MOTHER MARY WARD
Project name: 500012650
Your P.O. #: BN500116

ELEMENTS BY ATOMIC SPECTROSCOPY (WATER)

Maxxam ID			Z96464		
Sampling Date			2008/07/15 07:01		
COC Number			na		
	Units	Criteria	MOTHER MARY WARD-KITCHEN-STAFFROOM-STAN DING	RDL	QC Batch

Metals					
. Lead (Pb)	mg/L	0.01	0.0032	0.0005	1571435
<p>RDL = Reportable Detection Limit QC Batch = Quality Control Batch CRITERIA: Ontario Regulation 243/07 made under the Safe Drinking Water Act, 2002. Released June 7, 2007</p>					

Maxxam ID			Z96465		
Sampling Date			2008/07/15 07:36		
COC Number			na		
	Units	Criteria	MOTHER MARY WARD-KITCHEN-STAFFROOM-FLUS HED	RDL	QC Batch

Metals					
. Lead (Pb)	mg/L	0.01	0.0012	0.0005	1571435
<p>RDL = Reportable Detection Limit QC Batch = Quality Control Batch CRITERIA: Ontario Regulation 243/07 made under the Safe Drinking Water Act, 2002. Released June 7, 2007</p>					

Maxxam Job #: A878298
Report Date: 2008/07/28

Dufferin Peel Catholic District...
Client Project #: MOTHER MARY WARD
Project name: 500012650
Your P.O. #: BN500116

Package 1	12.0°C
-----------	--------

Each temperature is the average of up to three cooler temperatures taken at receipt

GENERAL COMMENTS

Results relate only to the items tested.

Dufferin Peel Catholic District...
Attention: Roland Lawton
Client Project #: MOTHER MARY WARD
P.O. #: BN500116
Project name: 500012650

Quality Assurance Report
Maxxam Job Number: MA878298

QA/QC Batch	QC Type	Parameter	Date Analyzed yyyy/mm/dd	Value	Recovery	Units	QC Limits
1571435 HRE	MATRIX SPIKE	. Lead (Pb)	2008/07/26		98	%	80 - 120
	Spiked Blank	. Lead (Pb)	2008/07/26		99	%	85 - 115
	Method Blank	. Lead (Pb)	2008/07/26	ND, RDL=0.5		ug/L	
	RPD	. Lead (Pb)	2008/07/26	NC		%	25

ND = Not detected
 NC = Non-calculable
 RPD = Relative Percent Difference
 SPIKE = Fortified sample

Validation Signature Page

Maxxam Job #: A878298

The analytical data and all QC contained in this report were reviewed and validated by the following individual(s).

Cristina Nervo

CHRISTINA NERVO, Scientific Services

=====

Maxxam has procedures in place to guard against improper use of the electronic signature and have the required "signatories", as per section 5.10.2 of ISO/IEC 17025:2005(E), signing the reports. SCC and CAEAL have approved this reporting process and electronic report format.

6740 Campobello Rd
Mississauga
Ontario L5N 2L8

REGULATION 243 DRINKING WATER SUBM CHAIN OF CUSTODY RECORD

Tel: 905-817-5700
Fax: 905-817-5779
Toll Free: 1-800-563-6266

Samples are Regulated
Under Reg 243

17-Jul-08 14:04

JAMES ASPIN



A878298

CCO ENV-875

Report to:

Company Name: Dufferin-Peel Catholic District School Board
 Client Contact: Roland Lawton, General Manager of Physical Plant Facilities
 Address: 5685 Keaton Cres., Mississauga ON L5R 3H5
 E-Mail: roland.lawton@dpcdsb.org Tel: 905-890-0708 ext. 23204
 Project: Regulation 243 Fax: 905-890-5841
 Quote #: A83456 P.O.#: BN500636
 Lab Service Rep.: James Aspen

Invoice to: Same as "Report to"

PAGE _____ OF _____

ANALYSIS REQUESTED

Specify School Type

M.O.E. Assigned Water System Number

School	Private School	Day nursery	
<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	500012650

Sample Identification	Sample Type (Please Specify Standing / Flushed)	Date Sampled	Time Sampled	Sampler Initials	Field Chlorine		No. of Bottles	Lead	School	Private School	Day nursery
					Total	Free					
Mother Mary Ward											
Kitchen - Staffroom	Standing	07/15/08	7:01 a.m.	Jm.			1	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>		
Kitchen - Staffroom	Flushed	07/15/08	7:36 a.m.	Jm.			1	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>		

SIF : Sample Inspection
 Resolved By: _____
 Date: _____

NEW METALS
 PRESERVATION
 CHECKED

* In accordance with the Safe Drinking Water Act (2002), notification of adverse results must be reported to the Health Department. Failure to do so is an offence under the act. It is **IMPERATIVE** that the areas shaded in grey be filled out.

TAT (Turnaround Time)	Notification Information for School, Private Schools & Day Nurseries		LABORATORY USE ONLY	
RUSH TAT MUST HAVE PRIOR APPROVAL	Facility Name: Mother Mary Ward	Medical Officer of Health	Received By: ZORITA ZENITA	
<input checked="" type="checkbox"/> Normal (5-15 Working Days)	Facility Address: 69 Maitland Street	Region: Peel Region	Date: 08/17/08 Time: 14:04	
<input type="checkbox"/> RUSH (Specify Below)	Brampton, ON L6S 3B5	Tel #:	Comments:	
Date Due:	Tel: 905-458-4844 Fax: 905-458-8410	Fax #:		
PN #	E-mail:	Email:		
Relinquished by (Sign Name):	<i>K. Williams</i>	Date: July 17/08		
Relinquished by (Print Name):	Kim Williams	Time: 2:30 p.m.		

NOTE: Samples submitted to Maxxam Analytics must be received below 10°C. It is the Sampler's responsibility to ensure adequate cooling is provided so that this receiving temperature is met. Please ensure that a separate COC document is used for each individual waterworks.

LARRY MIESUD