

Your P.O. #: BN500636
Your Project #: NOTRE DAME CATHOLIC
Site:500012442
Your C.O.C. #: NA

Attention: Roland Lawton
Dufferin Peel Catholic District...
School Board
40 Matheson Blvd W
Mississauga, ON
L5R 1C5

Report Date: 2008/07/24

CERTIFICATE OF ANALYSIS

MAXXAM JOB #: A877990
Received: 2008/07/17, 14:05

Sample Matrix: Water
Samples Received: 2

Analyses	Quantity	Date Extracted	Date Analyzed	Laboratory Method	Method Reference
Metals Analysis by ICPMS (as received) 0	2	2008/07/22	2008/07/24	CAM SOP-00447	EPA 6020

* RPDs calculated using raw data. The rounding of final results may result in the apparent difference.

(1) Metals analysis was performed on the sample 'as received'.

Encryption Key

Please direct all questions regarding this Certificate of Analysis to your Project Manager.

JAMES ASPIN, Project Manager
Email: James.Aspin@maxxamAnalytics.com
Phone# (905) 817-5700 Ext:5771

=====
Maxxam has procedures in place to guard against improper use of the electronic signature and have the required "signatories", as per section 5.10.2 of ISO/IEC 17025:2005(E), signing the reports. SCC and CAEAL have approved this reporting process and electronic report format.

For Service Group specific validation please refer to the Validation Signature Page

Total cover pages: 1

Maxxam Job #: A877990
Report Date: 2008/07/24

Dufferin Peel Catholic District...
Client Project #: NOTRE DAME CATHOLIC
Project name: 500012442
Your P.O. #: BN500636

ELEMENTS BY ATOMIC SPECTROSCOPY (WATER)

Maxxam ID			Z95488	Z95489		
Sampling Date			2008/07/17 06:27	2008/07/17 07:04		
COC Number			NA	NA		
	Units	Criteria	NOTRE CAME CATHOLIC SS KITCHEN-STAFFROOM/STANDING	NOTRE CAME CATHOLIC SS KITCHEN-STAFFROOM/FLUSHED	RDL	QC Batch

Metals						
Lead (Pb)	mg/L	0.01	0.0042	0.0014	0.0005	1567567

RDL = Reportable Detection Limit
QC Batch = Quality Control Batch
CRITERIA: Ontario Regulation 243/07 made under the Safe Drinking Water Act, 2002.

Released June 7, 2007

Maxxam Job #: A877990
Report Date: 2008/07/24

Dufferin Peel Catholic District...
Client Project #: NOTRE DAME CATHOLIC
Project name: 500012442
Your P.O. #: BN500636

Package 1	12.3°C
-----------	--------

Each temperature is the average of up to three cooler temperatures taken at receipt

GENERAL COMMENTS

Results relate only to the items tested.

Dufferin Peel Catholic District...
Attention: Roland Lawton
Client Project #: NOTRE DAME CATHOLIC
P.O. #: BN500636
Project name: 500012442

Quality Assurance Report
Maxxam Job Number: MA877990

QA/QC Batch	QC Type	Parameter	Date Analyzed yyyy/mm/dd	Value	Recovery	Units	QC Limits
1567567 JBW	MATRIX SPIKE	. Lead (Pb)	2008/07/24		99	%	80 - 120
	Spiked Blank	. Lead (Pb)	2008/07/24		99	%	85 - 115
	Method Blank	. Lead (Pb)	2008/07/24	ND, RDL=0.5		ug/L	
	RPD	. Lead (Pb)	2008/07/24	2.9		%	25

ND = Not detected
RPD = Relative Percent Difference
SPIKE = Fortified sample

Validation Signature Page

Maxxam Job #: A877990

The analytical data and all QC contained in this report were reviewed and validated by the following individual(s).

Cristina Nervo

CHRISTINA NERVO, Scientific Services

=====

Maxxam has procedures in place to guard against improper use of the electronic signature and have the required "signatories", as per section 5.10.2 of ISO/IEC 17025:2005(E), signing the reports. SCC and CAEAL have approved this reporting process and electronic report format.

