

Your P.O. #: BN500636
Your Project #: REGULATION 243 OUR LADY OF PRO
Site:500001299
Your C.O.C. #: na

Attention: Roland Lawton
Dufferin Peel Catholic District...
School Board
40 Matheson Blvd W
Mississauga, ON
L5R 1C5

Report Date: 2008/08/12

CERTIFICATE OF ANALYSIS

MAXXAM JOB #: A885748
Received: 2008/08/05, 14:44

Sample Matrix: Water
Samples Received: 2

Analyses	Quantity	Date Extracted	Date Analyzed	Laboratory Method	Method Reference
Metals Analysis by ICPMS (as received) 0	2	2008/08/11	2008/08/11	CAM SOP-00447	EPA 6020

* RPDs calculated using raw data. The rounding of final results may result in the apparent difference.

(1) Metals analysis was performed on the sample 'as received'.

Encryption Key

Please direct all questions regarding this Certificate of Analysis to your Project Manager.

JAMES ASPIN, Project Manager
Email: James.Aspin@maxxamAnalytics.com
Phone# (905) 817-5700 Ext:5771

=====

Maxxam has procedures in place to guard against improper use of the electronic signature and have the required "signatories", as per section 5.10.2 of ISO/IEC 17025:2005(E), signing the reports. SCC and CAEAL have approved this reporting process and electronic report format.

For Service Group specific validation please refer to the Validation Signature Page

Total cover pages: 1

Maxxam Job #: A885748
Report Date: 2008/08/12

Dufferin Peel Catholic District...
Client Project #: REGULATION 243 OUR LADY OF PRO
Project name: 500001299
Your P.O. #: BN500636

ELEMENTS BY ATOMIC SPECTROSCOPY (WATER)

Maxxam ID			AD0291	AD0292		
Sampling Date			2008/07/16 7:00	2008/07/16 07:36		
COC Number			na	na		
	Units	Criteria	OUR LADY OF PROVIDENCE KITCHEN-STAFFROOM STANDING	OUR LADY OF PROVIDENCE KITCHEN-STAFFROOM FLUSHED	RDL	QC Batch

Metals						
. Lead (Pb)	mg/L	0.01	ND	ND	0.0005	1583288

ND = Not detected
RDL = Reportable Detection Limit
QC Batch = Quality Control Batch
CRITERIA: Ontario Regulation 243/07 made under the Safe Drinking Water Act, 2002.
Released June 7, 2007

Maxxam Job #: A885748
Report Date: 2008/08/12

Dufferin Peel Catholic District...
Client Project #: REGULATION 243 OUR LADY OF PRO
Project name: 500001299
Your P.O. #: BN500636

Package 1	7.3°C
-----------	-------

Each temperature is the average of up to three cooler temperatures taken at receipt

GENERAL COMMENTS

Results relate only to the items tested.

Dufferin Peel Catholic District...
Attention: Roland Lawton
Client Project #: REGULATION 243 OUR LADY OF PRO
P.O. #: BN500636
Project name: 500001299

Quality Assurance Report
Maxxam Job Number: MA885748

QA/QC Batch	QC Type	Parameter	Date Analyzed yyyy/mm/dd	Value	Recovery	Units	QC Limits
1583288 HRE	MATRIX SPIKE						
	[AD0291-01]	. Lead (Pb)	2008/08/11		99	%	80 - 120
	Spiked Blank	. Lead (Pb)	2008/08/11		96	%	85 - 115
	Method Blank	. Lead (Pb)	2008/08/11	ND, RDL=0.0005		mg/L	
	RPD [AD0291-01]	. Lead (Pb)	2008/08/11	NC		%	25

ND = Not detected
 NC = Non-calculable
 RPD = Relative Percent Difference
 SPIKE = Fortified sample

Validation Signature Page

Maxxam Job #: A885748

The analytical data and all QC contained in this report were reviewed and validated by the following individual(s).




TROY CARRIERE, B.Sc., C.Chem, Scientific Specialist

Maxxam has procedures in place to guard against improper use of the electronic signature and have the required "signatories", as per section 5.10.2 of ISO/IEC 17025:2005(E), signing the reports. SCC and CAEAL have approved this reporting process and electronic report format.



6740 Campobello Rd
Mississauga
Ontario L5N 2L8

5-Aug-08 14:44

JAMES ASPIN



A885748

NNA ENV-667

Fax: 905-817-5779
Toll Free: 1-800-563-6266

**DRINKING WATER SUBMISSION
USTODY RECORD**

Samples are Regulated
Under Reg 243

Maxxam Analytics Inc.
CAM FCD-00196/2

Report to:

Company Name:	Dufferin-Peel Catholic District School Board		
Client Contact:	Roland Lawton, General Manager of Physical Plant Facilities		
Address:	5685 Keaton Cres., Mississauga ON L5R 3H5		
E-Mail:	<u>roland.lawton@dpcdsb.org</u>	Tel:	905-890-0708 ext. 23204
Project:	Regulation 243	Fax:	905-890-5841
Quote #:	A83456	P.O.#:	BN500636
Lab Service Rep.:	James Aspen		

Invoice to: Same as "Report to"

**DW METALS
PRESERVATION
CHECKED**

PAGE ____ OF ____

ANALYSIS REQUESTED

Specify School Type	M.O.E. Assigned Water System Number
School	
Private School / Day nursery	

Sample Identification	Sample Type (Please Specify Standing / Flushed)	Date Sampled	Time Sampled	Sampler Initials	Field Chlorine		No. of Bottles	Lead	School	Private School	Day nursery	M.O.E. Assigned Water System Number
					Total	Free						
Our Lady of Providence												50001299
Kitchen - Staffroom	Standing	July 16 08	7:00 AM	JSP			1	X	X			
Kitchen - Staffroom	Flushed	July 16 08	7:05 AM	JSP			1	X	X			

* In accordance with the Safe Drinking Water Act (2002), notification of adverse results must be reported to the SAC, MOH & Waterworks. Failure to do so is an offence under the act. It is **IMPERATIVE** that the areas shaded in grey be filled out completely before submitting to Maxxam Analytics.

TAT (Turnaround Time)	Notification Information for School, Private Schools & Day Nurseries		LABORATORY USE ONLY
RUSH TAT MUST HAVE PRIOR APPROVAL	Facility Name: Our Lady of Providence	Medical Officer of Health	Received By: <i>[Signature]</i>
<input checked="" type="checkbox"/> Normal (5-15 Working Days)	Facility Address: 35 Black Oak Drive	Region: Peel Region	Date: 08/07/08 Time: 14:00
<input type="checkbox"/> RUSH (Specify Below)	Brampton, ON L6R 1B9	Tel #:	Comments: <i>[Handwritten]</i>
Date Due:	Tel: 905-458-7080 Fax: 905-458-1657	Fax #:	
PN #	E-mail:	Email:	
Relinquished by (Sign Name): <i>[Signature]</i>	Date: July 17 08	Laboratory Prepared Container:	<input type="checkbox"/> Yes <input type="checkbox"/> No
Relinquished by (Print Name): <i>[Signature]</i>	Time: 6:00 am - 6:30 am		

NOTE: Samples submitted to Maxxam Analytics must be received below 10°C. It is the Sampler's responsibility to ensure adequate cooling is provided so that this receiving temperature is met. Please ensure that a separate COC document is used for each indiv