

Your P.O. #: BN500636
Your Project #: PAULINE VANIER CATHOLIC R243
Site:500012221
Your C.O.C. #: NA

Attention: Roland Lawton
Dufferin Peel Catholic District...
School Board
40 Matheson Blvd W
Mississauga, ON
L5R 1C5

Report Date: 2008/07/25

CERTIFICATE OF ANALYSIS

MAXXAM JOB #: A877968
Received: 2008/07/17, 14:16

Sample Matrix: Water
Samples Received: 2

Analyses	Quantity	Date Extracted	Date Analyzed	Laboratory Method	Method Reference
Metals Analysis by ICPMS (as received) ①	1	2008/07/23	2008/07/24	CAM SOP-00447	EPA 6020
Metals Analysis by ICPMS (as received) ①	1	2008/07/24	2008/07/24	CAM SOP-00447	EPA 6020

* RPDs calculated using raw data. The rounding of final results may result in the apparent difference.

(1) Metals analysis was performed on the sample 'as received'.

Encryption Key

Please direct all questions regarding this Certificate of Analysis to your Project Manager.

JAMES ASPIN, Project Manager
Email: James.Aspin@maxxamAnalytics.com
Phone# (905) 817-5700 Ext:5771

=====
Maxxam has procedures in place to guard against improper use of the electronic signature and have the required "signatories", as per section 5.10.2 of ISO/IEC 17025:2005(E), signing the reports. SCC and CAEAL have approved this reporting process and electronic report format.

For Service Group specific validation please refer to the Validation Signature Page

Total cover pages: 1

Maxxam Job #: A877968
Report Date: 2008/07/25

Dufferin Peel Catholic District...
Client Project #: PAULINE VANIER CATHOLIC R243
Project name: 500012221
Your P.O. #: BN500636

ELEMENTS BY ATOMIC SPECTROSCOPY (WATER)

Maxxam ID			Z95421		
Sampling Date			2008/07/16 06:10		
COC Number			NA		
	Units	Criteria	PAULINE VANIER CATHOLIC KITCHEN-STAFFROOM/STANDING	RDL	QC Batch

Metals					
. Lead (Pb)	mg/L	0.01	ND	0.0005	1569150
<p>ND = Not detected RDL = Reportable Detection Limit QC Batch = Quality Control Batch CRITERIA: Ontario Regulation 243/07 made under the Safe Drinking Water Act, 2002. Released June 7, 2007</p>					

Maxxam ID			Z95422		
Sampling Date			2008/07/16 06:45		
COC Number			NA		
	Units	Criteria	PAULINE VANIER CATHOLIC KITCHEN-STAFFROOM/FLUSHED	RDL	QC Batch

Metals					
. Lead (Pb)	mg/L	0.01	ND	0.0005	1568088
<p>ND = Not detected RDL = Reportable Detection Limit QC Batch = Quality Control Batch CRITERIA: Ontario Regulation 243/07 made under the Safe Drinking Water Act, 2002. Released June 7, 2007</p>					

Maxxam Job #: A877968
Report Date: 2008/07/25

Dufferin Peel Catholic District...
Client Project #: PAULINE VANIER CATHOLIC R243
Project name: 500012221
Your P.O. #: BN500636

Package 1	10.0°C
-----------	--------

Each temperature is the average of up to three cooler temperatures taken at receipt

GENERAL COMMENTS

Results relate only to the items tested.

Dufferin Peel Catholic District...
Attention: Roland Lawton
Client Project #: PAULINE VANIER CATHOLIC R243
P.O. #: BN500636
Project name: 500012221

Quality Assurance Report
Maxxam Job Number: MA877968

QA/QC Batch	QC Type	Parameter	Date Analyzed yyyy/mm/dd	Value	Recovery	Units	QC Limits
1568088 JBW	MATRIX SPIKE	. Lead (Pb)	2008/07/23		104	%	80 - 120
	Spiked Blank	. Lead (Pb)	2008/07/24		100	%	85 - 115
	Method Blank	. Lead (Pb)	2008/07/24	ND, RDL=0.5		ug/L	
	RPD	. Lead (Pb)	2008/07/23	NC		%	25
1569150 JBW	MATRIX SPIKE	. Lead (Pb)	2008/07/24		105	%	80 - 120
	Spiked Blank	. Lead (Pb)	2008/07/24		101	%	85 - 115
	Method Blank	. Lead (Pb)	2008/07/24	ND, RDL=0.5		ug/L	
	RPD	. Lead (Pb)	2008/07/24	NC		%	25

ND = Not detected
 NC = Non-calculable
 RPD = Relative Percent Difference
 SPIKE = Fortified sample

Validation Signature Page

Maxxam Job #: A877968

The analytical data and all QC contained in this report were reviewed and validated by the following individual(s).



TROY CARRIERE, B.Sc., C.Chem, Scientific Specialist

Maxxam has procedures in place to guard against improper use of the electronic signature and have the required "signatories", as per section 5.10.2 of ISO/IEC 17025:2005(E), signing the reports. SCC and CAEAL have approved this reporting process and electronic report format.



6740 Campobello Rd
Mississauga
Ontario L5N 2L8

REGULATION 243 DRINKING WATER CHAIN OF CUSTODY RECORD

Tel: 905-817-5700
Fax: 905-817-5779
Toll Free: 1-800-563-6266

Samples are Regular
Under Reg 243

17-Jul-08 14:16
JAMES ASPIN



A877968

FW ENV-756

CAM FCD-00196/2

Report to:

Company Name: Dufferin-Peel Catholic District School Board
 Contact: Roland Lawton, General Manager of Physical Plant Facilities
 Address: 5685 Keaton Cres., Mississauga ON L5R 3H5
 Mail: roland.lawton@dpcdsb.org Tel: 905-890-0708 ext. 23204
 Object: Regulation 243 Fax: 905-890-5841
 Note #: A83456 P.O.#: BN500636
 Service Rep.: James Aspen

Invoice to: Same as "Report to"

DW METALS
PRESERVATION
CHECKED

ANALYSIS REQUESTED	
Specify School Type	M.O.E. Assigned Water System Number
<input type="checkbox"/> School <input type="checkbox"/> Private School <input type="checkbox"/> Day nursery	500012221

Sample Identification	Sample Type (Please Specify Standing / Flushed)	Date Sampled	Time Sampled	Sampler Initials	Field Chlorine		No. of Bottles	Lead
					Total	Free		
Pauline Vanier Catholic Kitchen - Staffroom	Standing	16-7-08	6:10 AM				1	X
Kitchen - Staffroom	Flushed	16-7-08	6:45 AM				1	X

In accordance with the Safe Drinking Water Act (2002), notification of adverse results must be reported to the SAC, MOH & Waterworks. Failure to do so is an offence under the act. It is **IMPERATIVE** that the areas shaded in grey be filled out completely before submitting to Maxxam Analytics.

TAT (Turnaround Time)	Notification Information for School, Private Schools & Day Nurseries	LABORATORY USE ONLY
RUSH TAT MUST HAVE PRIOR APPROVAL	Facility Name: Pauline Vanier Catholic Facility Address: 56 Oaklea Blvd., Brampton, ON L6Y 4G5	Received By: <i>[Signature]</i> Date: 08/07/17 Time: 14:16
<input type="checkbox"/> Normal (5-15 Working Days)		Comments: 10/10/10 '08 JUL 17 14:16
<input type="checkbox"/> RUSH (Specify Below)		
Site Due:	Tel: 905-455-1001 Fax: 905-455-3406	
Order #	E-mail:	
Relinquished by (Sign Name): <i>J. M. Lima</i>	Date: <i>JULY 16-08</i>	Laboratory Prepared Container:
Relinquished by (Print Name): <i>JOSE MIKE LIMA</i>	Time: <i>6:45 AM</i>	<input type="checkbox"/> Yes <input type="checkbox"/> No

NOTE: Samples submitted to Maxxam Analytics must be received below 10°C.

It is the Sampler's responsibility to ensure adequate cooling is provided so that this receiving temperature is met.

Please ensure that a separate COC document is used for each individual