

Your P.O. #: BN500636
Your Project #: QUEEN OF HEAVEN R243
Site:500018695
Your C.O.C. #: NA

Attention: Roland Lawton
Dufferin Peel Catholic District...
School Board
40 Matheson Blvd W
Mississauga, ON
L5R 1C5

Report Date: 2008/07/24

CERTIFICATE OF ANALYSIS

MAXXAM JOB #: A878049
Received: 2008/07/17, 13:29

Sample Matrix: Water
Samples Received: 2

Analyses	Quantity	Date Extracted	Date Analyzed	Laboratory Method	Method Reference
Metals Analysis by ICPMS (as received) 0	2	2008/07/22	2008/07/24	CAM SOP-00447	EPA 6020

* RPDs calculated using raw data. The rounding of final results may result in the apparent difference.

(1) Metals analysis was performed on the sample 'as received'.

Encryption Key

Please direct all questions regarding this Certificate of Analysis to your Project Manager.

JAMES ASPIN, Project Manager
Email: James.Aspin@maxxamAnalytics.com
Phone# (905) 817-5700 Ext:5771

=====
Maxxam has procedures in place to guard against improper use of the electronic signature and have the required "signatories", as per section 5.10.2 of ISO/IEC 17025:2005(E), signing the reports. SCC and CAEAL have approved this reporting process and electronic report format.

For Service Group specific validation please refer to the Validation Signature Page

Total cover pages: 1

Maxxam Job #: A878049
Report Date: 2008/07/24

Dufferin Peel Catholic District...
Client Project #: QUEEN OF HEAVEN R243
Project name: 500018695
Your P.O. #: BN500636

ELEMENTS BY ATOMIC SPECTROSCOPY (WATER)

Maxxam ID			Z95664	Z95665		
Sampling Date			2008/07/17 07:00	2008/07/17 07:35		
COC Number			NA	NA		
	Units	Criteria	QUEEN OF HEAVEN KITCHEN-STAFFROOM/STANDING	QUEEN OF HEAVEN KITCHEN-STAFFROOM/FLUSHED	RDL	QC Batch

Metals						
Lead (Pb)	mg/L	0.01	ND	ND	0.0005	1567567

ND = Not detected
RDL = Reportable Detection Limit
QC Batch = Quality Control Batch
CRITERIA: Ontario Regulation 243/07 made under the Safe Drinking Water Act, 2002.

Released June 7, 2007

Maxxam Job #: A878049
Report Date: 2008/07/24

Dufferin Peel Catholic District...
Client Project #: QUEEN OF HEAVEN R243
Project name: 500018695
Your P.O. #: BN500636

Package 1	7.3°C
-----------	-------

Each temperature is the average of up to three cooler temperatures taken at receipt

GENERAL COMMENTS

Results relate only to the items tested.

Dufferin Peel Catholic District...
Attention: Roland Lawton
Client Project #: QUEEN OF HEAVEN R243
P.O. #: BN500636
Project name: 500018695

Quality Assurance Report
Maxxam Job Number: MA878049

QA/QC Batch	QC Type	Parameter	Date Analyzed yyyy/mm/dd	Value	Recovery	Units	QC Limits
1567567 JBW	MATRIX SPIKE	. Lead (Pb)	2008/07/24		99	%	80 - 120
	Spiked Blank	. Lead (Pb)	2008/07/24		99	%	85 - 115
	Method Blank	. Lead (Pb)	2008/07/24	ND, RDL=0.5		ug/L	
	RPD	. Lead (Pb)	2008/07/24	2.9		%	25

ND = Not detected
RPD = Relative Percent Difference
SPIKE = Fortified sample

Validation Signature Page

Maxxam Job #: A878049

The analytical data and all QC contained in this report were reviewed and validated by the following individual(s).

Cristina Nervo

CHRISTINA NERVO, Scientific Services

=====

Maxxam has procedures in place to guard against improper use of the electronic signature and have the required "signatories", as per section 5.10.2 of ISO/IEC 17025:2005(E), signing the reports. SCC and CAEAL have approved this reporting process and electronic report format.



6740 Campobello Rd
Mississauga
Ontario L5N 2L8

REGULATION 243 DRINKING WATER SU CHAIN OF CUSTODY RECORD

Tel: 905-817-5700
Fax: 905-817-5779
Toll Free: 1-800-563-6266

Samples are Regulated
Under Reg 243

17-Jul-08 13:29
JAMES ASPIN
A878049
FW ENV-925
CAM FCD-00196/2

Report to:

Company Name: Dufferin-Peel Catholic District School Board
Client Contact: Roland Lawton, General Manager of Physical Plant Facilities
Address: 5685 Keaton Cres., Mississauga ON L5R 3H5
E-Mail: roland.lawton@dpcdsb.org Tel: 905-890-0708 ext. 23204
Project: Regulation 243 Fax: 905-890-5841
Quote #: A83456 P.O.#: BN500636
Lab Service Rep.: James Aspin

Invoice to: Same as "Report to"

**DW METALS
PRESERVATION
CHECKED**

PAGE _____ OF _____

ANALYSIS REQUESTED

Specify School Type

M.O.E. Assigned Water System Number

School	Private School	Day nursery
<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>

Sample Identification	Sample Type (Please Specify Standing / Flushed)	Date Sampled	Time Sampled	Sampler Initials	Field Chlorine		No. of Bottles	Lead	School	Private School	Day nursery	M.O.E. Assigned Water System Number
					Total	Free						
Queen of Heaven Kitchen - Staffroom	Standing	July 17, 08	7:00 AM J.M.				1	X	X			500018695
Kitchen - Staffroom	Flushed	July 17, 08	7:35 AM J.M.				1	X	X			

In accordance with the Safe Drinking Water Act (2002), notification of adverse results must be reported to the SAC, MOH & Waterworks. Failure to do so is an offence under the act. It is **IMPERATIVE** that the areas shaded in grey be filled out completely before submitting to Maxxam Analytics.

TAT (Turnaround Time)	Notification Information for School, Private Schools & Day Nurseries	LABORATORY USE ONLY
RUSH TAT MUST HAVE PRIOR APPROVAL	Facility Name: Queen Of Heaven Facility Address: 1198 Alexandra Avenue Mississauga, ON L5E 2A5	Received By: ZORNA ZERUDA Date: 08/07/08 Time: 13:29
Normal (5-15 Working Days)		Comments:
RUSH (Specify Below)	Tel #: _____ Fax #: _____	
Rate Due:	Tel: 905-278-9771 Fax: 905-891-5972	
Inv #	E-mail: _____	
Relinquished by (Sign Name): <i>F. Mason</i>	Date: July 17/08	Laboratory Prepared Container:
Relinquished by (Print Name): FRANK MASON	Time: 7:35 A.M.	<input type="checkbox"/> Yes <input type="checkbox"/> No

NOTE: Samples submitted to Maxxam Analytics must be received below 10°C. It is the Sampler's responsibility to ensure adequate cooling is provided so that this receiving temperature is met. Please ensure that a separate COC document is used for each indiv

7/17/08
08 JUL 17 13:29