

Your P.O. #: BN500636
Your Project #: ROBERT F HALL
Site:500018630
Your C.O.C. #: na

Attention: Roland Lawton
Dufferin Peel Catholic District...
School Board
40 Matheson Blvd W
Mississauga, ON
L5R 1C5

Report Date: 2008/09/03

CERTIFICATE OF ANALYSIS

MAXXAM JOB #: A896904
Received: 2008/08/28, 10:02

Sample Matrix: Water
Samples Received: 2

Analyses	Quantity	Date Extracted	Date Analyzed	Laboratory Method	Method Reference
Metals Analysis by ICPMS (as received) ¶	2	2008/09/02	2008/09/03	CAM SOP-00447	EPA 6020

* RPDs calculated using raw data. The rounding of final results may result in the apparent difference.

(1) Metals analysis was performed on the sample 'as received'.

Encryption Key

Please direct all questions regarding this Certificate of Analysis to your Project Manager.

JAMES ASPIN, Project Manager
Email: James.Aspin@maxxamAnalytics.com
Phone# (905) 817-5700 Ext:5771

=====

Maxxam has procedures in place to guard against improper use of the electronic signature and have the required "signatories", as per section 5.10.2 of ISO/IEC 17025:2005(E), signing the reports. SCC and CAEAL have approved this reporting process and electronic report format.

For Service Group specific validation please refer to the Validation Signature Page

Total cover pages: 1

Maxxam Job #: A896904
Report Date: 2008/09/03

Dufferin Peel Catholic District...
Client Project #: ROBERT F HALL
Project name: 500018630
Your P.O. #: BN500636

ELEMENTS BY ATOMIC SPECTROSCOPY (WATER)

Maxxam ID			A11926		
Sampling Date			2008/08/26 06:25		
COC Number			na		
	Units	Criteria	ROBERT F.HALL CATHOLIC SS-KITCHEN-STAFFROOM-STANDIN G	RDL	QC Batch

Metals					
. Lead (Pb)	mg/L	0.01	0.0005	0.0005	1601439
<p>RDL = Reportable Detection Limit QC Batch = Quality Control Batch CRITERIA: Ontario Regulation 243/07 made under the Safe Drinking Water Act, 2002. Released June 7, 2007</p>					

Maxxam ID			A11927		
Sampling Date			2008/08/26 07:00		
COC Number			na		
	Units	Criteria	ROBERT F.HALL CATHOLIC SS-KITCHEN-STAFFROOM-FLUSHED	RDL	QC Batch

Metals					
. Lead (Pb)	mg/L	0.01	0.0025	0.0005	1601439
<p>RDL = Reportable Detection Limit QC Batch = Quality Control Batch CRITERIA: Ontario Regulation 243/07 made under the Safe Drinking Water Act, 2002. Released June 7, 2007</p>					

Maxxam Job #: A896904
Report Date: 2008/09/03

Dufferin Peel Catholic District...
Client Project #: ROBERT F HALL
Project name: 500018630
Your P.O. #: BN500636

Package 1	6.3°C
-----------	-------

Each temperature is the average of up to three cooler temperatures taken at receipt

GENERAL COMMENTS

Results relate only to the items tested.

Dufferin Peel Catholic District...
Attention: Roland Lawton
Client Project #: ROBERT F HALL
P.O. #: BN500636
Project name: 500018630

Quality Assurance Report
Maxxam Job Number: MA896904

QA/QC Batch	QC Type	Parameter	Date Analyzed yyyy/mm/dd	Value	Recovery	Units	QC Limits
1601439 MIL	MATRIX SPIKE	. Lead (Pb)	2008/09/02		107	%	80 - 120
	Spiked Blank	. Lead (Pb)	2008/09/02		100	%	85 - 115
	Method Blank	. Lead (Pb)	2008/09/02	ND, RDL=0.0005		mg/L	
	RPD	. Lead (Pb)	2008/09/02	NC		%	25

ND = Not detected
NC = Non-calculable
RPD = Relative Percent Difference
SPIKE = Fortified sample

Validation Signature Page

Maxxam Job #: A896904

The analytical data and all QC contained in this report were reviewed and validated by the following individual(s).

Cristina Nervo

CHRISTINA NERVO, Scientific Services

=====

Maxxam has procedures in place to guard against improper use of the electronic signature and have the required "signatories", as per section 5.10.2 of ISO/IEC 17025:2005(E), signing the reports. SCC and CAEAL have approved this reporting process and electronic report format.

RE: TEST
6740 Campobello Rd
Mississauga
Ontario L5N 2L8

REGULATION 243 DRINKING WATER SUBM
CHAIN OF CUSTODY RECORD

Tel: 905-817-5700
Fax: 905-817-5779
Toll Free: 1-800-563-6266

Samples are Regulated
Under Reg 243

28-Aug-08 10:02
JAMES ASPIN
A896904
CCO ENV-701
CAM FCD-00196/2

Report to:

Company Name: Dufferin-Peel Catholic District School Board
Client Contact: Roland Lawton, General Manager of Physical Plant Facilities
Address: 5685 Keaton Cres., Mississauga ON L5R 3H5
E-Mail: roland.lawton@dpcdsb.org Tel: 905-890-0708 ext. 23204
Project: Regulation 243 Fax: 905-890-5841
Quote #: A83456 P.O.#: BN500636
Lab Service Rep.: James Aspin

Invoice to: Same as "Report to"

PAGE ____ OF ____

ANALYSIS REQUESTED

Specify School Type

Private School Day nursery

M.O.E. Assigned Water System Number

500018630

Sample Identification	Sample Type (Please Specify Standing / Flushed)	Date Sampled	Time Sampled	Sampler Initials	Field Chlorine		No. of Bottles	Lead	School	Private School	Day nursery	M.O.E. Assigned Water System Number
					Total	Free						
Robert F. Hall Catholic SS Kitchen - Staffroom	Standing	Aug 26/08	6:25am	JLV			1	x	x			500018630
Kitchen - Staffroom	Flushed	Aug 26/08	7:00 am	JLV			1	x	x			

In accordance with the Safe Drinking Water Act (2002), notification of adverse results must be reported to the SAC, MOH & Waterworks. Failure to do so is an offence under the act. It is **IMPERATIVE** that the areas shaded in grey be filled out completely before submitting to Maxxam Analytics.

TAT (Turnaround Time)	Notification Information for School, Private Schools & Day Nurseries		LABORATORY USE ONLY
RUSH TAT MUST HAVE PRIOR APPROVAL	Facility Name: Robert F. Hall Catholic S.S.	Medical Officer of Health	Received By: [Signature]
<input checked="" type="checkbox"/> Normal (5-15 Working Days)	Facility Address: 6500 Old Church Road	Region: Peel Region	Date: 8/28/08 Time: 10:00
<input type="checkbox"/> RUSH (Specify Below)	Caledon East, ON L7C 0H3	Tel #:	Comments: 0/0/7c
Date Due:	Tel: 1-905-584-1670 Fax: 1-905-584-1488	Fax #:	
PN #	E-mail:	Email:	
Relinquished by (Sign Name): Denise Vaia	Date: Aug 26/08	Laboratory Prepared Container:	<input type="checkbox"/> Yes <input type="checkbox"/> No
Relinquished by (Print Name): Denise Vaia	Time: 7:00 am		

NOTE: Sample SIF : Sample Inspection
It is the Sampler's responsibility
Please ensure that Resolved By: _____
Date: _____

DW METALS
PRESERVATION
CHECKED

08 AUG 28 10:02