

Your P.O. #: BN500636
Your Project #: SAN LORENZO RUIZ R243
Site:500019020
Your C.O.C. #: na

Attention: Roland Lawton
Dufferin Peel Catholic District...
School Board
40 Matheson Blvd W
Mississauga, ON
L5R 1C5

Report Date: 2008/07/24

CERTIFICATE OF ANALYSIS

MAXXAM JOB #: A878004
Received: 2008/07/17, 13:32

Sample Matrix: Water
Samples Received: 2

Analyses	Quantity	Date Extracted	Date Analyzed	Laboratory Method	Method Reference
Metals Analysis by ICPMS (as received) 0	2	2008/07/22	2008/07/24	CAM SOP-00447	EPA 6020

* RPDs calculated using raw data. The rounding of final results may result in the apparent difference.

(1) Metals analysis was performed on the sample 'as received'.

Encryption Key

Please direct all questions regarding this Certificate of Analysis to your Project Manager.

JAMES ASPIN, Project Manager
Email: James.Aspin@maxxamAnalytics.com
Phone# (905) 817-5700 Ext:5771

=====
Maxxam has procedures in place to guard against improper use of the electronic signature and have the required "signatories", as per section 5.10.2 of ISO/IEC 17025:2005(E), signing the reports. SCC and CAEAL have approved this reporting process and electronic report format.

For Service Group specific validation please refer to the Validation Signature Page

Total cover pages: 1

Maxxam Job #: A878004
Report Date: 2008/07/24

Dufferin Peel Catholic District...
Client Project #: SAN LORENZO RUIZ R243
Project name: 500019020
Your P.O. #: BN500636

ELEMENTS BY ATOMIC SPECTROSCOPY (WATER)

Maxxam ID			Z95532		
Sampling Date			2008/07/17 07:00		
COC Number			na		
	Units	Criteria	SAN LORENZO RUIZ KITCHEN-STAFFROOM/STANDING	RDL	QC Batch

Metals					
. Lead (Pb)	mg/L	0.01	0.0037	0.0005	1567567
<p>RDL = Reportable Detection Limit QC Batch = Quality Control Batch CRITERIA: Ontario Regulation 243/07 made under the Safe Drinking Water Act, 2002. Released June 7, 2007</p>					

Maxxam ID			Z95533		
Sampling Date			2008/07/17 07:35		
COC Number			na		
	Units	Criteria	SAN LORENZO RUIZ KITCHEN-STAFFROOM/FLUSHED	RDL	QC Batch

Metals					
. Lead (Pb)	mg/L	0.01	0.0073	0.0005	1567574
<p>RDL = Reportable Detection Limit QC Batch = Quality Control Batch CRITERIA: Ontario Regulation 243/07 made under the Safe Drinking Water Act, 2002. Released June 7, 2007</p>					

Maxxam Job #: A878004
Report Date: 2008/07/24

Dufferin Peel Catholic District...
Client Project #: SAN LORENZO RUIZ R243
Project name: 500019020
Your P.O. #: BN500636

Package 1	13.7°C
-----------	--------

Each temperature is the average of up to three cooler temperatures taken at receipt

GENERAL COMMENTS

Results relate only to the items tested.

Dufferin Peel Catholic District...
Attention: Roland Lawton
Client Project #: SAN LORENZO RUIZ R243
P.O. #: BN500636
Project name: 500019020

Quality Assurance Report
Maxxam Job Number: MA878004

QA/QC Batch	QC Type	Parameter	Date Analyzed yyyy/mm/dd	Value	Recovery	Units	QC Limits
1567567 JBW	MATRIX SPIKE	. Lead (Pb)	2008/07/24		99	%	80 - 120
	Spiked Blank	. Lead (Pb)	2008/07/24		99	%	85 - 115
	Method Blank	. Lead (Pb)	2008/07/24	ND, RDL=0.5		ug/L	
	RPD	. Lead (Pb)	2008/07/24	2.9		%	25
1567574 JBW	MATRIX SPIKE	. Lead (Pb)	2008/07/24		104	%	80 - 120
	Spiked Blank	. Lead (Pb)	2008/07/24		99	%	85 - 115
	Method Blank	. Lead (Pb)	2008/07/24	ND, RDL=0.5		ug/L	
	RPD	. Lead (Pb)	2008/07/24	0.8		%	25

ND = Not detected
RPD = Relative Percent Difference
SPIKE = Fortified sample

Validation Signature Page

Maxxam Job #: A878004

The analytical data and all QC contained in this report were reviewed and validated by the following individual(s).




TROY CARRIERE, B.Sc., C.Chem, Scientific Specialist

=====

Maxxam has procedures in place to guard against improper use of the electronic signature and have the required "signatories", as per section 5.10.2 of ISO/IEC 17025:2005(E), signing the reports. SCC and CAEAL have approved this reporting process and electronic report format.



6740 Campobello Rd
Mississauga
Ontario L5N 2L8

REGULATION 243 DRINKING WATER SUBMITTAL
CHAIN OF CUSTODY RECORD

Tel: 905-817-5700
Fax: 905-817-5779
Toll Free: 1-800-563-6266

Samples are Regulated
Under Reg 243

17-Jul-08 13:32
JAMES ASPIN
A878004
FW ENV-464
CAM FCD-00196/2

Report to:

Company Name: Dufferin-Peel Catholic District School Board
Client Contact: Roland Lawton, General Manager of Physical Plant Facilities
Address: 5685 Keaton Cres., Mississauga ON L5R 3H5
E-Mail: roland.lawton@dpcdsb.org Tel: 905-890-0708 ext. 23204
Project: Regulation 243 Fax: 905-890-5841
Quote #: A83456 P.O.#: BN500636
Lab Service Rep.: James Aspin

Invoice to: Same as "Report to"

**DW METALS
PRESERVATION
CHECKED**

PAGE _____ OF _____

ANALYSIS REQUESTED

Specify School Type

M.O.E. Assigned Water System Number

Lead	School	Private School	Day nursery	M.O.E. Assigned Water System Number
				500019020

Sample Identification	Sample Type (Please Specify Standing / Flushed)	Date Sampled	Time Sampled	Sampler Initials	Field Chlorine		No. of Bottles	Lead	School	Private School	Day nursery
					Total	Free					
San Lorenzo Ruiz Kitchen - Staffroom	Standing	July 17/08	7:00 am				1	X	X		
Kitchen - Staffroom	Flushed	July 17/08	7:35 am				1	X	X		

SIF : Sample Inspection
Resolved By: _____

In accordance with the Safe Drinking Water Act (2002), notification of adverse results is required. Failure to do so is an offence under the act. It is **IMPERATIVE** that the areas shaded in grey be notified. Maxxam Analytics.

TAT (Turnaround Time)	Notification Information for School, Private School	Medical Officer of Health	LABORATORY USE ONLY
RUSH TAT MUST HAVE PRIOR APPROVAL	Facility Name: San Lorenzo Ruiz Facility Address: 100 Barondale Drive Mississauga, ON L4Z 3R1	Region: Peel Region	Received By: <i>[Signature]</i> Date: 08/07/08 Time: 13:32
<input type="checkbox"/> Normal (5-15 Working Days)		Tel #:	Comments: 12/14/15
<input type="checkbox"/> RUSH (Specify Below)		Fax #:	08 JUL 17 13:32
Rate Due:	Tel: 905-501-0400 Fax: 905-501-9275	Email:	
Inv #			
Relinquished by (Sign Name):	Date:		Laboratory Prepared Container:
Relinquished by (Print Name):	Time:		<input type="checkbox"/> Yes <input type="checkbox"/> No

NOTE: Samples submitted to Maxxam Analytics must be received below 10°C.

It is the Sampler's responsibility to ensure adequate cooling is provided so that this receiving temperature is met.

Please ensure that a separate COC document is used for each indiv

Joe Pizzorusso

SAN LORENZO