

Your Project #: ST ALFRED
Site:500019046
Your C.O.C. #: NA

Attention: Roland Lawton
Dufferin Peel Catholic District...
School Board
40 Matheson Blvd W
Mississauga, ON
L5R 1C5

Report Date: 2008/07/25

CERTIFICATE OF ANALYSIS

MAXXAM JOB #: A878023
Received: 2008/07/17, 13:49

Sample Matrix: Water
Samples Received: 2

Analyses	Quantity	Date Extracted	Date Analyzed	Laboratory Method	Method Reference
Metals Analysis by ICPMS (as received) 0	2	2008/07/24	2008/07/25	CAM SOP-00447	EPA 6020

* RPDs calculated using raw data. The rounding of final results may result in the apparent difference.

(1) Metals analysis was performed on the sample 'as received'.

Encryption Key

Please direct all questions regarding this Certificate of Analysis to your Project Manager.

JAMES ASPIN, Project Manager
Email: James.Aspin@maxxamAnalytics.com
Phone# (905) 817-5700 Ext:5771

=====
Maxxam has procedures in place to guard against improper use of the electronic signature and have the required "signatories", as per section 5.10.2 of ISO/IEC 17025:2005(E), signing the reports. SCC and CAEAL have approved this reporting process and electronic report format.

For Service Group specific validation please refer to the Validation Signature Page

Total cover pages: 1

Maxxam Job #: A878023
Report Date: 2008/07/25

Dufferin Peel Catholic District...
Client Project #: ST ALFRED
Project name: 500019046
Sampler Initials: KW

ELEMENTS BY ATOMIC SPECTROSCOPY (WATER)

Maxxam ID			Z95603	Z95604		
Sampling Date			2008/07/15 07:00	2008/07/15 07:35		
COC Number			NA	NA		
	Units	Criteria	ST. ALFRED	ST. ALFRED	RDL	QC Batch
			KITCHEN-STAFFROOM/STANDING	KITCHEN-STAFFROOM/FLUSHED		

Metals						
Lead (Pb)	mg/L	0.01	0.0018	0.0008	0.0005	1569634

RDL = Reportable Detection Limit
QC Batch = Quality Control Batch
CRITERIA: Ontario Regulation 243/07 made under the Safe Drinking Water Act, 2002.
Released June 7, 2007

Maxxam Job #: A878023
Report Date: 2008/07/25

Dufferin Peel Catholic District...
Client Project #: ST ALFRED
Project name: 500019046
Sampler Initials: KW

Package 1	10.0°C
-----------	--------

Each temperature is the average of up to three cooler temperatures taken at receipt

GENERAL COMMENTS

Results relate only to the items tested.

Dufferin Peel Catholic District...
Attention: Roland Lawton
Client Project #: ST ALFRED
P.O. #:
Project name: 500019046

Quality Assurance Report
Maxxam Job Number: MA878023

QA/QC Batch	QC Type	Parameter	Date Analyzed yyyy/mm/dd	Value	Recovery	Units	QC Limits
1569634 HRE	MATRIX SPIKE						
	[Z95604-01]	. Lead (Pb)	2008/07/25		98	%	80 - 120
	Spiked Blank	. Lead (Pb)	2008/07/25		102	%	85 - 115
	Method Blank	. Lead (Pb)	2008/07/25	ND, RDL=0.5		ug/L	
	RPD [Z95604-01]	. Lead (Pb)	2008/07/25	NC		%	25

ND = Not detected
 NC = Non-calculable
 RPD = Relative Percent Difference
 SPIKE = Fortified sample

Validation Signature Page

Maxxam Job #: A878023

The analytical data and all QC contained in this report were reviewed and validated by the following individual(s).

Cristina Nervo

CHRISTINA NERVO, Scientific Services

=====

Maxxam has procedures in place to guard against improper use of the electronic signature and have the required "signatories", as per section 5.10.2 of ISO/IEC 17025:2005(E), signing the reports. SCC and CAEAL have approved this reporting process and electronic report format.



6740 Campobello Rd
Mississauga
Ontario L5N 2L8

REGULATION 243 DRINKING WATER SUB CHAIN OF CUSTODY RECORD

Tel: 905-817-5700
Fax: 905-817-5779
Toll Free: 1-800-563-6266

Samples are Regulated
Under Reg 243

17-Jul-08 13:49
JAMES ASPIN
A878023
FW ENV-688
CAM FCD-00196/z

Report to:

Company Name: Dufferin-Peel Catholic District School Board
Client Contact: Roland Lawton, General Manager of Physical Plant Facilities
Address: 5685 Keaton Cres., Mississauga ON L5R 3H5
E-Mail: roland.lawton@dpcdsb.org Tel: 905-890-0708 ext. 23204
Project: Regulation 243 Fax: 905-890-5841
Quote #: A83456 P.O.#: BN500636
Lab Service Rep.: James Aspen

Invoice to: Same as "Report to"

DWC METALS
PRESERVATION
CHECKED

PAGE 01 OF 01
ANALYSIS REQUESTED

Specify School Type
School Private School Day nursery
M.O.E. Assigned Water System Number
500019046

Sample Identification	Sample Type (Please Specify Standing / Flushed)	Date Sampled	Time Sampled	Sampler Initials	Field Chlorine		No. of Bottles	Lead	School	Private School	Day nursery	M.O.E. Assigned Water System Number
					Total	Free						
St. Alfred												500019046
Kitchen - Staffroom	Standing	07/15/08	07:00 AM				1	X	X			
Kitchen - Staffroom	Flushed	07/15/08	07:35 AM				1	X	X			

In accordance with the Safe Drinking Water Act (2002), notification of adverse results must be reported to the SAC, MOH & Waterworks. Failure to do so is an offence under the act. It is IMPERATIVE that the areas shaded in grey be filled out completely before submitting to Maxxam Analytics.

TAT (Turnaround Time)	Notification Information for School, Private Schools & Day Nurseries		LABORATORY USE ONLY
RUSH TAT MUST HAVE PRIOR APPROVAL	Facility Name: St. Alfred	Medical Officer of Health	Received By: <i>[Signature]</i>
	Facility Address: 3341 Havenwood Drive	Region: Peel Region	Date: 07/17/08 Time: 13:49
<input checked="" type="checkbox"/> Normal (5-15 Working Days)	Mississauga, ON L4X 2M2		Comments:
<input type="checkbox"/> RUSH (Specify Below)		Tel #:	
Rate Due:	Tel: 905-625-0584 Fax: 905-625-4490	Fax #:	
Lab #:	E-mail:	Email:	
Relinquished by (Sign Name): <i>[Signature]</i>	Date: July 17/08	Laboratory Prepared Container:	<input type="checkbox"/> Yes <input type="checkbox"/> No
Relinquished by (Print Name): Kim Williams	Time: 2:36pm		

NOTE: Samples submitted to Maxxam Analytics must be received below 10°C. It is the Sampler's responsibility to ensure adequate cooling is provided so that this receiving temperature is met. Please ensure that a separate COC document is used for each individual sample.

10/10/08
08 JUL 17 13:49