

Your P.O. #: BN500116
Your Project #: ST. ANGELA MERICI CATHOLIC
Site:500012390
Your C.O.C. #: NA

Attention: Roland Lawton
Dufferin Peel Catholic District...
School Board
40 Matheson Blvd W
Mississauga, ON
L5R 1C5

Report Date: 2008/08/08

CERTIFICATE OF ANALYSIS

MAXXAM JOB #: A885259
Received: 2008/08/01, 13:17

Sample Matrix: Water
Samples Received: 2

| Analyses | Quantity | Date Extracted | Date Analyzed | Laboratory Method | Method Reference |
|--|----------|-------------------|------------------|-------------------|---------------------|
| Metals Analysis by ICPMS (as received) 0 | 2 | 2008/08/07 | 2008/08/07 | CAM SOP-00447 | EPA 6020 |

* RPDs calculated using raw data. The rounding of final results may result in the apparent difference.

(1) Metals analysis was performed on the sample 'as received'.

Encryption Key

Please direct all questions regarding this Certificate of Analysis to your Project Manager.

JAMES ASPIN, Project Manager
Email: James.Aspin@maxxamAnalytics.com
Phone# (905) 817-5700 Ext:5771

=====
Maxxam has procedures in place to guard against improper use of the electronic signature and have the required "signatories", as per section 5.10.2 of ISO/IEC 17025:2005(E), signing the reports. SCC and CAEAL have approved this reporting process and electronic report format.

For Service Group specific validation please refer to the Validation Signature Page

Total cover pages: 1

Maxxam Job #: A885259
Report Date: 2008/08/08

Dufferin Peel Catholic District...
Client Project #: ST. ANGELA MERICI CATHOLIC
Project name: 500012390
Your P.O. #: BN500116

ELEMENTS BY ATOMIC SPECTROSCOPY (WATER)

| | | | | | | |
|---------------|--------------|-----------------|--|---|------------|-----------------|
| Maxxam ID | | | AC7876 | AC7877 | | |
| Sampling Date | | | 2008/07/31 07:00 | 2008/07/31 07:35 | | |
| COC Number | | | NA | NA | | |
| | Units | Criteria | ST ANGELA MERICI KITCHEN STANDING | ST ANGELA MERICI KITCHEN FLUSHED | RDL | QC Batch |

| | | | | | | |
|---------------|------|-------------|--------|----|--------|---------|
| Metals | | | | | | |
| . Lead (Pb) | mg/L | 0.01 | 0.0012 | ND | 0.0005 | 1580482 |

ND = Not detected
RDL = Reportable Detection Limit
QC Batch = Quality Control Batch
CRITERIA: Ontario Regulation 243/07 made under the Safe Drinking Water Act, 2002.

Released June 7, 2007

Maxxam Job #: A885259
Report Date: 2008/08/08

Dufferin Peel Catholic District...
Client Project #: ST. ANGELA MERICI CATHOLIC
Project name: 500012390
Your P.O. #: BN500116

| | |
|-----------|-------|
| Package 1 | 8.7°C |
|-----------|-------|

Each temperature is the average of up to three cooler temperatures taken at receipt

GENERAL COMMENTS

Results relate only to the items tested.

Dufferin Peel Catholic District...
Attention: Roland Lawton
Client Project #: ST. ANGELA MERICI CATHOLIC
P.O. #: BN500116
Project name: 500012390

Quality Assurance Report
Maxxam Job Number: MA885259

| QA/QC Batch | QC Type | Parameter | Date Analyzed yyyy/mm/dd | Value | Recovery | Units | QC Limits |
|-------------|--------------|-------------|-----------------------------|----------------|----------|-------|-----------|
| 1580482 HRE | MATRIX SPIKE | . Lead (Pb) | 2008/08/07 | | 99 | % | 80 - 120 |
| | Spiked Blank | . Lead (Pb) | 2008/08/07 | | 101 | % | 85 - 115 |
| | Method Blank | . Lead (Pb) | 2008/08/07 | ND, RDL=0.0005 | | mg/L | |
| | RPD | . Lead (Pb) | 2008/08/07 | NC | | % | 25 |

ND = Not detected
NC = Non-calculable
RPD = Relative Percent Difference
SPIKE = Fortified sample

Validation Signature Page

Maxxam Job #: A885259

The analytical data and all QC contained in this report were reviewed and validated by the following individual(s).



TROY CARRIERE, B.Sc., C.Chem, Scientific Specialist

=====

Maxxam has procedures in place to guard against improper use of the electronic signature and have the required "signatories", as per section 5.10.2 of ISO/IEC 17025:2005(E), signing the reports. SCC and CAEAL have approved this reporting process and electronic report format.



6740 Campobello Rd
Mississauga
Ontario L5N 2L8

**REGULATION 243 DRINKING WATER SUBM
CHAIN OF CUSTODY RECORD**

Tel: 905-817-5700
Fax: 905-817-5779
Toll Free: 1-800-563-6266

Samples are Regulated
Under Reg 243

1-Aug-08 13:17
JAMES ASPIN
A885259
M_O ENV-775

Report to:

Company Name: Dufferin-Peel Catholic District School Board
Client Contact: Roland Lawton, General Manager of Physical Plant Facilities
Address: 5685 Keaton Cres., Mississauga ON L5R 3H5
E-Mail: roland.lawton@dpcdsb.org Tel: 905-890-0708 ext. 23204
Project: Regulation 243 Fax: 905-890-5841
Quote #: A83456 P.O.#: BN500636
Lab Service Rep.: James Aspen

Invoice to: Same as "Report to"

DW METALS
PRESERVATION
CHECKED

PAGE ____ OF ____

ANALYSIS REQUESTED

Specify School Type

M.O.E. Assigned Water System Number

| | | | |
|--------|----------------|-------------|-----------|
| School | Private School | Day nursery | |
| | | | 500012390 |

| Sample Identification | Sample Type (Please Specify Standing / Flushed) | Date Sampled | Time Sampled | Sampler Initials | Field Chlorine | | No. of Bottles | Lead | School | Private School | Day nursery | M.O.E. Assigned Water System Number |
|--|---|--------------|--------------|------------------|----------------|------|----------------|------|--------|----------------|-------------|-------------------------------------|
| | | | | | Total | Free | | | | | | |
| St. Angela Merici Kitchen - Staffroom | Standing | July 31 | 7:00 | KA | | | 1 | X | X | | | 500012390 |
| Kitchen - Staffroom | Flushed | July 31 | 7:35 | KA | | | 1 | X | X | | | |

* In accordance with the Safe Drinking Water Act (2002), notification of adverse results must be reported to the SAC, MOH & Waterworks. Failure to do so is an offence under the act. It is **IMPERATIVE** that the areas shaded in grey be filled out completely before submitting to Maxxam Analytics.

| TAT (Turnaround Time) | Notification Information for School, Private Schools & Day Nurseries | | LABORATORY USE ONLY |
|--|--|--------------------------------|--|
| RUSH TAT MUST HAVE PRIOR APPROVAL | Facility Name: St. Angela Merici Catholic | Medical Officer of Health | Received By: <i>20514 25/08/08</i> |
| <input checked="" type="checkbox"/> Normal (5-15 Working Days) | Facility Address: 83 Edenbrook Hill Drive | Region: Peel Region | Date: <i>08/08/08</i> Time: <i>13:17</i> |
| <input type="checkbox"/> RUSH (Specify Below) | Brampton, ON L7A 2N7 | Tel #: | Comments: |
| Date Due: | Tel: 905-840-1505 Fax: 905-840-7445 | Fax #: | |
| PN # | E-mail: | Email: | |
| Relinquished by (Sign Name): <i>Kevin Allen</i> | Date: <i>July 31 2008</i> | Laboratory Prepared Container: | <input type="checkbox"/> Yes <input type="checkbox"/> No |
| Relinquished by (Print Name): | Time: <i>7:00</i> | | |

NOTE: Samples submitted to Maxxam Analytics must be cooled to 4°C or below. It is the Sampler's responsibility to ensure adequate cooling is provided. Please ensure that a separate COC document is provided. **SIF** : Sample Inspection

Resolved By: _____
Date: _____

'08 AUG 1 13:17
8/1/08-C