

Your P.O. #: BN500116
Your Project #: ST BENEDICT
Site:500013846
Your C.O.C. #: na

Attention: Roland Lawton
Dufferin Peel Catholic District...
School Board
40 Matheson Blvd W
Mississauga, ON
L5R 1C5

Report Date: 2008/07/28

CERTIFICATE OF ANALYSIS

MAXXAM JOB #: A878236
Received: 2008/07/17, 13:55

Sample Matrix: Water
Samples Received: 2

Analyses	Quantity	Date Extracted	Date Analyzed	Laboratory Method	Method Reference
Metals Analysis by ICPMS (as received) Ⓟ	1	2008/07/25	2008/07/25	CAM SOP-00447	EPA 6020
Metals Analysis by ICPMS (as received) Ⓟ	1	2008/07/25	2008/07/26	CAM SOP-00447	EPA 6020

* RPDs calculated using raw data. The rounding of final results may result in the apparent difference.

(1) Metals analysis was performed on the sample 'as received'.

Encryption Key

Please direct all questions regarding this Certificate of Analysis to your Project Manager.

JAMES ASPIN, Project Manager
Email: James.Aspin@maxxamAnalytics.com
Phone# (905) 817-5700 Ext:5771

=====
Maxxam has procedures in place to guard against improper use of the electronic signature and have the required "signatories", as per section 5.10.2 of ISO/IEC 17025:2005(E), signing the reports. SCC and CAEAL have approved this reporting process and electronic report format.

For Service Group specific validation please refer to the Validation Signature Page

Total cover pages: 1

Maxxam Job #: A878236
Report Date: 2008/07/28

Dufferin Peel Catholic District...
Client Project #: ST BENEDICT
Project name: 500013846
Your P.O. #: BN500116
Sampler Initials: GO

ELEMENTS BY ATOMIC SPECTROSCOPY (WATER)

Maxxam ID			Z96281		
Sampling Date			2008/07/16 07:20		
COC Number			na		
	Units	Criteria	ST. BENEDICT-KITCHEN-STAFFROOM-S TANDING	RDL	QC Batch

Metals					
. Lead (Pb)	mg/L	0.01	0.0022	0.0005	1570678
<p>RDL = Reportable Detection Limit QC Batch = Quality Control Batch CRITERIA: Ontario Regulation 243/07 made under the Safe Drinking Water Act, 2002. Released June 7, 2007</p>					

Maxxam ID			Z96282		
Sampling Date			2008/07/16 07:55		
COC Number			na		
	Units	Criteria	ST. BENEDICT-KITCHEN-STAFFROOM-F LUSHED	RDL	QC Batch

Metals					
. Lead (Pb)	mg/L	0.01	0.0012	0.0005	1570632
<p>RDL = Reportable Detection Limit QC Batch = Quality Control Batch CRITERIA: Ontario Regulation 243/07 made under the Safe Drinking Water Act, 2002. Released June 7, 2007</p>					

Maxxam Job #: A878236
Report Date: 2008/07/28

Dufferin Peel Catholic District...
Client Project #: ST BENEDICT
Project name: 500013846
Your P.O. #: BN500116
Sampler Initials: GO

Package 1	10.0°C
-----------	--------

Each temperature is the average of up to three cooler temperatures taken at receipt

GENERAL COMMENTS

Results relate only to the items tested.

Dufferin Peel Catholic District...
Attention: Roland Lawton
Client Project #: ST BENEDICT
P.O. #: BN500116
Project name: 500013846

Quality Assurance Report
Maxxam Job Number: MA878236

QA/QC Batch	QC Type	Parameter	Date Analyzed yyyy/mm/dd	Value	Recovery	Units	QC Limits
1570632 JBW	MATRIX SPIKE	. Lead (Pb)	2008/07/26		112	%	80 - 120
	Spiked Blank	. Lead (Pb)	2008/07/26		99	%	85 - 115
	Method Blank	. Lead (Pb)	2008/07/26	ND, RDL=0.5		ug/L	
	RPD	. Lead (Pb)	2008/07/26	1.2		%	25
1570678 HRE	MATRIX SPIKE	. Lead (Pb)	2008/07/25		99	%	80 - 120
	Spiked Blank	. Lead (Pb)	2008/07/25		99	%	85 - 115
	Method Blank	. Lead (Pb)	2008/07/25	ND, RDL=0.5		ug/L	
	RPD	. Lead (Pb)	2008/07/25	NC		%	25

ND = Not detected
 NC = Non-calculable
 RPD = Relative Percent Difference
 SPIKE = Fortified sample

Validation Signature Page

Maxxam Job #: A878236


The analytical data and all QC contained in this report were reviewed and validated by the following individual(s).

Cristina Nervo

CHRISTINA NERVO, Scientific Services

=====

Maxxam has procedures in place to guard against improper use of the electronic signature and have the required "signatories", as per section 5.10.2 of ISO/IEC 17025:2005(E), signing the reports. SCC and CAEAL have approved this reporting process and electronic report format.



6740 Campobello Rd
Mississauga
Ontario L5N 2L8

REGULATION 243 DRINKING WATER SUBM CHAIN OF CUSTODY RECORD

Tel: 905-817-5700
Fax: 905-817-5779
Toll Free: 1-800-563-6266

Samples are Regulated
Under Reg 243

17-Jul-08 13:55
JAMES ASPIN
A878236
CCO ENV-941

Report to:

Company Name: Dufferin-Peel Catholic District School Board
Client Contact: Roland Lawton, General Manager of Physical Plant Facilities
Address: 5685 Keaton Cres., Mississauga ON L5R 3H5
E-Mail: roland.lawton@dpcdsb.org Tel: 905-890-0708 ext. 23204
Project: Regulation 243 Fax: 905-890-5841
Quote #: A83456 P.O.#: BN500636
Lab Service Rep.: James Aspin

Invoice to: Same as "Report to"

DW METALS
PRESERVATION
CHECKED

PAGE		OF
ANALYSIS REQUESTED		
Specify School Type	M.O.E. Assigned Water System Number	
School	Private School	Day nursery
<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	
		500013846

Sample Identification	Sample Type (Please Specify Standing / Flushed)	Date Sampled	Time Sampled	Sampler Initials	Field Chlorine		No. of Bottles	Lead
					Total	Free		
St. Benedict								
Kitchen - Staffroom	Standing	JULY 16	7:20 AM				1	X
Kitchen - Staffroom	Flushed	JULY 16	7:55 AM				1	X

In accordance with the Safe Drinking Water Act (2002), notification of adverse results must be reported to the SAC, MOH & Waterworks. Failure to do so is an offence under the act. It is **IMPERATIVE** that the areas shaded in grey be filled out completely before submitting to Maxxam Analytics.

TAT (Turnaround Time)	Notification Information for School, Private Schools & Day Nurseries		LABORATORY USE ONLY
RUSH TAT MUST HAVE PRIOR APPROVAL	Facility Name: <u>St. Benedict</u>	Medical Officer of Health	Received By: <u>[Signature]</u>
<input checked="" type="checkbox"/> Normal (5-15 Working Days)	Facility Address: <u>345 Blind Line, R.R. #4</u>	Region: <u>Dufferin County</u>	Date: <u>08/10/17</u> Time: <u>13:15</u>
<input type="checkbox"/> RUSH (Specify Below)	<u>Orangeville, ON L9W 4X1</u>	Tel #:	Comments: <u>10/10/10</u>
Rate Due:	Tel: <u>1-519-942-5980</u> Fax: <u>1-519-942-3849</u>	Fax #:	
Inv #	E-mail:	Email:	
Relinquished by (Sign Name): <u>George O'Neill</u>			08 JUL 17 13:55
Relinquished by (Print Name): <u>GEORGE ONEILL</u>			Laboratory Prepared Container: <input type="checkbox"/> Yes <input type="checkbox"/> No
Date: <u>July 16/08</u>			
Time: <u>8 AM</u>			

NOTE: Samples submitted to Maxxam Analytics must be received below 10°C. It is the Sampler's responsibility to ensure adequate cooling is provided so that this receiving temperature is maintained. Please ensure that a separate COC document is used for each individual sample.

SIF: Sample Inspection

Page 6 of 6 Resolved By: _____