Your P.O. #: BN500116
Your Project #: ST. CORNELIUS
Site:500012780
Your C.O.C. #: NA

Attention: Roland Lawton
Dufferin Peel Catholic District...
School Board
40 Matheson Blvd W
Mississauga, ON
L5R 1C5

Report Date: 2008/09/09

CERTIFICATE OF ANALYSIS

MAXXAM JOB #: A8A0485
Received: 2008/09/05, 13:34

Sample Matrix: Water
Samples Received: 2

Analyses	Quantity	Date Extracted	Date Analyzed	Laboratory Method	Method Reference
Metals Analysis by ICPMS (as received) (1)	2	2008/09/08	2008/09/08	CAM SOP-00447	EPA 6020

* RPDs calculated using raw data. The rounding of final results may result in the apparent difference.

(1) Metals analysis was performed on the sample 'as received'.

Encryption Key

James Aspin
09 Sep 2008 09:07:51 -04:00

Please direct all questions regarding this Certificate of Analysis to your Project Manager.

JAMES ASPIN, Project Manager
Email: James.Aspin@maxxamAnalytics.com
Phone# (905) 817-5700 Ext:5771

==========
Maxxam has procedures in place to guard against improper use of the electronic signature and have the required "signatories", as per section 5.10.2 of ISO/IEC 17025:2005(E), signing the reports. SCC and CAEAL have approved this reporting process and electronic report format.

For Service Group specific validation please refer to the Validation Signature Page

Total cover pages: 1

Maxxam Job #: A8A0485
Report Date: 2008/09/09

Dufferin Peel Catholic District...
Client Project #: ST. CORNELIUS
Project name: 500012780
Your P.O. #: BN500116

ELEMENTS BY ATOMIC SPECTROSCOPY (WATER)

Maxxam ID			AK1102	AK1103		
Sampling Date			2008/09/05 05:55	2008/09/05 06:30		
COC Number			NA	NA		
	Units	**Criteria**	**ST CORNELIUS STANDING**	**ST CORNELIUS FLUSHED**	**RDL**	**QC Batch**
Metals						
. Lead (Pb)	mg/L	**0.01**	0.0072	0.0040	0.0005	1606912

RDL = Reportable Detection Limit
QC Batch = Quality Control Batch
CRITERIA: Ontario Regulation 243/07 made under the Safe Drinking Water Act, 2002.

Released June 7, 2007

Maxxam Analytics International Corporation o/a Maxxam Analytics 6740 Campobello Road, Mississauga, Ontario, L5N 2L8 Tel: (905) 817-5700 Toll-Free: 800-563-6266 Fax: (905) 817-5777 www.maxxam.ca

Maxxam Job #: A8A0485
Report Date: 2008/09/09

Dufferin Peel Catholic District...
Client Project #: ST. CORNELIUS
Project name: 500012780
Your P.O. #: BN500116

Package 1	13.0°C

Each temperature is the average of up to three cooler temperatures taken at receipt

GENERAL COMMENTS

Results relate only to the items tested.

Maxxam Analytics International Corporation o/a Maxxam Analytics 6740 Campobello Road, Mississauga, Ontario, L5N 2L8 Tel: (905) 817-5700 Toll-Free: 800-563-6266 Fax: (905) 817-5777 www.maxxam.ca

Dufferin Peel Catholic District...
Attention: Roland Lawton
Client Project #: ST. CORNELIUS
P.O. #: BN500116
Project name: 500012780

Quality Assurance Report

Maxxam Job Number: MA8A0485

QA/QC Batch Num Init	QC Type	Parameter	Date Analyzed yyyy/mm/dd	Value	Recovery	Units	QC Limits
1606912 JBW	MATRIX SPIKE	. Lead (Pb)	2008/09/08		101	%	80 - 120
	Spiked Blank	. Lead (Pb)	2008/09/08		97	%	85 - 115
	Method Blank	. Lead (Pb)	2008/09/08	ND, RDL=0.0005		mg/L	
	RPD	. Lead (Pb)	2008/09/08	1.5 (1)		%	25

ND = Not detected
RPD = Relative Percent Difference
SPIKE = Fortified sample
(1) POTENTIAL EXCEEDENCE FOR PARAMETER

Maxxam Analytics International Corporation o/a Maxxam Analytics 6740 Campobello Road, Mlssissauga, Ontario, L5N 2L8 Tel: (905) 817-5700 Toll-Free: 800-563-6266 Fax: (905) 817-5777 www.maxxam.ca

Validation Signature Page

Maxxam Job #: A8A0485

The analytical data and all QC contained in this report were reviewed and validated by the following individual(s).

TROY CARRIERE, B.Sc., C.Chem, Scientific Specialist

==========

Maxxam has procedures in place to guard against improper use of the electronic signature and have the required "signatories", as per section 5.10.2 of ISO/IEC 17025:2005(E), signing the reports. SCC and CAEAL have approved this reporting process and electronic report format.

Maxxam Analytics International Corporation o/a Maxxam Analytics 6740 Campobello Road, Mississauga, Ontario, L5N 2L8 Tel: (905) 817-5700 Toll-Free: 800-563-6266 Fax: (905) 817-5777 www.maxxam.ca

Maxxam Analytics Inc

6740 Campobello Rd
Mississauga
Ontario L5N 2L8

Tel: 905-817-5700
Fax: 905-817-5779
Toll Free: 1-800-563-6266

REGULATION 243 DRINKING WATER SUBMISSION
CHAIN OF CUSTODY RECORD

Samples are Regulated Under Reg 243

5-Sep-08 13:34
JAMES ASPIN
A8A0485
M_O ENV-664

Report to:

Company Name:	Dufferin-Peel Catholic District School Board		
Client Contact:	Roland Lawton, General Manager of Physical Plant Facilities		
Address:	5685 Keaton Cres., Mississauga ON L5R 3H5		
E-Mail:	roland.lawton@dpcdsb.org	Tel:	905-890-0708 ext. 23204
Project:	Regulation 243	Fax:	905-890-5841
Quote #:	A83456	P.O.#:	BN500636
Lab Service Rep.:	James Aspen		

Invoice to: ✓ Same as "Report to"

PAGE ..... OF .....

ANALYSIS REQUESTED

Sample Identification	Sample Type (Please Specify Standing / Flushed)	Date Sampled	Time Sampled	Sampler Initials	Field Chlorine Total	Field Chlorine Free	No. of Bottles	Lead		Specify School Type: School	Private School	Day nursery	M.O.E. Assigned Water System Number
St. Cornelius		SEPT 5/08	5:55 AM										500012780
Kitchen - Staffroom	Standing						1	x		x			
		SEPT 5/08	6:30 AM										
Kitchen - Staffroom	Flushed						1	x		x			

08 SEP 5 13:34

* In accordance with the Safe Drinking Water Act (2002), notification of adverse results must be reported to the SAC, MOH & Waterworks.
Failure to do so is an offence under the act. **It is IMPERATIVE** that the areas shaded in grey be filled out completely before submitting to Maxxam Analytics.

TAT (Turnaround Time)	Notification Information for School , Private Schools & Day Nurseries		LABORATORY USE ONLY
RUSH TAT MUST HAVE PRIOR APPROVAL	Facility Name: St. Cornelius	Medical Officer of Health	Received By: Sunaina
	Facility Address: 16066 Innis Lake Road	Region: Peel Region	Date: 08/09/05 Time: 13:34
✓ Normal (5-15 Working Days)	Caledon East, ON L7C 2Z2		Comments: 13/13/13°
☐ RUSH (Specify Below)		Tel #:	
Date Due:	Tel: 1-905-584-2245 Fax: 1-905-584-0924	Fax.#:	
PN #	E-mail:	Email :	
Relinquished by (Sign Name):	Tony Costantile	Date: SEPT 5/08	Laboratory Prepared Container:
Relinquished by (Print Name):	TONY COSTANTILE	Time:	

NOTE: Samples sub... d below 10°C.
It is the Sampler's responsibility to en... s receiving temper...
Please ensure ... ch indiv...

SIF : Sample Inspection
Resolved ☐ By: ____
Date:

EXCEEDED PRESERVATION CHECK