Your Project #: ST DAVID OF WALES
Site:500019371
Your C.O.C. #: NA

Attention: Roland Lawton
Dufferin Peel Catholic District...
School Board
40 Matheson Blvd W
Mississauga, ON
L5R 1C5

Report Date: 2008/07/28

CERTIFICATE OF ANALYSIS

MAXXAM JOB #: A877965
Received: 2008/07/17, 14:57

Sample Matrix: Water
Samples Received: 2

Analyses	Quantity	Date Extracted	Date Analyzed	Laboratory Method	Method Reference
Metals Analysis by ICPMS (as received) (1)	2	2008/07/25	2008/07/25	CAM SOP-00447	EPA 6020

* RPDs calculated using raw data. The rounding of final results may result in the apparent difference.

(1) Metals analysis was performed on the sample 'as received'.

Encryption Key

James Aspin
28 Jul 2008 13:35:01 -04:00

Please direct all questions regarding this Certificate of Analysis to your Project Manager.

JAMES ASPIN, Project Manager
Email: James.Aspin@maxxamAnalytics.com
Phone# (905) 817-5700 Ext:5771

==========
Maxxam has procedures in place to guard against improper use of the electronic signature and have the required "signatories", as per section 5.10.2 of ISO/IEC 17025:2005(E), signing the reports. SCC and CAEAL have approved this reporting process and electronic report format.

For Service Group specific validation please refer to the Validation Signature Page

Total cover pages: 1

6740 Campobello Road, Mississauga, Ontario Canada L5N 2L8 Tel: 905-817-5700 Toll free:800-563-6266 Fax: 905-817-5777

Maxxam Job #: A877965
Report Date: 2008/07/28

Dufferin Peel Catholic District...
Client Project #: ST DAVID OF WALES
Project name: 500019371
Sampler Initials: GB

ELEMENTS BY ATOMIC SPECTROSCOPY (WATER)

Maxxam ID			Z95414		
Sampling Date			2008/07/17 06:30		
COC Number			NA		
	Units	**Criteria**	**ST. DAVID OF WALES KITCHEN-STAFFROOM/STANDING**	**RDL**	**QC Batch**
Metals					
. Lead (Pb)	mg/L	**0.01**	0.0014	0.0005	1570400

RDL = Reportable Detection Limit
QC Batch = Quality Control Batch
CRITERIA: Ontario Regulation 243/07 made under the Safe Drinking Water Act, 2002.

Released June 7, 2007

Maxxam ID			Z95415		
Sampling Date			2008/07/17 07:05		
COC Number			NA		
	Units	**Criteria**	**ST. DAVID OF WALES KITCHEN-STAFFROOM/FLUSHED**	**RDL**	**QC Batch**
Metals					
. Lead (Pb)	mg/L	**0.01**	0.0006	0.0005	1570417

RDL = Reportable Detection Limit
QC Batch = Quality Control Batch
CRITERIA: Ontario Regulation 243/07 made under the Safe Drinking Water Act, 2002.

Released June 7, 2007

6740 Campobello Road, Mississauga, Ontario Canada L5N 2L8 Tel: 905-817-5700 Toll free:800-563-6266 Fax: 905-817-5777

Maxxam Job #: A877965
Report Date: 2008/07/28

Dufferin Peel Catholic District...
Client Project #: ST DAVID OF WALES
Project name: 500019371
Sampler Initials: GB

Package 1	13.3°C

Each temperature is the average of up to three cooler temperatures taken at receipt

GENERAL COMMENTS

Results relate only to the items tested.

6740 Campobello Road, Mississauga, Ontario Canada L5N 2L8 Tel: 905-817-5700 Toll free:800-563-6266 Fax: 905-817-5777

Dufferin Peel Catholic District...
Attention: Roland Lawton
Client Project #: ST DAVID OF WALES
P.O. #:
Project name: 500019371

Quality Assurance Report

Maxxam Job Number: MA877965

QA/QC Batch Num Init	QC Type	Parameter	Date Analyzed yyyy/mm/dd	Value	Recovery	Units	QC Limits
1570400 HRE	MATRIX SPIKE	. Lead (Pb)	2008/07/25		100	%	80 - 120
	Spiked Blank	. Lead (Pb)	2008/07/25		101	%	85 - 115
	Method Blank	. Lead (Pb)	2008/07/25	ND, RDL=0.5		ug/L	
	RPD	. Lead (Pb)	2008/07/25	NC		%	25
1570417 HRE	MATRIX SPIKE	. Lead (Pb)	2008/07/25		100	%	80 - 120
	Spiked Blank	. Lead (Pb)	2008/07/25		97	%	85 - 115
	Method Blank	. Lead (Pb)	2008/07/25	ND, RDL=0.5		ug/L	
	RPD	. Lead (Pb)	2008/07/25	1.2		%	25

ND = Not detected
NC = Non-calculable
RPD = Relative Percent Difference
SPIKE = Fortified sample

6740 Campobello Road, Mississauga, Ontario Canada L5N 2L8 Tel: 905-817-5700 Toll free:800-563-6266 Fax: 905-817-5777

Validation Signature Page

Maxxam Job #: A877965

The analytical data and all QC contained in this report were reviewed and validated by the following individual(s).

Christina Nervo

CHRISTINA NERVO, Scientific Services

==========

Maxxam has procedures in place to guard against improper use of the electronic signature and have the required "signatories", as per section 5.10.2 of ISO/IEC 17025:2005(E), signing the reports. SCC and CAEAL have approved this reporting process and electronic report format.

6740 Campobello Road, Mississauga, Ontario Canada L5N 2L8 Tel: 905-817-5700 Toll free:800-563-6266 Fax: 905-817-5777

17-Jul-08 14:57
JAMES ASPIN
A877965
FW ENV-756

Maxxam Analytics Inc

6740 Campobello Rd
Mississauga
Ontario L5N 2L8

Tel: 905-817-5700
Fax: 905-817-5779
Toll Free: 1-800-563-6266

REGULATION 243 DRINKING WATER SU
CHAIN OF CUSTODY RECO

Samples are Regulated Under Reg 243

Maxxam Analytics Inc.
CAM FCD-00196/2

Report to:

Company Name:	Dufferin-Peel Catholic District School Board		
Client Contact:	Roland Lawton, General Manager of Physical Plant Facilities		
Address:	5685 Keaton Cres., Mississauga ON L5R 3H5		
E-Mail:	roland.lawton@dpcdsb.org	Tel:	905-890-0708 ext. 23204
Project:	Regulation 243	Fax:	905-890-5841
Quote #:	A83456	P.O.#:	BN500636
Lab Service Rep.:	James Aspen		

Invoice to: ✓ Same as "Report to"

PAGE ..... OF .....

DW METALS PRESERVATION CHECKED

Sample Identification	Sample Type (Please Specify Standing / Flushed)	Date Sampled	Time Sampled	Sampler Initials	Field Chlorine Total	Field Chlorine Free	No. of Bottles	Lead		School	Private School	Day nursery	M.O.E. Assigned Water System Number
St. David of Wales													500019371
Kitchen - Staffroom	Standing	07.17.08	6:30				1	x		x			
Kitchen - Staffroom	Flushed	07.17.08	7:05				1	x		x			

ANALYSIS REQUESTED — Specify School Type

SIF : Sample Inspection
Resolved ☐ By: _____
Date: _____

* In accordance with the Safe Drinking Water Act (2002), notification of adverse results must b
Failure to do so is an offence under the act. **It is IMPERATIVE** that the areas shaded in grey m Analytics.

TAT (Turnaround Time)	Notification Information for School , Private Schools & Day Nurseries		LABORATORY USE ONLY
RUSH TAT MUST HAVE PRIOR APPROVAL	Facility Name: St. David of Wales	Medical Officer of Health	Received By: ZOEY ZOOTA
	Facility Address: 4200 Beacon Lane	Region: Peel Region	Date: 08/07/17 Time: 14:57
✓ Normal (5-15 Working Days)	Mississauga, ON L5C 3V9		Comments: 12/14/14
☐ RUSH (Specify Below)		Tel #:	
Date Due:	Tel: 905-848-4200 Fax: 905-848-8172	Fax #:	
PN #	E-mail:	Email :	
Relinquished by (Sign Name): G. Balyta	Date: July 17/08		Laboratory Prepared Container:
Relinquished by (Print Name): G. BALYTA	Time: 2:54 pm		☐ Yes ☐ No

NOTE: Samples submitted to Maxxam Analytics must be received below 10°C.
It is the Sampler's responsibility to ensure adequate cooling is provided so that this receiving temperature is met.
Please ensure that a separate COC document is used for each indiv

'08 JUL 17 14:57
12/14/11 %