

Your Project #: ST. EDMUND CAMPION  
Site:500012468  
Your C.O.C. #: na

**Attention: Roland Lawton**  
Dufferin Peel Catholic District...  
School Board  
40 Matheson Blvd W  
Mississauga, ON  
L5R 1C5

**Report Date: 2008/08/13**

**CERTIFICATE OF ANALYSIS**

**MAXXAM JOB #: A885767**  
**Received: 2008/07/17, 14:41**

Sample Matrix: Water  
# Samples Received: 2

Analyses	Quantity	Date Extracted	Date Analyzed	Laboratory Method	Method Reference
Metals Analysis by ICPMS (as received) 0	2	2008/08/11	2008/08/12	CAM SOP-00447	EPA 6020

\* RPDs calculated using raw data. The rounding of final results may result in the apparent difference.

(1) Metals analysis was performed on the sample 'as received'.

**Encryption Key**

Please direct all questions regarding this Certificate of Analysis to your Project Manager.

JAMES ASPIN, Project Manager  
Email: James.Aspin@maxxamAnalytics.com  
Phone# (905) 817-5700 Ext:5771

=====

Maxxam has procedures in place to guard against improper use of the electronic signature and have the required "signatories", as per section 5.10.2 of ISO/IEC 17025:2005(E), signing the reports. SCC and CAEAL have approved this reporting process and electronic report format.

For Service Group specific validation please refer to the Validation Signature Page

Total cover pages: 1

Maxxam Job #: A885767  
Report Date: 2008/08/13

Dufferin Peel Catholic District...  
Client Project #: ST. EDMUND CAMPION  
Project name: 500012468

**ELEMENTS BY ATOMIC SPECTROSCOPY (WATER)**

Maxxam ID			AD0401		AD0402		
Sampling Date			2008/07/15 06:40		2008/07/15 07:20		
COC Number			na		na		
	<b>Units</b>	<b>Criteria</b>	<b>ST. EDMUND CAMPION KITCHEN- STAFFROOM STANDING</b>	<b>QC Batch</b>	<b>ST. EDMUND CAMPION KITCHEN- STAFFROOM FLUSHED</b>	<b>RDL</b>	<b>QC Batch</b>

<b>Metals</b>							
. Lead (Pb)	mg/L	<b>0.01</b>	ND	1583288	ND	0.0005	1583279

ND = Not detected  
RDL = Reportable Detection Limit  
QC Batch = Quality Control Batch  
CRITERIA: Ontario Regulation 243/07 made under the Safe Drinking Water Act, 2002.  
  
Released June 7, 2007

Maxxam Job #: A885767  
Report Date: 2008/08/13

Dufferin Peel Catholic District...  
Client Project #: ST. EDMUND CAMPION  
Project name: 500012468

Package 1	14.7°C
-----------	--------

Each temperature is the average of up to three cooler temperatures taken at receipt

**GENERAL COMMENTS**

**Results relate only to the items tested.**

Dufferin Peel Catholic District...  
Attention: Roland Lawton  
Client Project #: ST. EDMUND CAMPION  
P.O. #:  
Project name: 500012468

Quality Assurance Report  
Maxxam Job Number: MA885767

QA/QC Batch	QC Type	Parameter	Date Analyzed yyyy/mm/dd	Value	Recovery	Units	QC Limits
1583279 MIL	MATRIX SPIKE	. Lead (Pb)	2008/08/12		106	%	80 - 120
	Spiked Blank	. Lead (Pb)	2008/08/12		107	%	85 - 115
	Method Blank	. Lead (Pb)	2008/08/12	ND, RDL=0.0005		mg/L	
	RPD	. Lead (Pb)	2008/08/12	NC		%	25
1583288 HRE	MATRIX SPIKE	. Lead (Pb)	2008/08/11		99	%	80 - 120
	Spiked Blank	. Lead (Pb)	2008/08/11		96	%	85 - 115
	Method Blank	. Lead (Pb)	2008/08/11	ND, RDL=0.0005		mg/L	
	RPD	. Lead (Pb)	2008/08/11	NC		%	25


ND = Not detected  
 NC = Non-calculable  
 RPD = Relative Percent Difference  
 SPIKE = Fortified sample

**Validation Signature Page**

**Maxxam Job #: A885767**

---

The analytical data and all QC contained in this report were reviewed and validated by the following individual(s).



---

BRAD NEWMAN, Scientific Specialist

=====

Maxxam has procedures in place to guard against improper use of the electronic signature and have the required "signatories", as per section 5.10.2 of ISO/IEC 17025:2005(E), signing the reports. SCC and CAEAL have approved this reporting process and electronic report format.



6740 Campobello Rd  
Mississauga  
Ontario L5N 2L8

## REGULATION 243 DRINKING WATER SUBMISSION CHAIN OF CUSTODY RECORD

Tel: 905-817-5700  
Fax: 905-817-5779  
Toll Free: 1-800-563-6266

Samples are Regulated  
Under Reg 243

Maxxam Analytics Inc.  
CAM FCD-00196/2

### Report to:

Company Name: Dufferin-Peel Catholic District School Board  
Client Contact: Roland Lawton, General Manager of Physical Plant Facilities  
Address: 5685 Keaton Cres., Mississauga ON L5R 3H5  
E-Mail: [roland.lawton@dpcdsb.org](mailto:roland.lawton@dpcdsb.org) Tel: 905-890-0708 ext. 23204  
Project: Regulation 243 Fax: 905-890-5841  
Quote #: A83456 P.O.#: BN500636  
Lab Service Rep.: James Aspen

Invoice to:  Same as "Report to"

17-Jul-08 14:41

JAMES ASPIN



A885767

NNA ENV-667

PAGE \_\_\_\_ OF \_\_\_\_

### ANALYSIS REQUESTED

Specify  
School  
Type

School  
Private School  
Day nursery

M.O.E. Assigned  
Water System  
Number

500012468

Sample Identification	Sample Type (Please Specify Standing / Flushed)	Date Sampled	Time Sampled	Sampler Initials	Field Chlorine		No. of Bottles	Lead	School	Private School	Day nursery	M.O.E. Assigned Water System Number
					Total	Free						
<b>St. Edmund Campion</b>												
Kitchen - Staffroom	Standing	July 15	6:40 AM				1	X	X			
Kitchen - Staffroom	Flushed	July 15	7:20 AM					X	X			

DW METALS  
PRESERVATION  
CHECKED

In accordance with the Safe Drinking Water Act (2002), notification of adverse results must be reported to the SAC, MOH & Waterworks. Failure to do so is an offence under the act. It is **IMPERATIVE** that the areas shaded in grey be filled out completely before submitting to Maxxam Analytics.

Turnaround Time	Notification Information for School, Private Schools & Day Nurseries		LABORATORY USE ONLY	
<b>RUSH TAT MUST HAVE PRIOR APPROVAL</b>	Facility Name: St. Edmund Campion	Medical Officer of Health	Received By: <i>Kim Williams</i>	
<input checked="" type="checkbox"/> Normal (5-15 Working Days)	Facility Address: 275 Brisdale Drive	Region: Peel Region	Date: 08/07/08 Time: 14:41	
<input type="checkbox"/> RUSH (Specify Below)	Brampton, ON L7A 3C7	Tel #:	Comments: 14/15/15	
Date Due:	Tel: 905-846-7124 Fax: 905-846-1527	Fax #:	JUL 17 '08 14:41	
PN #	E-mail:	Email:		
Relinquished by (Sign Name): <i>Kim Williams</i>	Date: July 17/08	Laboratory Prepared Container:	<input type="checkbox"/> Yes <input type="checkbox"/> No	
Relinquished by (Print Name): Kim Williams	Time: 2:50pm			

**NOTE:** Samples received below 10°C. It is the Sampler's responsibility to ensure that this receiving temperature is met. Please ensure that this receiving temperature is met for each individual sample.

SIF: Sample Inspection

Resolved By: \_\_\_\_\_

Page 6 of 6

Date: \_\_\_\_\_