

Your P.O. #: BN500636  
Your Project #: ST HERBERT  
Site:500019150  
Your C.O.C. #: na

**Attention: Roland Lawton**  
Dufferin Peel Catholic District...  
School Board  
40 Matheson Blvd W  
Mississauga, ON  
L5R 1C5

**Report Date: 2008/07/25**

**CERTIFICATE OF ANALYSIS**

**MAXXAM JOB #: A877894**  
**Received: 2008/07/17, 13:14**

Sample Matrix: Water  
# Samples Received: 2

Analyses	Quantity	Date Extracted	Date Analyzed	Laboratory Method	Method Reference
Metals Analysis by ICPMS (as received) ¶	2	2008/07/24	2008/07/24	CAM SOP-00447	EPA 6020

\* RPDs calculated using raw data. The rounding of final results may result in the apparent difference.

(1) Metals analysis was performed on the sample 'as received'.

**Encryption Key**

Please direct all questions regarding this Certificate of Analysis to your Project Manager.

JAMES ASPIN, Project Manager  
Email: James.Aspin@maxxamAnalytics.com  
Phone# (905) 817-5700 Ext:5771

=====  
Maxxam has procedures in place to guard against improper use of the electronic signature and have the required "signatories", as per section 5.10.2 of ISO/IEC 17025:2005(E), signing the reports. SCC and CAEAL have approved this reporting process and electronic report format.

For Service Group specific validation please refer to the Validation Signature Page

Total cover pages: 1

Maxxam Job #: A877894  
Report Date: 2008/07/25

Dufferin Peel Catholic District...  
Client Project #: ST HERBERT  
Project name: 500019150  
Your P.O. #: BN500636

**ELEMENTS BY ATOMIC SPECTROSCOPY (WATER)**

Maxxam ID			Z95099		
Sampling Date			2008/07/17 06:08		
COC Number			na		
	<b>Units</b>	<b>Criteria</b>	<b>KITCHEN-STAFFROOM(STANDING)</b>	<b>RDL</b>	<b>QC Batch</b>

<b>Metals</b>					
. Lead (Pb)	mg/L	<b>0.01</b>	0.0011	0.0005	1569253

RDL = Reportable Detection Limit  
QC Batch = Quality Control Batch  
CRITERIA: Ontario Regulation 243/07 made under the Safe Drinking Water Act, 2002.  
Released June 7, 2007

Maxxam ID			Z95100		
Sampling Date			2008/07/17 06:43		
COC Number			na		
	<b>Units</b>	<b>Criteria</b>	<b>KITCHEN-STAFFROOM(FLUSHED)</b>	<b>RDL</b>	<b>QC Batch</b>

<b>Metals</b>					
. Lead (Pb)	mg/L	<b>0.01</b>	0.0011	0.0005	1569253

RDL = Reportable Detection Limit  
QC Batch = Quality Control Batch  
CRITERIA: Ontario Regulation 243/07 made under the Safe Drinking Water Act, 2002.  
Released June 7, 2007

Maxxam Job #: A877894  
Report Date: 2008/07/25

Dufferin Peel Catholic District...  
Client Project #: ST HERBERT  
Project name: 500019150  
Your P.O. #: BN500636

Package 1	12.3°C
-----------	--------

Each temperature is the average of up to three cooler temperatures taken at receipt

**GENERAL COMMENTS**

**Results relate only to the items tested.**

Dufferin Peel Catholic District...  
Attention: Roland Lawton  
Client Project #: ST HERBERT  
P.O. #: BN500636  
Project name: 500019150

Quality Assurance Report  
Maxxam Job Number: MA877894

QA/QC Batch	QC Type	Parameter	Date Analyzed yyyy/mm/dd	Value	Recovery	Units	QC Limits
1569253 JBW	MATRIX SPIKE	. Lead (Pb)	2008/07/24		106	%	80 - 120
	Spiked Blank	. Lead (Pb)	2008/07/24		99	%	85 - 115
	Method Blank	. Lead (Pb)	2008/07/24	ND, RDL=0.5		ug/L	
	RPD	. Lead (Pb)	2008/07/24	NC		%	25

ND = Not detected  
NC = Non-calculable  
RPD = Relative Percent Difference  
SPIKE = Fortified sample

**Validation Signature Page**

**Maxxam Job #: A877894**

---

The analytical data and all QC contained in this report were reviewed and validated by the following individual(s).

  


---

TROY CARRIERE, B.Sc., C.Chem, Scientific Specialist

---

Maxxam has procedures in place to guard against improper use of the electronic signature and have the required "signatories", as per section 5.10.2 of ISO/IEC 17025:2005(E), signing the reports. SCC and CAEAL have approved this reporting process and electronic report format.

6740 Campobello Rd  
 Mississauga  
 Ontario L5N 2L8

**REGULATION 243 DRINKING WATER SUBM**  
**CHAIN OF CUSTODY RECORD**

Tel: 905-817-5700  
 Fax: 905-817-5779  
 Toll Free: 1-800-563-6266

Samples are Regulated  
 Under Reg 243

17-Jul-08 13:14

JAMES ASPIN



A877894

J L ENV-970

LAM FLD-00190/2

**Report to:**

Company Name: Dufferin-Peel Catholic District School Board  
 Client Contact: Roland Lawton, General Manager of Physical Plant Facilities  
 Address: 5685 Keaton Cres., Mississauga ON L5R 3H5  
 E-Mail: roland.lawton@dpccdsb.org Tel: 905-890-0708 ext. 23204  
 Project: Regulation 243 Fax: 905-890-5841  
 Quote #: A83456 P.O.#: BN500636  
 Lab Service Rep.: James Aspen

Invoice to:  Same as "Report to"

**DW METALS  
 PRESERVATION  
 CHECKED**

PAGE \_\_\_\_\_ OF \_\_\_\_\_

**ANALYSIS REQUESTED**

Specify School Type

School Private School Day nursery

M.O.E. Assigned Water System Number

Sample Identification	Sample Type (Please Specify Standing / Flushed)	Date Sampled	Time Sampled	Sampler Initials	Field Chlorine		No. of Bottles	Lead	School	Private School	Day nursery	M.O.E. Assigned Water System Number
					Total	Free						
<b>St. Herbert</b>												500019150
Kitchen - Staffroom	Standing	JULY 17 2008	6:08 A.M	RM			1	X	X			
Kitchen - Staffroom	Flushed	JULY 17 2008	6:43 A.M	RM			1	X	X			

\* In accordance with the Safe Drinking Water Act (2002), notification of adverse results must be reported to the SAC, MOH & Waterworks. Failure to do so is an offence under the act. It is **IMPERATIVE** that the areas shaded in grey be filled out completely before submitting to Maxxam Analytics.

TAT (Turnaround Time)	Notification Information for School, Private Schools & Day Nurseries		LABORATORY USE ONLY
<b>RUSH TAT MUST HAVE PRIOR APPROVAL</b>	Facility Name: St. Herbert	Medical Officer of Health	Received By: <i>[Signature]</i>
<input checked="" type="checkbox"/> Normal (5-15 Working Days)	Facility Address: 5180 Fallingbrook Drive	Region: Peel Region	Date: 08/07/17 Time: 13:14
<input type="checkbox"/> RUSH (Specify Below)	Mississauga, ON L5V 2C6	Tel #:	Comments: insufficient cooling 13/12/12°C
Date Due:	Tel: 905-858-1171 Fax: 905-858-1173	Fax #:	
PN #	E-mail:	Email:	
Relinquished by (Sign Name): <i>[Signature]</i>	Date: JULY 17, 2008	Laboratory Prepared Container: <input type="checkbox"/> Yes <input type="checkbox"/> No	
Relinquished by (Print Name): RONALDO MEANA	Time: 6:48 A.M		

**NOTE:** Samples submitted to Maxxam Analytics must be received by 10:00 AM. It is the Sampler's responsibility to ensure adequate cooling is provided so that the samples are preserved. Please ensure that a separate COC document is used for each sample.

**SIF** : Sample Inspection  
 Resolved  By: \_\_\_\_\_

08 JUL 17 13:14