

Your P.O. #: BN500636
Your Project #: ST JEAN BREBEUF
Site:500012559
Your C.O.C. #: NA

Attention: Roland Lawton
Dufferin Peel Catholic District...
School Board
40 Matheson Blvd W
Mississauga, ON
L5R 1C5

Report Date: 2008/08/07

CERTIFICATE OF ANALYSIS

MAXXAM JOB #: A885267
Received: 2008/08/01, 13:31

Sample Matrix: Water
Samples Received: 2

Analyses	Quantity	Date Extracted	Date Analyzed	Laboratory Method	Method Reference
Metals Analysis by ICPMS (as received) 0	2	2008/08/06	2008/08/07	CAM SOP-00447	EPA 6020

* RPDs calculated using raw data. The rounding of final results may result in the apparent difference.

(1) Metals analysis was performed on the sample 'as received'.

Encryption Key

Please direct all questions regarding this Certificate of Analysis to your Project Manager.

JAMES ASPIN, Project Manager
Email: James.Aspin@maxxamAnalytics.com
Phone# (905) 817-5700 Ext:5771

=====
Maxxam has procedures in place to guard against improper use of the electronic signature and have the required "signatories", as per section 5.10.2 of ISO/IEC 17025:2005(E), signing the reports. SCC and CAEAL have approved this reporting process and electronic report format.

For Service Group specific validation please refer to the Validation Signature Page

Total cover pages: 1

Maxxam Job #: A885267
Report Date: 2008/08/07

Dufferin Peel Catholic District...
Client Project #: ST JEAN BREBEUF
Project name: 500012559
Your P.O. #: BN500636

ELEMENTS BY ATOMIC SPECTROSCOPY (WATER)

Maxxam ID			AC7919		AC7920		
Sampling Date			2008/07/31 07:00		2008/07/31 07:35		
COC Number			NA		NA		
	Units	Criteria	ST JEAN BREBEUF KITCHEN STANDING	QC Batch	ST JEAN BREBEUF KITCHEN FLUSHED	RDL	QC Batch

Metals							
. Lead (Pb)	mg/L	0.01	0.0039	1579769	0.0024	0.0005	1579773

RDL = Reportable Detection Limit
QC Batch = Quality Control Batch
CRITERIA: Ontario Regulation 243/07 made under the Safe Drinking Water Act, 2002.
Released June 7, 2007

Maxxam Job #: A885267
Report Date: 2008/08/07

Dufferin Peel Catholic District...
Client Project #: ST JEAN BREBEUF
Project name: 500012559
Your P.O. #: BN500636

Package 1	8.3°C
-----------	-------

Each temperature is the average of up to three cooler temperatures taken at receipt

GENERAL COMMENTS

Results relate only to the items tested.

Dufferin Peel Catholic District...
Attention: Roland Lawton
Client Project #: ST JEAN BREBEUF
P.O. #: BN500636
Project name: 500012559

Quality Assurance Report
Maxxam Job Number: MA885267

QA/QC Batch Num Init	QC Type	Parameter	Date Analyzed yyyy/mm/dd	Value	Recovery	Units	QC Limits
1579769 HRE	MATRIX SPIKE [AC7919-01]	. Lead (Pb)	2008/08/07		98	%	80 - 120
	Spiked Blank	. Lead (Pb)	2008/08/07		98	%	85 - 115
	Method Blank	. Lead (Pb)	2008/08/07	ND, RDL=0.0005		mg/L	
	RPD [AC7919-01]	. Lead (Pb)	2008/08/07	0.2		%	25
1579773 HRE	MATRIX SPIKE	. Lead (Pb)	2008/08/07		96	%	80 - 120
	Spiked Blank	. Lead (Pb)	2008/08/07		98	%	85 - 115
	Method Blank	. Lead (Pb)	2008/08/07	ND, RDL=0.0005		mg/L	
	RPD	. Lead (Pb)	2008/08/07	NC		%	25

ND = Not detected
NC = Non-calculable
RPD = Relative Percent Difference
SPIKE = Fortified sample

Validation Signature Page

Maxxam Job #: A885267

The analytical data and all QC contained in this report were reviewed and validated by the following individual(s).

 

EWA PRANJIC, M.Sc., C.Chem, Scientific Specialist

=====
Maxxam has procedures in place to guard against improper use of the electronic signature and have the required "signatories", as per section 5.10.2 of ISO/IEC 17025:2005(E), signing the reports. SCC and CAEAL have approved this reporting process and electronic report format.

REGULATION 243 DRINKING WATER SUBM CHAIN OF CUSTODY RECORD

Tel: 905-817-5700
Fax: 905-817-5779
Toll Free: 1-800-563-6266

Samples are Regulated
Under Reg 243

1-Aug-08 13:31
JAMES ASPIN
A885267
M_O ENV-813

Report to:

Company Name: Dufferin-Peel Catholic District School Board
Client Contact: Roland Lawton, General Manager of Physical Plant Facilities
Address: 5685 Keaton Cres., Mississauga ON L5R 3H5
E-Mail: roland.lawton@dpcdsb.org Tel: 905-890-0708 ext. 23204
Project: Regulation 243 Fax: 905-890-5841
Quote #: A83456 P.O.#: BN500636
Lab Service Rep.: James Aspin

Invoice to: Same as "Report to"

DW METALS
PRESERVATION
CHECKED

PAGE _____ OF _____

ANALYSIS REQUESTED			
Specify School Type	School	Private School	Day nursery
M.O.E. Assigned Water System Number			
			500012559

Sample Identification	Sample Type (Please Specify Standing / Flushed)	Date Sampled	Time Sampled	Sampler Initials	Field Chlorine		No. of Bottles	Lead	School	Private School	Day nursery
					Total	Free					
St. Jean Brebeuf Kitchen - Staffroom	Standing	JULY 31/08	7:00	[Signature]			1	x	x		
Kitchen - Staffroom	Flushed	JULY 31/08	7:35	[Signature]			1	x	x		

* In accordance with the Safe Drinking Water Act (2002), notification of adverse results must be reported to the SAC, MOH & Waterworks. Failure to do so is an offence under the act. It is **IMPERATIVE** that the areas shaded in grey be filled out completely before submitting to Maxxam Analytics.

TAT (Turnaround Time)	Notification Information for School, Private Schools & Day Nurseries		LABORATORY USE ONLY
RUSH TAT MUST HAVE PRIOR APPROVAL	Facility Name: St. Jean Brebeuf	Medical Officer of Health	Received By: [Signature]
<input checked="" type="checkbox"/> Normal (5-15 Working Days)	Facility Address: 63 Glenforest Road	Region: Peel Region	Date: 08/08/08 Time: 17:31
<input type="checkbox"/> RUSH (Specify Below)	Brampton, ON L6S 1L8	Tel #:	Comments:
Date Due:	Tel: 905-791-8529 Fax: 905-791-6468	Fax #:	
PN #	E-mail:	Email:	
Relinquished by (Sign Name): [Signature]	Date: July 31/08	Laboratory Prepared Container:	<input type="checkbox"/> Yes <input type="checkbox"/> No
Relinquished by (Print Name): FRANK GONZALEZ	Time:		

NOTE: Samples submitted to Maxxam Analytics must be cooled to 4°C or below. It is the Sampler's responsibility to ensure adequate cooling is provided. Please ensure that a separate COC document is provided.

SIF : Sample Inspection
Resolved By: _____
Date: _____

7/31/08
08 AUG 1 13:31