

Your Project #: ST JEROME
Site:500018864
Your C.O.C. #: NA

Attention: Roland Lawton
Dufferin Peel Catholic District...
School Board
40 Matheson Blvd W
Mississauga, ON
L5R 1C5

Report Date: 2008/07/25

CERTIFICATE OF ANALYSIS

MAXXAM JOB #: A877964
Received: 2008/07/17, 14:56

Sample Matrix: Water
Samples Received: 2

Analyses	Quantity	Date Extracted	Date Analyzed	Laboratory Method	Method Reference
Metals Analysis by ICPMS (as received) ①	1	2008/07/24	2008/07/24	CAM SOP-00447	EPA 6020
Metals Analysis by ICPMS (as received) ①	1	2008/07/24	2008/07/25	CAM SOP-00447	EPA 6020

* RPDs calculated using raw data. The rounding of final results may result in the apparent difference.

(1) Metals analysis was performed on the sample 'as received'.

Encryption Key

Please direct all questions regarding this Certificate of Analysis to your Project Manager.

JAMES ASPIN, Project Manager
Email: James.Aspin@maxxamAnalytics.com
Phone# (905) 817-5700 Ext:5771

=====
Maxxam has procedures in place to guard against improper use of the electronic signature and have the required "signatories", as per section 5.10.2 of ISO/IEC 17025:2005(E), signing the reports. SCC and CAEAL have approved this reporting process and electronic report format.

For Service Group specific validation please refer to the Validation Signature Page

Total cover pages: 1

Maxxam Job #: A877964
Report Date: 2008/07/25

Dufferin Peel Catholic District...
Client Project #: ST JEROME
Project name: 500018864
Sampler Initials: LC

ELEMENTS BY ATOMIC SPECTROSCOPY (WATER)

Maxxam ID			Z95412		
Sampling Date			2008/07/17 06:15		
COC Number			NA		
	Units	Criteria	ST. JEROME	RDL	QC Batch
			KITCHEN-STAFFROOM/STANDING		

Metals					
. Lead (Pb)	mg/L	0.01	0.0013	0.0005	1569634
RDL = Reportable Detection Limit QC Batch = Quality Control Batch CRITERIA: Ontario Regulation 243/07 made under the Safe Drinking Water Act, 2002. Released June 7, 2007					

Maxxam ID			Z95413		
Sampling Date			2008/07/17 06:50		
COC Number			NA		
	Units	Criteria	ST. JEROME	RDL	QC Batch
			KITCHEN-STAFFROOM/FLUSHED		

Metals					
. Lead (Pb)	mg/L	0.01	ND	0.0005	1569380
ND = Not detected RDL = Reportable Detection Limit QC Batch = Quality Control Batch CRITERIA: Ontario Regulation 243/07 made under the Safe Drinking Water Act, 2002. Released June 7, 2007					

Maxxam Job #: A877964
Report Date: 2008/07/25

Dufferin Peel Catholic District...
Client Project #: ST JEROME
Project name: 500018864
Sampler Initials: LC

Package 1	12.7°C
-----------	--------

Each temperature is the average of up to three cooler temperatures taken at receipt

GENERAL COMMENTS

Results relate only to the items tested.

Dufferin Peel Catholic District...
Attention: Roland Lawton
Client Project #: ST JEROME
P.O. #:
Project name: 500018864

Quality Assurance Report
Maxxam Job Number: MA877964

QA/QC Batch	QC Type	Parameter	Date Analyzed yyyy/mm/dd	Value	Recovery	Units	QC Limits
1569380 HRE	MATRIX SPIKE	. Lead (Pb)	2008/07/24		99	%	80 - 120
	Spiked Blank	. Lead (Pb)	2008/07/24		98	%	85 - 115
	Method Blank	. Lead (Pb)	2008/07/24	ND, RDL=0.5		ug/L	
	RPD	. Lead (Pb)	2008/07/24	NC		%	25
1569634 HRE	MATRIX SPIKE	. Lead (Pb)	2008/07/25		98	%	80 - 120
	Spiked Blank	. Lead (Pb)	2008/07/25		102	%	85 - 115
	Method Blank	. Lead (Pb)	2008/07/25	ND, RDL=0.5		ug/L	
	RPD	. Lead (Pb)	2008/07/25	NC		%	25

ND = Not detected
 NC = Non-calculable
 RPD = Relative Percent Difference
 SPIKE = Fortified sample

Validation Signature Page

Maxxam Job #: A877964

The analytical data and all QC contained in this report were reviewed and validated by the following individual(s).

Cristina Nervo

CHRISTINA NERVO, Scientific Services

=====

Maxxam has procedures in place to guard against improper use of the electronic signature and have the required "signatories", as per section 5.10.2 of ISO/IEC 17025:2005(E), signing the reports. SCC and CAEAL have approved this reporting process and electronic report format.



6740 Campobello Rd
Mississauga
Ontario L5N 2L8

REGULATION 243 DRINKING WATER
CHAIN OF CUSTODY RECORD

Tel: 905-817-5700
Fax: 905-817-5779
Toll Free: 1-800-563-6266

17-Jul-08 14:56

JAMES ASPIN



A877964

FW

ENV-756

Maxxam Analytics Inc.
CAM FCD-00196/2

Samples are Required
Under Reg 243

Report to:

Company Name: Dufferin-Peel Catholic District School Board
Client Contact: Roland Lawton, General Manager of Physical Plant Facilities
Address: 5685 Keaton Cres., Mississauga ON L5R 3H5
E-Mail: roland.lawton@dpcdsb.org Tel: 905-890-0708 ext. 23204
Project: Regulation 243 Fax: 905-890-5841
Quote #: A83456 P.O.#: BN500636
Lab Service Rep.: James Aspin

Invoice to: Same as "Report to"

**DW METALS
PRESERVATION
CHECKED**

PAGE _____ OF _____

ANALYSIS REQUESTED

Specify School Type

School	Private School	Day nursery	M.O.E. Assigned Water System Number
<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	

500018864

Sample Identification	Sample Type (Please Specify Standing / Flushed)	Date Sampled	Time Sampled	Sampler Initials	Field Chlorine		No. of Bottles	Lead	Specify School Type			
					Total	Free			School	Private School	Day nursery	
St. Jerome												
Kitchen - Staffroom	Standing	July 17 2008	6:15 am	MS			1	X	X			
Kitchen - Staffroom	Flushed	July 17 2008	6:50 am	MS			1	X	X			

SIF : Sample Inspection
Resolved By: _____
Date: _____

In accordance with the Safe Drinking Water Act (2002), notification of adverse results must be reported to the Ministry of the Environment. Failure to do so is an offence under the act. It is **IMPERATIVE** that the areas shaded in grey be filled in.

TAT (Turnaround Time)	Notification Information for School, Private Schools & Day Nurseries	LABORATORY USE ONLY
RUSH TAT MUST HAVE PRIOR APPROVAL	Facility Name: St. Jerome Facility Address: 790 Paisley Blvd. West Mississauga, ON L5C 3P5	Received By: <i>Zofia Zerkova</i> Date: <i>08/07/08</i> Time: <i>14:56</i> Comments: <i>10/10/10</i>
<input checked="" type="checkbox"/> Normal (5-15 Working Days)		
<input type="checkbox"/> RUSH (Specify Below)		
Date Due:	Tel: 905-273-3836 Fax: 905-273-9539	
PN #	E-mail:	
Relinquished by (Sign Name): <i>L. Chatoff</i>	Date: <i>July 17/08</i>	Laboratory Prepared Container:
Relinquished by (Print Name): <i>Lydia Chatoff</i>	Time: <i>2:55 pm</i>	<input type="checkbox"/> Yes <input type="checkbox"/> No

NOTE: Samples submitted to Maxxam Analytics must be received below 10°C.

It is the Sampler's responsibility to ensure adequate cooling is provided so that this temperature is met.

Please ensure that a separate COC document is used for each individual sample.

08 JUL 17 14:56
12/12/10