

Your P.O. #: BN500116  
Your Project #: ST. KEVIN  
Site:500012143  
Your C.O.C. #: NA

**Attention: Roland Lawton**  
Dufferin Peel Catholic District...  
School Board  
40 Matheson Blvd W  
Mississauga, ON  
L5R 1C5

**Report Date: 2008/09/09**

**CERTIFICATE OF ANALYSIS**

**MAXXAM JOB #: A8A0484**  
**Received: 2008/09/05, 13:32**

Sample Matrix: Water  
# Samples Received: 2

Analyses	Quantity	Date Extracted	Date Analyzed	Laboratory Method	Method Reference
Metals Analysis by ICPMS (as received) 0	2	2008/09/08	2008/09/08	CAM SOP-00447	EPA 6020

\* RPDs calculated using raw data. The rounding of final results may result in the apparent difference.

(1) Metals analysis was performed on the sample 'as received'.

**Encryption Key**

Please direct all questions regarding this Certificate of Analysis to your Project Manager.

JAMES ASPIN, Project Manager  
Email: James.Aspin@maxxamAnalytics.com  
Phone# (905) 817-5700 Ext:5771

=====  
Maxxam has procedures in place to guard against improper use of the electronic signature and have the required "signatories", as per section 5.10.2 of ISO/IEC 17025:2005(E), signing the reports. SCC and CAEAL have approved this reporting process and electronic report format.

For Service Group specific validation please refer to the Validation Signature Page

Total cover pages: 1

Maxxam Job #: A8A0484  
 Report Date: 2008/09/09

Dufferin Peel Catholic District...  
 Client Project #: ST. KEVIN  
 Project name: 500012143  
 Your P.O. #: BN500116

**ELEMENTS BY ATOMIC SPECTROSCOPY (WATER)**

Maxxam ID			AK1100	AK1101		
Sampling Date			2008/09/05 06:00	2008/09/05 06:35		
COC Number			NA	NA		
	<b>Units</b>	<b>Criteria</b>	<b>ST KEVIN STANDING</b>	<b>ST KEVIN FLUSHED</b>	<b>RDL</b>	<b>QC Batch</b>

<b>Metals</b>						
Lead (Pb)	mg/L	<b>0.01</b>	0.0021	0.0015	0.0005	1606912

RDL = Reportable Detection Limit  
 QC Batch = Quality Control Batch  
 CRITERIA: Ontario Regulation 243/07 made under the Safe Drinking Water Act, 2002.  
 Released June 7, 2007

Maxxam Job #: A8A0484  
Report Date: 2008/09/09

Dufferin Peel Catholic District...  
Client Project #: ST. KEVIN  
Project name: 500012143  
Your P.O. #: BN500116

Package 1	13.0°C
-----------	--------

Each temperature is the average of up to three cooler temperatures taken at receipt

**GENERAL COMMENTS**

**Results relate only to the items tested.**

Dufferin Peel Catholic District...  
 Attention: Roland Lawton  
 Client Project #: ST. KEVIN  
 P.O. #: BN500116  
 Project name: 500012143

Quality Assurance Report  
 Maxxam Job Number: MA8A0484

QA/QC Batch	QC Type	Parameter	Date Analyzed yyyy/mm/dd	Value	Recovery	Units	QC Limits
1606912 JBW	MATRIX SPIKE	. Lead (Pb)	2008/09/08		101	%	80 - 120
	Spiked Blank	. Lead (Pb)	2008/09/08		97	%	85 - 115
	Method Blank	. Lead (Pb)	2008/09/08	ND, RDL=0.0005		mg/L	
	RPD	. Lead (Pb)	2008/09/08	1.5 (1)		%	25

ND = Not detected  
 RPD = Relative Percent Difference  
 SPIKE = Fortified sample  
 ( 1 ) POTENTIAL EXCEEDENCE FOR PARAMETER

## Validation Signature Page

**Maxxam Job #: A8A0484**

---

The analytical data and all QC contained in this report were reviewed and validated by the following individual(s).



---

TROY CARRIERE, B.Sc., C.Chem, Scientific Specialist

=====

Maxxam has procedures in place to guard against improper use of the electronic signature and have the required "signatories", as per section 5.10.2 of ISO/IEC 17025:2005(E), signing the reports. SCC and CAEAL have approved this reporting process and electronic report format.



6740 Campobello Rd  
Mississauga  
Ontario L5N 2L8

# REGULATION 243 DRINKING WATER SUBMISSION CHAIN OF CUSTODY RECORD

Tel: 905-817-5700  
Fax: 905-817-5779  
Toll Free: 1-800-563-6266

Samples are Regulated  
Under Reg 243

5-Sep-08 13:32  
JAMES ASPIN  
 A8A0484  
M\_O ENV-664

**Report to:**

Company Name: Dufferin-Peel Catholic District School Board  
Client Contact: Roland Lawton, General Manager of Physical Plant Facilities  
Address: 5685 Keaton Cres., Mississauga ON L5R 3H5  
E-Mail: [roland.lawton@dpcdsb.org](mailto:roland.lawton@dpcdsb.org) Tel: 905-890-0708 ext. 23204  
Project: Regulation 243 Fax: 905-890-5841  
Quote #: A83456 P.O.#: BN500636  
Lab Service Rep.: James Aspin

Invoice to:  Same as "Report to"

PAGE \_\_\_\_ OF \_\_\_\_

**ANALYSIS REQUESTED**

Specify School Type

M.O.E. Assigned Water System Number

500012143

'08 SEP 5 13:32

Sample Identification	Sample Type (Please Specify Standing / Flushed)	Date Sampled	Time Sampled	Sampler Initials	Field Chlorine		No. of Bottles	Lead	School	Private School	Day nursery	M.O.E. Assigned Water System Number
					Total	Free						
<b>St. Kevin</b>												
Kitchen - Staffroom	Standing	Sept 5 08	6 AM				1	X	X			
Kitchen - Staffroom	Flushed	Sept 5 08	6:35 AM				1	X	X			

\* In accordance with the Safe Drinking Water Act (2002), notification of adverse results must be reported to the SAC, MOH & Waterworks. Failure to do so is an offence under the act. It is **IMPERATIVE** that the areas shaded in grey be filled out completely before submitting to Maxxam Analytics.

TAT (Turnaround Time)	Notification Information for School, Private Schools & Day Nurseries		LABORATORY USE ONLY
<b>RUSH TAT MUST HAVE PRIOR APPROVAL</b>	Facility Name: St. Kevin	Medical Officer of Health	Received By: <i>[Signature]</i>
<input checked="" type="checkbox"/> Normal (5-15 Working Days)	Facility Address: 103 Malta Avenue	Region: Peel Region	Date: 08/09/08 Time: 13:32
<input type="checkbox"/> RUSH (Specify Below)	Brampton, ON L6Y 4C8	Tel #:	Comments: 13/13/130
Date Due:	Tel: 905-450-0571 Fax: 905-450-1113	Fax #:	
PN #	E-mail:	Email:	
Relinquished by (Sign Name):	Date:	Laboratory Prepared Container:	
Relinquished by (Print Name):	Time:		

**NOTE:** Samples must be kept below 10°C. It is the Sampler's responsibility to ensure this receiving temperature is maintained for each individual sample.

**SIF** : Sample Inspection Resolved  By: Page 6 of 6

BYE MATT  
PRESERVATION  
CITATION