

Your P.O. #: BN500116
Your Project #: ST MARGARET OF SCOTLAND
Site:500019514
Your C.O.C. #: na

Attention: Roland Lawton
Dufferin Peel Catholic District...
School Board
40 Matheson Blvd W
Mississauga, ON
L5R 1C5

Report Date: 2008/07/28

CERTIFICATE OF ANALYSIS

MAXXAM JOB #: A878370
Received: 2008/07/17, 14:04

Sample Matrix: Water
Samples Received: 2

Analyses	Quantity	Date Extracted	Date Analyzed	Laboratory Method	Method Reference
Metals Analysis by ICPMS (as received) 0	2	2008/07/25	2008/07/26	CAM SOP-00447	EPA 6020

* RPDs calculated using raw data. The rounding of final results may result in the apparent difference.

(1) Metals analysis was performed on the sample 'as received'.

Encryption Key

Please direct all questions regarding this Certificate of Analysis to your Project Manager.

JAMES ASPIN, Project Manager
Email: James.Aspin@maxxamAnalytics.com
Phone# (905) 817-5700 Ext:5771

=====
Maxxam has procedures in place to guard against improper use of the electronic signature and have the required "signatories", as per section 5.10.2 of ISO/IEC 17025:2005(E), signing the reports. SCC and CAEAL have approved this reporting process and electronic report format.

For Service Group specific validation please refer to the Validation Signature Page

Total cover pages: 1

Maxxam Job #: A878370
Report Date: 2008/07/28

Dufferin Peel Catholic District...
Client Project #: ST MARGARET OF SCOTLAND
Project name: 500019514
Your P.O. #: BN500116

ELEMENTS BY ATOMIC SPECTROSCOPY (WATER)

Maxxam ID			Z96823		
Sampling Date			2008/07/17 06:35		
COC Number			na		
	Units	Criteria	ST. MARGARET OF SCOTLAND-KITCHEN-STAFFROOM- STANDING	RDL	QC Batch

Metals					
. Lead (Pb)	mg/L	0.01	0.0055	0.0005	1570632
<p>RDL = Reportable Detection Limit QC Batch = Quality Control Batch CRITERIA: Ontario Regulation 243/07 made under the Safe Drinking Water Act, 2002. Released June 7, 2007</p>					

Maxxam ID			Z96824		
Sampling Date			2008/07/17 07:35		
COC Number			na		
	Units	Criteria	ST. MARGARET OF SCOTLAND-KITCHEN-STAFFROOM- FLUSHED	RDL	QC Batch

Metals					
. Lead (Pb)	mg/L	0.01	0.0022	0.0005	1570632
<p>RDL = Reportable Detection Limit QC Batch = Quality Control Batch CRITERIA: Ontario Regulation 243/07 made under the Safe Drinking Water Act, 2002. Released June 7, 2007</p>					

Maxxam Job #: A878370
Report Date: 2008/07/28

Dufferin Peel Catholic District...
Client Project #: ST MARGARET OF SCOTLAND
Project name: 500019514
Your P.O. #: BN500116

Package 1	10.0°C
-----------	--------

Each temperature is the average of up to three cooler temperatures taken at receipt

GENERAL COMMENTS

Results relate only to the items tested.

Dufferin Peel Catholic District...
Attention: Roland Lawton
Client Project #: ST MARGARET OF SCOTLAND
P.O. #: BN500116
Project name: 500019514

Quality Assurance Report
Maxxam Job Number: MA878370

QA/QC Batch			Date Analyzed				QC Limits
Num Init	QC Type	Parameter	yyyy/mm/dd	Value	Recovery	Units	
1570632 JBW	MATRIX SPIKE	. Lead (Pb)	2008/07/26		112	%	80 - 120
	Spiked Blank	. Lead (Pb)	2008/07/26		99	%	85 - 115
	Method Blank	. Lead (Pb)	2008/07/26	ND, RDL=0.5		ug/L	
	RPD	. Lead (Pb)	2008/07/26	1.2		%	25

ND = Not detected
RPD = Relative Percent Difference
SPIKE = Fortified sample

Validation Signature Page

Maxxam Job #: A878370

The analytical data and all QC contained in this report were reviewed and validated by the following individual(s).

Cristina Nervo

CHRISTINA NERVO, Scientific Services

=====

Maxxam has procedures in place to guard against improper use of the electronic signature and have the required "signatories", as per section 5.10.2 of ISO/IEC 17025:2005(E), signing the reports. SCC and CAEAL have approved this reporting process and electronic report format.



6740 Campobello Rd
Mississauga
Ontario L5N 2L8

REGULATION 243 DRINKING WATER SUBM CHAIN OF CUSTODY RECORD

Tel: 905-817-5700
Fax: 905-817-5779
Toll Free: 1-800-563-6266

Samples are Regulated
Under Reg 243

17-Jul-08 14:04
JAMES ASPIN
A878370
CCO ENV-832
CAM FCD-00196/2

Report to:

Company Name: Dufferin-Peel Catholic District School Board
 Contact: Roland Lawton, General Manager of Physical Plant Facilities
 Address: 5685 Keaton Cres., Mississauga ON L5R 3H5
 Mail: roland.lawton@dpcdsb.org Tel: 905-890-0708 ext. 23204
 Subject: Regulation 243 Fax: 905-890-5841
 Note #: A83456 P.O.#: BN500636
 Service Rep.: James Aspen

Invoice to: Same as "Report to"

ANALYSIS REQUESTED	
Specify School Type	M.O.E. Assigned Water System Number
School	
Private School	
Day nursery	
	500019514

Sample Identification	Sample Type (Please Specify Standing / Flushed)	Date Sampled	Time Sampled	Sampler Initials	Field Chlorine		No. of Bottles	Lead	School Type			
					Total	Free			School	Private School	Day nursery	
St. Margaret of Scotland Kitchen - Staffroom	Standing	5/17	6:35				1	X	X			
Kitchen - Staffroom	Flushed	5/17	7:35				1	X	X			

In accordance with the Safe Drinking Water Act (2002), notification of adverse results must be reported to the SAC, MOH & Waterworks. Failure to do so is an offence under the act. It is **IMPERATIVE** that the areas shaded in grey be filled out completely before submitting to Maxxam Analytics.

TAT (Turnaround Time)	Notification Information for School, Private Schools & Day Nurseries		LABORATORY USE ONLY
RUSH TAT MUST HAVE PRIOR APPROVAL	Facility Name: St. Margaret of Scotland	Medical Officer of Health	Received By: <i>J. J. [Signature]</i>
<input type="checkbox"/> Normal (5-15 Working Days)	Facility Address: 2266 Council Ring Road	Region: Peel Region	Date: 08/07/08 Time: 12:04
<input type="checkbox"/> RUSH (Specify Below)	Mississauga, ON L5L 1C1	Tel #:	Comments: 10/10/10
Site Due:	Tel: 905-820-5115 Fax: 905-820-9272	Fax #:	
Order #:	E-mail:	Email:	

Relinquished by (Sign Name): *[Signature]* Date: 17 Jul 08
 Relinquished by (Print Name): BRZEZINSKI WALDEMAR Time: 7:10AM
 Laboratory Prepared Container: Yes No

NOTE: Samples submitted to Maxxam
It is the Sampler's responsibility to ensure adequate cool
Please ensure that a separate CO

SIF : Sample Inspection

Resolved By: Page 6 of 6

DRINKING WATER METALS
PRESERVATION
CHECKED