

Your P.O. #: BN500116
Your Project #: ST.NICHOLAS
Site:500012741
Your C.O.C. #: NA

Attention: Roland Lawton
Dufferin Peel Catholic District...
School Board
40 Matheson Blvd W
Mississauga, ON
L5R 1C5

Report Date: 2008/10/01

CERTIFICATE OF ANALYSIS

MAXXAM JOB #: A8B1767
Received: 2008/09/29, 09:06

Sample Matrix: Water
Samples Received: 2

Analyses	Quantity	Date Extracted	Date Analyzed	Laboratory Method	Method Reference
Metals Analysis by ICPMS (as received) 0	2	2008/10/01	2008/10/01	CAM SOP-00447	EPA 6020

* RPDs calculated using raw data. The rounding of final results may result in the apparent difference.

(1) Metals analysis was performed on the sample 'as received'.

Encryption Key

Please direct all questions regarding this Certificate of Analysis to your Project Manager.

JAMES ASPIN, Project Manager
Email: James.Aspin@maxxamAnalytics.com
Phone# (905) 817-5700 Ext:5771

=====
Maxxam has procedures in place to guard against improper use of the electronic signature and have the required "signatories", as per section 5.10.2 of ISO/IEC 17025:2005(E), signing the reports. SCC and CAEAL have approved this reporting process and electronic report format.

For Service Group specific validation please refer to the Validation Signature Page

Total cover pages: 1

Maxxam Job #: A8B1767
 Report Date: 2008/10/01

Dufferin Peel Catholic District...
 Client Project #: ST.NICHOLAS
 Project name: 500012741
 Your P.O. #: BN500116

ELEMENTS BY ATOMIC SPECTROSCOPY (WATER)

Maxxam ID			AP8535	AP8536		
Sampling Date			2008/09/29 06:40	2008/09/29 07:17		
COC Number			NA	NA		
	Units	Criteria	KITCHEN-STAFFROOM STANDING	KITCHEN-STAFFROOM FLUSHED	RDL	QC Batch

Metals						
Lead (Pb)	mg/L	0.01	0.0006	ND	0.0005	1630295

ND = Not detected
 RDL = Reportable Detection Limit
 QC Batch = Quality Control Batch
 CRITERIA: Ontario Regulation 243/07 made under the Safe Drinking Water Act, 2002.
 Released June 7, 2007

Maxxam Job #: A8B1767
Report Date: 2008/10/01

Dufferin Peel Catholic District...
Client Project #: ST.NICHOLAS
Project name: 500012741
Your P.O. #: BN500116

GENERAL COMMENTS

Results relate only to the items tested.

Dufferin Peel Catholic District...
 Attention: Roland Lawton
 Client Project #: ST.NICHOLAS
 P.O. #: BN500116
 Project name: 500012741

Quality Assurance Report
 Maxxam Job Number: MA8B1767

QA/QC Batch	QC Type	Parameter	Date Analyzed yyyy/mm/dd	Value	Recovery	Units	QC Limits
1630295 JBW	MATRIX SPIKE	. Lead (Pb)	2008/10/01		104	%	80 - 120
	Spiked Blank	. Lead (Pb)	2008/10/01		99	%	85 - 115
	Method Blank	. Lead (Pb)	2008/10/01	ND, RDL=0.0005		mg/L	
	RPD	. Lead (Pb)	2008/10/01	NC		%	25

ND = Not detected
 NC = Non-calculable
 RPD = Relative Percent Difference
 SPIKE = Fortified sample

Validation Signature Page

Maxxam Job #: A8B1767

The analytical data and all QC contained in this report were reviewed and validated by the following individual(s).

Cristina Nervo

CHRISTINA NERVO, Scientific Services

=====

Maxxam has procedures in place to guard against improper use of the electronic signature and have the required "signatories", as per section 5.10.2 of ISO/IEC 17025:2005(E), signing the reports. SCC and CAEAL have approved this reporting process and electronic report format.

6740 Campobello Rd
Mississauga
Ontario L5N 2L8

29-Sep-08 09:06
JAMES ASPIN
A8B1767

NNA ENV-687

Toll Free: 1-800-563-6266

**DW METALS
PRESERVATION
CHECKED**

**Samples are Regulated
Under Reg 243**

Maxxam Analytics Inc.
CAM FCD-00196/2

Report to:

Company Name: Dufferin-Peel Catholic District School Board
Client Contact: Roland Lawton, General Manager of Physical Plant Facilities
Address: 5685 Keaton Cres., Mississauga ON L5R 3H5
-Mail: roland.lawton@dpcdsb.org Tel: 905-890-0708 ext. 23204
Project: Regulation 243 Fax: 905-890-5841
Quote #: A83456 P.O.#: BN500636
Lab Service Rep.: James Aspin

Invoice to: Same as "Report to"

PAGE ____ OF ____

ANALYSIS REQUESTED

Specify School Type

M.O.E. Assigned Water System Number

500012741

08 SEP 29 9:06

Sample Identification	Sample Type (Please Specify Standing / Flushed)	Date Sampled	Time Sampled	Sampler Initials	Field Chlorine		No. of Bottles	Lead	School	Private School	Day nursery
					Total	Free					
St. Nicholas Kitchen - Staffroom	Standing	Sept 29/08	6:40 AM				1	X	X		
Kitchen - Staffroom	Flushed	Sept 29/08	7:17				1	X	X		

In accordance with the Safe Drinking Water Act (2002), notification of adverse results must be reported to the SAC, MOH & Waterworks. Failure to do so, is an offence under the act. It is **IMPERATIVE** that the areas shaded in grey be filled out completely before submitting to Maxxam Analytics.

TAT (Turnaround Time)	Notification Information for School, Private Schools & Day Nurseries	LABORATORY USE ONLY
RUSH TAT MUST HAVE PRIOR APPROVAL	Facility Name: St. Nicholas Facility Address: 120 Harvest Moon Drive Bolton, ON L7E 2W1	Received By: <i>Nayla Mikhael</i> Date: 08/09/09 Time: 9:06 Comments:
<input checked="" type="checkbox"/> Normal (5-15 Working Days)		16/16/16°C no i/c
<input type="checkbox"/> RUSH (Specify Below)		
Rate Due:	Tel: 1-905-857-7582 Fax: 1-905-857-9353	
SN #	E-mail:	

Relinquished by (Sign Name): *Terry Groves* Date: *Sept 29/08*
Relinquished by (Print Name): **TERRY GROVES** Time: *7:18 AM*
Laboratory Prepared Container: Yes No

NOTE: Sample received below 10°C. It is the Sampler's responsibility that this receiving temperature is met. Please ensure that this receiving temperature is met. Resolved By: _____ Date: _____