

Your P.O. #: BN500636
Your Project #: ST PIO OF PIETRECINA
Site:500019267
Your C.O.C. #: NA

Attention: Roland Lawton
Dufferin Peel Catholic District...
School Board
40 Matheson Blvd W
Mississauga, ON
L5R 1C5

Report Date: 2008/07/25

CERTIFICATE OF ANALYSIS

MAXXAM JOB #: A878002
Received: 2008/07/17, 13:25

Sample Matrix: Water
Samples Received: 2

| Analyses | Quantity | Date Extracted | Date Analyzed | Laboratory Method | Method Reference |
|--|----------|-------------------|------------------|-------------------|---------------------|
| Metals Analysis by ICPMS (as received) 0 | 2 | 2008/07/24 | 2008/07/24 | CAM SOP-00447 | EPA 6020 |

* RPDs calculated using raw data. The rounding of final results may result in the apparent difference.

(1) Metals analysis was performed on the sample 'as received'.

Encryption Key

Please direct all questions regarding this Certificate of Analysis to your Project Manager.

JAMES ASPIN, Project Manager
Email: James.Aspin@maxxamAnalytics.com
Phone# (905) 817-5700 Ext:5771

=====
Maxxam has procedures in place to guard against improper use of the electronic signature and have the required "signatories", as per section 5.10.2 of ISO/IEC 17025:2005(E), signing the reports. SCC and CAEAL have approved this reporting process and electronic report format.

For Service Group specific validation please refer to the Validation Signature Page

Total cover pages: 1

Maxxam Job #: A878002
Report Date: 2008/07/25

Dufferin Peel Catholic District...
Client Project #: ST PIO OF PIETRECINA
Project name: 500019267
Your P.O. #: BN500636

ELEMENTS BY ATOMIC SPECTROSCOPY (WATER)

| | | | | | | |
|---------------|--------------|-----------------|--|---|------------|-----------------|
| Maxxam ID | | | Z95528 | Z95529 | | |
| Sampling Date | | | 2008/07/15 07:00 | 2008/07/15 08:45 | | |
| COC Number | | | NA | NA | | |
| | Units | Criteria | ST. PIO OF PIETRELCINA KITCHEN-STAFFROOM/STANDING | ST. PIO OF PIETRELCINA KITCHEN-STAFFROOM/FLUSHED | RDL | QC Batch |

| | | | | | | |
|---------------|------|-------------|----|----|--------|---------|
| Metals | | | | | | |
| Lead (Pb) | mg/L | 0.01 | ND | ND | 0.0005 | 1569253 |

ND = Not detected
RDL = Reportable Detection Limit
QC Batch = Quality Control Batch
CRITERIA: Ontario Regulation 243/07 made under the Safe Drinking Water Act, 2002.

Released June 7, 2007

Maxxam Job #: A878002
Report Date: 2008/07/25

Dufferin Peel Catholic District...
Client Project #: ST PIO OF PIETRECINA
Project name: 500019267
Your P.O. #: BN500636

| | |
|-----------|--------|
| Package 1 | 13.7°C |
|-----------|--------|

Each temperature is the average of up to three cooler temperatures taken at receipt

GENERAL COMMENTS

Results relate only to the items tested.

Dufferin Peel Catholic District...
Attention: Roland Lawton
Client Project #: ST PIO OF PIETRECINA
P.O. #: BN500636
Project name: 500019267

Quality Assurance Report
Maxxam Job Number: MA878002

| QA/QC Batch | QC Type | Parameter | Date Analyzed yyyy/mm/dd | Value | Recovery | Units | QC Limits |
|-------------|--------------|-------------|-----------------------------|-------------|----------|-------|-----------|
| 1569253 JBW | MATRIX SPIKE | . Lead (Pb) | 2008/07/24 | | 106 | % | 80 - 120 |
| | Spiked Blank | . Lead (Pb) | 2008/07/24 | | 99 | % | 85 - 115 |
| | Method Blank | . Lead (Pb) | 2008/07/24 | ND, RDL=0.5 | | ug/L | |
| | RPD | . Lead (Pb) | 2008/07/24 | NC | | % | 25 |

ND = Not detected
NC = Non-calculable
RPD = Relative Percent Difference
SPIKE = Fortified sample

Validation Signature Page

Maxxam Job #: A878002

The analytical data and all QC contained in this report were reviewed and validated by the following individual(s).



TROY CARRIERE, B.Sc., C.Chem, Scientific Specialist

=====

Maxxam has procedures in place to guard against improper use of the electronic signature and have the required "signatories", as per section 5.10.2 of ISO/IEC 17025:2005(E), signing the reports. SCC and CAEAL have approved this reporting process and electronic report format.



6740 Campobello Rd
Mississauga
Ontario L5N 2L8

REGULATION 243 DRINKING WATER SUBSISTANCE CHAIN OF CUSTODY RECORD

Tel: 905-817-5700
Fax: 905-817-5779
Toll Free: 1-800-563-6266

Samples are Regulated
Under Reg 243

17-Jul-08 13:25
JAMES ASPIN
A878002
FW ENV-464
CAM FCD-00196/2

Report to:

Company Name: Dufferin-Peel Catholic District School Board
Client Contact: Roland Lawton, General Manager of Physical Plant Facilities
Address: 5685 Keaton Cres., Mississauga ON L5R 3H5
E-Mail: roland.lawton@dpcdsb.org Tel: 905-890-0708 ext. 23204
Project: Regulation 243 Fax: 905-890-5841
Quote #: A83456 P.O.#: BN500636
Lab Service Rep.: James Aspin

Invoice to: Same as "Report to"

**DW METALS
PRESERVATION
CHECKED**

| ANALYSIS REQUESTED | | | | | | | |
|---|-------------------------------------|--------------------------|-------------|-------------------------------------|--------------------------|--------------------------|-----------|
| Specify School Type | M.O.E. Assigned Water System Number | | | | | | |
| <table border="1"> <tr> <th>School</th> <th>Private School</th> <th>Day nursery</th> </tr> <tr> <td><input checked="" type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input type="checkbox"/></td> </tr> </table> | School | Private School | Day nursery | <input checked="" type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> | 500019267 |
| School | Private School | Day nursery | | | | | |
| <input checked="" type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> | | | | | |

| Sample Identification | Sample Type (Please Specify Standing / Flushed) | Date Sampled | Time Sampled | Sampler Initials | Field Chlorine | | No. of Bottles | Lead |
|---|---|--------------|--------------|------------------|----------------|------|----------------|------|
| | | | | | Total | Free | | |
| St. Pio of Pietrelcina Kitchen - Staffroom | Standing | July 15 | 7:00 AM | RB | | | 1 | X |
| Kitchen - Staffroom | Flushed | July 15 | 8:45 AM | RB | | | 1 | X |

SIF: Sample Inspection
Resolved By: _____
Date: _____

In accordance with the Safe Drinking Water Act (2002), notification of adverse works.
Failure to do so is an offence under the act. It is IMPERATIVE that the areas s... itting to Maxxam Analytics.

| TAT (Turnaround Time) | Notification Information for School, Private Schools & Day Nurseries | LABORATORY USE ONLY |
|--|--|---|
| RUSH TAT MUST HAVE PRIOR APPROVAL | Facility Name: St. Pio of Pietrelcina Facility Address: 4765 Huron Heights Drive Mississauga, ON L4Z 4G9 | Received By: <i>M. Jones</i> Date: 08/07/17 Time: 13:25 Comments: 12/14/15 |
| <input checked="" type="checkbox"/> Normal (5-15 Working Days) | Tel #: _____ Fax #: _____ | 08 JUL 17 13:25 |
| <input type="checkbox"/> RUSH (Specify Below) | E-mail: _____ | |
| Rate Due: | | |
| Lab # | | |
| Relinquished by (Sign Name): <i>R.B.</i> | Date: July 15/2008 | Laboratory Prepared Container: <input type="checkbox"/> Yes <input type="checkbox"/> No |
| Relinquished by (Print Name): ROBERT BOEM | Time: _____ | |

NOTE: Samples submitted to Maxxam Analytics must be received below 10°C.
It is the Sampler's responsibility to ensure adequate cooling is provided so that this receiving temperature is met.
Please ensure that a separate COC document is used for each indiv