

Your P.O. #: BN500116
Your Project #: ST. RAYMOND
Site:500018760
Your C.O.C. #: N/A

Attention: Roland Lawton
Dufferin Peel Catholic District...
School Board
40 Matheson Blvd W
Mississauga, ON
L5R 1C5

Report Date: 2008/08/29

CERTIFICATE OF ANALYSIS

MAXXAM JOB #: A885355
Received: 2008/08/01, 13:17

Sample Matrix: Water
Samples Received: 2

Analyses	Quantity	Date Extracted	Date Analyzed	Laboratory Method	Method Reference
Metals Analysis by ICPMS (as received) ¶	2	2008/08/28	2008/08/28	CAM SOP-00447	EPA 6020

* RPDs calculated using raw data. The rounding of final results may result in the apparent difference.

(1) Metals analysis was performed on the sample 'as received'.

Encryption Key

Please direct all questions regarding this Certificate of Analysis to your Project Manager.

JAMES ASPIN, Project Manager
Email: James.Aspin@maxxamAnalytics.com
Phone# (905) 817-5700 Ext:5771

=====
Maxxam has procedures in place to guard against improper use of the electronic signature and have the required "signatories", as per section 5.10.2 of ISO/IEC 17025:2005(E), signing the reports. SCC and CAEAL have approved this reporting process and electronic report format.

For Service Group specific validation please refer to the Validation Signature Page

Total cover pages: 1

Maxxam Job #: A885355
Report Date: 2008/08/29

Dufferin Peel Catholic District...
Client Project #: ST. RAYMOND
Project name: 500018760
Your P.O. #: BN500116

ELEMENTS BY ATOMIC SPECTROSCOPY (WATER)

Maxxam ID			AC8424	AC8425		
Sampling Date			2008/07/31 07:00	2008/07/31 07:35		
COC Number			N/A	N/A		
	Units	Criteria	ST.	ST.	RDL	QC Batch
			RAYMOND-STANDING 2008/07/31 7:00AM	RAYMOND-FLUSHED 2008/07/31 7:35AM		

Metals						
. Lead (Pb)	mg/L	0.01	0.0022	ND	0.0005	1598857
<p>ND = Not detected N/A = Not Applicable RDL = Reportable Detection Limit QC Batch = Quality Control Batch CRITERIA: Ontario Regulation 243/07 made under the Safe Drinking Water Act, 2002. Released June 7, 2007</p>						

Maxxam Job #: A885355
Report Date: 2008/08/29

Dufferin Peel Catholic District...
Client Project #: ST. RAYMOND
Project name: 500018760
Your P.O. #: BN500116

Package 1	8.7°C
-----------	-------

Each temperature is the average of up to three cooler temperatures taken at receipt

GENERAL COMMENTS

Results relate only to the items tested.

Dufferin Peel Catholic District...
Attention: Roland Lawton
Client Project #: ST. RAYMOND
P.O. #: BN500116
Project name: 500018760

Quality Assurance Report
Maxxam Job Number: MA885355

QA/QC Batch	QC Type	Parameter	Date Analyzed yyyy/mm/dd	Value	Recovery	Units	QC Limits
1598857 HRE	MATRIX SPIKE	. Lead (Pb)	2008/08/28		102	%	80 - 120
	Spiked Blank	. Lead (Pb)	2008/08/28		99	%	85 - 115
	Method Blank	. Lead (Pb)	2008/08/28	ND, RDL=0.0005		mg/L	
	RPD	. Lead (Pb)	2008/08/28	NC		%	25

ND = Not detected
NC = Non-calculable
RPD = Relative Percent Difference
SPIKE = Fortified sample

Validation Signature Page

Maxxam Job #: A885355

The analytical data and all QC contained in this report were reviewed and validated by the following individual(s).



TROY CARRIERE, B.Sc., C.Chem, Scientific Specialist

Maxxam has procedures in place to guard against improper use of the electronic signature and have the required "signatories", as per section 5.10.2 of ISO/IEC 17025:2005(E), signing the reports. SCC and CAEAL have approved this reporting process and electronic report format.

NO COC

1-Aug-08 13:17
JAMES ASPIN
A885355
MAF ENV-694

St. Raymond - Standing 2008/07/31 7:00AM
St. Raymond - Flushed 2008/07/31 7:35AM

DW METALS
PRESERVATION
CHECKED

SIF : Sample Inspection
Resolved By: _____
Date: _____

MARK FEATHER
2008/08/1 13:17
8/8/08