

Your P.O. #: BN500116
Your Project #: ST. SOFIA
Site:500019215
Your C.O.C. #: na

Attention: Roland Lawton
Dufferin Peel Catholic District...
School Board
40 Matheson Blvd W
Mississauga, ON
L5R 1C5

Report Date: 2008/09/03

CERTIFICATE OF ANALYSIS

MAXXAM JOB #: A894561
Received: 2008/08/22, 12:35

Sample Matrix: Water
Samples Received: 2

Analyses	Quantity	Date Extracted	Date Analyzed	Laboratory Method	Method Reference
Metals Analysis by ICPMS (as received) ①	1	2008/09/02	2008/09/02	CAM SOP-00447	EPA 6020
Metals Analysis by ICPMS (as received) ①	1	2008/09/02	2008/09/03	CAM SOP-00447	EPA 6020

* RPDs calculated using raw data. The rounding of final results may result in the apparent difference.

(1) Metals analysis was performed on the sample 'as received'.

Encryption Key

Please direct all questions regarding this Certificate of Analysis to your Project Manager.

JAMES ASPIN, Project Manager
Email: James.Aspin@maxxamAnalytics.com
Phone# (905) 817-5700 Ext:5771

=====
Maxxam has procedures in place to guard against improper use of the electronic signature and have the required "signatories", as per section 5.10.2 of ISO/IEC 17025:2005(E), signing the reports. SCC and CAEAL have approved this reporting process and electronic report format.

For Service Group specific validation please refer to the Validation Signature Page

Total cover pages: 1

Maxxam Job #: A894561
Report Date: 2008/09/03

Dufferin Peel Catholic District...
Client Project #: ST. SOFIA
Project name: 500019215
Your P.O. #: BN500116

ELEMENTS BY ATOMIC SPECTROSCOPY (WATER)

Maxxam ID			AH1027	AH1028		
Sampling Date			2008/08/06 07:00	2008/08/06 07:35		
COC Number			na	na		
	Units	Criteria	ST. SOFIA -KITCHEN -STAFFROOM -STANDING	ST. SOFIA -KITCHEN -STAFFROOM -FLUSHED	RDL	QC Batch

Metals						
. Lead (Pb)	mg/L	0.01	0.0022	0.0009	0.0005	1601439

RDL = Reportable Detection Limit
QC Batch = Quality Control Batch
CRITERIA: Ontario Regulation 243/07 made under the Safe Drinking Water Act, 2002.
Released June 7, 2007

Maxxam Job #: A894561
Report Date: 2008/09/03

Dufferin Peel Catholic District...
Client Project #: ST. SOFIA
Project name: 500019215
Your P.O. #: BN500116

Package 1	5.0°C
-----------	-------

Each temperature is the average of up to three cooler temperatures taken at receipt

GENERAL COMMENTS

Results relate only to the items tested.

Dufferin Peel Catholic District...
Attention: Roland Lawton
Client Project #: ST. SOFIA
P.O. #: BN500116
Project name: 500019215

Quality Assurance Report
Maxxam Job Number: MA894561

QA/QC Batch	QC Type	Parameter	Date Analyzed yyyy/mm/dd	Value	Recovery	Units	QC Limits
1601439 MIL	MATRIX SPIKE	. Lead (Pb)	2008/09/02		107	%	80 - 120
	Spiked Blank	. Lead (Pb)	2008/09/02		100	%	85 - 115
	Method Blank	. Lead (Pb)	2008/09/02	ND, RDL=0.0005		mg/L	
	RPD	. Lead (Pb)	2008/09/02	NC		%	25

ND = Not detected
NC = Non-calculable
RPD = Relative Percent Difference
SPIKE = Fortified sample

Validation Signature Page

Maxxam Job #: A894561

The analytical data and all QC contained in this report were reviewed and validated by the following individual(s).

EWA PRANJIC, M.Sc., C.Chem, Scientific Specialist

=====

Maxxam has procedures in place to guard against improper use of the electronic signature and have the required "signatories", as per section 5.10.2 of ISO/IEC 17025:2005(E), signing the reports. SCC and CAEAL have approved this reporting process and electronic report format.




6740 Campobello Rd.
Mississauga
Ontario L5N 2L8

REGULATION 243 DRINKING WATER SUBM CHAIN OF CUSTODY RECORD

Tel: 905-817-5700
Fax: 905-817-5779
Toll Free: 1-800-563-6266

Samples are Regulated
Under Reg 243

22-Aug-08 12:35
JAMES ASPIN

A894561
S_A ENV-912

Report to:

Company Name:	Dufferin-Peel Catholic District School Board		
Client Contact:	Roland Lawton, General Manager of Physical Plant Facilities		
Address:	5685 Keaton Cres., Mississauga ON L5R 3H5		
E-Mail:	<u>roland.lawton@dpcdsb.org</u>	Tel:	905-890-0708 ext. 23204
Project:	Regulation 243	Fax:	905-890-5841
Quote #:	A83456	P.O.#:	BN500636
Lab Service Rep.:	James Aspen		

Invoice to: Same as "Report to"

PAGE _____ OF _____	
ANALYSIS REQUESTED	
Specify School Type	M.O.E. Assigned Water System Number
School	
Private School / Day nursery	

Sample Identification	Sample Type (Please Specify Standing / Flushed)	Date Sampled	Time Sampled	Sampler Initials	Field Chlorine		No. of Bottles	Lead	School	Private School	Day nursery	M.O.E. Assigned Water System Number
					Total	Free						
St. Sofia			7:00	A.M								500019215
Kitchen - Staffroom	Standing	AUG 6 7		A.M			1	X	X			
Kitchen - Staffroom	Flushed	AUG 6 7	7:35	A.M			1	X	X			

* In accordance with the Safe Drinking Water Act (2002), notification of adverse results must be reported to the SAC, MOH & Waterworks. Failure to do so is an offence under the act. It is **IMPERATIVE** that the areas shaded in grey be filled out completely before submitting to Maxxam Analytics.

TAT (Turnaround Time)	Notification Information for School, Private Schools & Day Nurseries	LABORATORY USE ONLY
RUSH TAT MUST HAVE PRIOR APPROVAL	Facility Name: St. Sofia Facility Address: 3540 Havenwood Drive Mississauga, ON L4X 2M9	Received By: <u>Naylaa Mikhail</u> Date: <u>08/08/22</u> Time: <u>12:35</u> Comments: <u>5/5/5°C</u>
<input checked="" type="checkbox"/> Normal (5-15 Working Days)		
<input type="checkbox"/> RUSH (Specify Below)		
Date Due:	Tel: 905-625-0823 Fax: 905-628-3124	
PN #	E-mail:	
Relinquished by (Sign Name):	Date:	Laboratory Prepared Container:
Relinquished by (Print Name):	Time:	<input type="checkbox"/> Yes <input type="checkbox"/> No

NOTE: Samples submitted to Maxxam Analytics are the property of Maxxam Analytics. It is the Sampler's responsibility to ensure adequate labeling and chain of custody. Please ensure that a separate container is used for each sample.

SIF: Sample Inspection
Resolved By: _____
Date: _____
Page 6 of 6

DW METALS
PRESERVATION
CHECKED