

Your P.O. #: BN500116  
Your Project #: ST.TERESA OF AVILA  
Site:500019540  
Your C.O.C. #: na

**Attention: Roland Lawton**  
Dufferin Peel Catholic District...  
School Board  
40 Matheson Blvd W  
Mississauga, ON  
L5R 1C5

**Report Date: 2008/09/18**

**CERTIFICATE OF ANALYSIS**

**MAXXAM JOB #: A8A4218**  
**Received: 2008/09/12, 12:29**

Sample Matrix: Water  
# Samples Received: 2

Analyses	Quantity	Date Extracted	Date Analyzed	Laboratory Method	Method Reference
Metals Analysis by ICPMS (as received) ¶	2	2008/09/17	2008/09/17	CAM SOP-00447	EPA 6020

\* RPDs calculated using raw data. The rounding of final results may result in the apparent difference.

(1) Metals analysis was performed on the sample 'as received'.

**Encryption Key**

Please direct all questions regarding this Certificate of Analysis to your Project Manager.

JAMES ASPIN, Project Manager  
Email: James.Aspin@maxxamAnalytics.com  
Phone# (905) 817-5700 Ext:5771

=====

Maxxam has procedures in place to guard against improper use of the electronic signature and have the required "signatories", as per section 5.10.2 of ISO/IEC 17025:2005(E), signing the reports. SCC and CAEAL have approved this reporting process and electronic report format.

For Service Group specific validation please refer to the Validation Signature Page

Total cover pages: 1

Maxxam Job #: A8A4218  
 Report Date: 2008/09/18

Dufferin Peel Catholic District...  
 Client Project #: ST.TERESA OF AVILA  
 Project name: 500019540  
 Your P.O. #: BN500116  
 Sampler Initials: JP

**ELEMENTS BY ATOMIC SPECTROSCOPY (WATER)**

Maxxam ID			AL9627	AL9628		
Sampling Date			2008/09/12 07:20	2008/09/12 07:55		
COC Number			na	na		
	<b>Units</b>	<b>Criteria</b>	<b>ST. TERESA OF AVILA KITCHEN-STAFFROOM STANDING</b>	<b>ST. TERESA OF AVILA KITCHEN-STAFFROOM FLUSHED</b>	<b>RDL</b>	<b>QC Batch</b>

<b>Metals</b>						
. Lead (Pb)	mg/L	<b>0.01</b>	0.0040	0.0016	0.0005	1616201

RDL = Reportable Detection Limit  
 QC Batch = Quality Control Batch  
 CRITERIA: Ontario Regulation 243/07 made under the Safe Drinking Water Act, 2002.  
 Released June 7, 2007

Maxxam Job #: A8A4218  
Report Date: 2008/09/18

Dufferin Peel Catholic District...  
Client Project #: ST.TERESA OF AVILA  
Project name: 500019540  
Your P.O. #: BN500116  
Sampler Initials: JP

Package 1	12.0°C
-----------	--------

Each temperature is the average of up to three cooler temperatures taken at receipt

**GENERAL COMMENTS**

**Results relate only to the items tested.**

Dufferin Peel Catholic District...  
 Attention: Roland Lawton  
 Client Project #: ST.TERESA OF AVILA  
 P.O. #: BN500116  
 Project name: 500019540

Quality Assurance Report  
 Maxxam Job Number: MA8A4218

QA/QC Batch	QC Type	Parameter	Date Analyzed yyyy/mm/dd	Value	Recovery	Units	QC Limits
1616201 JBW	MATRIX SPIKE	. Lead (Pb)	2008/09/17		106	%	80 - 120
	Spiked Blank	. Lead (Pb)	2008/09/17		100	%	85 - 115
	Method Blank	. Lead (Pb)	2008/09/17	ND, RDL=0.0005		mg/L	
	RPD	. Lead (Pb)	2008/09/17	NC		%	25



ND = Not detected  
 NC = Non-calculable  
 RPD = Relative Percent Difference  
 SPIKE = Fortified sample

## Validation Signature Page

**Maxxam Job #: A8A4218**

---

The analytical data and all QC contained in this report were reviewed and validated by the following individual(s).



---

TROY CARRIERE, B.Sc., C.Chem, Scientific Specialist

=====

Maxxam has procedures in place to guard against improper use of the electronic signature and have the required "signatories", as per section 5.10.2 of ISO/IEC 17025:2005(E), signing the reports. SCC and CAEAL have approved this reporting process and electronic report format.



6740 Campobello Rd  
Mississauga  
Ontario L5N 2L8

12-Sep-08 12:29

JAMES ASPIN



A8A4218

NNA ENV-987

Toll Free: 1-800-563-6266

DRINKING WATER SUBMISSION

**USTODY RECORD**

Samples are Regulated  
Under Reg 243

Maxxam Analytics Inc.  
CAM FCD-00196/2

**Report to:**

Company Name: Dufferin-Peel Catholic District School Board  
Client Contact: Roland Lawton, General Manager of Physical Plant Facilities  
Address: 5685 Keaton Cres., Mississauga ON L5R 3H5  
E-Mail: roland.lawton@dpcdsb.org Tel: 905-890-0708 ext. 23204  
Project: Regulation 243 Fax: 905-890-5841  
Quote #: A83456 P.O.#: BN500636  
Lab Service Rep.: James Aspin

Invoice to:  Same as "Report to"

PAGE \_\_\_\_ OF \_\_\_\_

ANALYSIS REQUESTED

Specify School Type	M.O.E. Assigned Water System Number
School	
Private School Day nursery	

500019540

'08 SEP 12 12:29

Sample Identification	Sample Type (Please Specify Standing / Flushed)	Date Sampled	Time Sampled	Sampler Initials	Field Chlorine		No. of Bottles	Lead	School	Private School	Day nursery
					Total	Free					
<b>St. Teresa of Avila</b>											
Kitchen - Staffroom	Standing	Sept/12/08	7:20	JGP			1	X	X		
Kitchen - Staffroom	Flushed	Sept/12/08	7:55	JGP			1	X	X		

**DW METALS PRESERVATION CHECKED**

(2002), notification of adverse results must be reported to the SAC, MOH & Waterworks. **IMPERATIVE** that the areas shaded in grey be filled out completely before submitting to Maxxam Analytics.

TAT (Turnaround Time)	Notification Information for School, Private Schools & Day Nurseries		LABORATORY USE ONLY	
<b>RUSH TAT MUST HAVE PRIOR APPROVAL</b>	Facility Name: St. Teresa of Avila	Medical Officer of Health	Received By: Naglaa Mikhail	
<input checked="" type="checkbox"/> Normal (5-15 Working Days)	Facility Address: 6675 Montevideo Road	Region: Peel Region	Date: 08/09/12	Time: 12:29
<input type="checkbox"/> RUSH (Specify Below)	Mississauga, ON L5N 4E8	Tel #:	Comments: 12/12/12 <sup>e</sup> insufficient cooling	
Date Due:	Tel: 905-858-3462 Fax: 905-858-1673	Fax #:		
PN #	E-mail:	Email:		
Relinquished by (Sign Name): Jefferson G. Pinto	Date: Sept/12/08	Laboratory Prepared Container:		
Relinquished by (Print Name): Jefferson G. Pinto	Time: 7:20 AM TO 7:55 AM	<input type="checkbox"/> Yes	<input type="checkbox"/> No	

**NOTE:** Samples submitted to Maxxam Analytics n  
It is the Sampler's responsibility to ensure adequate cooling is provided.  
Please ensure that a separate COC document is submitted.

**SIF** : Sample Inspection  
Resolved  By: \_\_\_\_\_  
Date: \_\_\_\_\_