

Your P.O. #: BN500116
Your Project #: ST. VALENTINE
Site:500018773
Your C.O.C. #: na

Attention: Roland Lawton
Dufferin Peel Catholic District...
School Board
40 Matheson Blvd W
Mississauga, ON
L5R 1C5

Report Date: 2008/07/28

CERTIFICATE OF ANALYSIS

MAXXAM JOB #: A878279
Received: 2008/07/17, 13:29

Sample Matrix: Water
Samples Received: 2

Analyses	Quantity	Date Extracted	Date Analyzed	Laboratory Method	Method Reference
Metals Analysis by ICPMS (as received) 0	2	2008/07/25	2008/07/26	CAM SOP-00447	EPA 6020

* RPDs calculated using raw data. The rounding of final results may result in the apparent difference.

(1) Metals analysis was performed on the sample 'as received'.

Encryption Key

Please direct all questions regarding this Certificate of Analysis to your Project Manager.

JAMES ASPIN, Project Manager
Email: James.Aspin@maxxamAnalytics.com
Phone# (905) 817-5700 Ext:5771

=====
Maxxam has procedures in place to guard against improper use of the electronic signature and have the required "signatories", as per section 5.10.2 of ISO/IEC 17025:2005(E), signing the reports. SCC and CAEAL have approved this reporting process and electronic report format.

For Service Group specific validation please refer to the Validation Signature Page

Total cover pages: 1

Maxxam Job #: A878279
Report Date: 2008/07/28

Dufferin Peel Catholic District...
Client Project #: ST. VALENTINE
Project name: 500018773
Your P.O. #: BN500116

ELEMENTS BY ATOMIC SPECTROSCOPY (WATER)

Maxxam ID			Z96400		
Sampling Date			2008/07/17 07:15		
COC Number			na		
	Units	Criteria	ST. VALENTINE-KITCHEN-STAFFROOM- STANDING	RDL	QC Batch

Metals					
. Lead (Pb)	mg/L	0.01	ND	0.0005	1570632
ND = Not detected RDL = Reportable Detection Limit QC Batch = Quality Control Batch CRITERIA: Ontario Regulation 243/07 made under the Safe Drinking Water Act, 2002. Released June 7, 2007					

Maxxam ID			Z96401		
Sampling Date			2008/07/17 07:50		
COC Number			na		
	Units	Criteria	ST. VALENTINE-KITCHEN-STAFFROOM- FLUSHED	RDL	QC Batch

Metals					
. Lead (Pb)	mg/L	0.01	ND	0.0005	1571011
ND = Not detected RDL = Reportable Detection Limit QC Batch = Quality Control Batch CRITERIA: Ontario Regulation 243/07 made under the Safe Drinking Water Act, 2002. Released June 7, 2007					

Maxxam Job #: A878279
Report Date: 2008/07/28

Dufferin Peel Catholic District...
Client Project #: ST. VALENTINE
Project name: 500018773
Your P.O. #: BN500116

Package 1	7.3°C
-----------	-------

Each temperature is the average of up to three cooler temperatures taken at receipt

GENERAL COMMENTS

Results relate only to the items tested.

Dufferin Peel Catholic District...
Attention: Roland Lawton
Client Project #: ST. VALENTINE
P.O. #: BN500116
Project name: 500018773

Quality Assurance Report
Maxxam Job Number: MA878279

QA/QC Batch	QC Type	Parameter	Date Analyzed yyyy/mm/dd	Value	Recovery	Units	QC Limits
1570632 JBW	MATRIX SPIKE	. Lead (Pb)	2008/07/26		112	%	80 - 120
	Spiked Blank	. Lead (Pb)	2008/07/26		99	%	85 - 115
	Method Blank	. Lead (Pb)	2008/07/26	ND, RDL=0.5		ug/L	
	RPD	. Lead (Pb)	2008/07/26	1.2		%	25
1571011 HRE	MATRIX SPIKE	. Lead (Pb)	2008/07/26		100	%	80 - 120
	Spiked Blank	. Lead (Pb)	2008/07/26		100	%	85 - 115
	Method Blank	. Lead (Pb)	2008/07/26	ND, RDL=0.5		ug/L	
	RPD	. Lead (Pb)	2008/07/26	1.5		%	25

ND = Not detected
RPD = Relative Percent Difference
SPIKE = Fortified sample

Validation Signature Page

Maxxam Job #: A878279

The analytical data and all QC contained in this report were reviewed and validated by the following individual(s).

 

EWA PRANJIC, M.Sc., C.Chem, Scientific Specialist

=====
Maxxam has procedures in place to guard against improper use of the electronic signature and have the required "signatories", as per section 5.10.2 of ISO/IEC 17025:2005(E), signing the reports. SCC and CAEAL have approved this reporting process and electronic report format.



6740 Campobello Rd
Mississauga
Ontario L5N 2L8

REGULATION 243 DRINKING WATER SUBM CHAIN OF CUSTODY RECORD

Tel: 905-817-5700
Fax: 905-817-5779
Toll Free: 1-800-563-6266

Samples are Regulated
Under Reg 243

17-Jul-08 13:29
JAMES ASPIN
A878279
CCO ENV-875

Report to:

Company Name: Dufferin-Peel Catholic District School Board
Client Contact: Roland Lawton, General Manager of Physical Plant Facilities
Address: 5685 Keaton Cres., Mississauga ON L5R 3H5
E-Mail: roland.lawton@dpcdsb.org Tel: 905-890-0708 ext. 23204
Project: Regulation 243 Fax: 905-890-5841
Quote #: A83456 P.O.#: BN500636
Lab Service Rep.: James Aspin

Invoice to: Same as "Report to"

DW METALS
PRESERVATION
CHECKED

PAGE ____ OF ____

ANALYSIS REQUESTED

Specify School Type

Private School Day nursery

M.O.E. Assigned Water System Number

500018773

Sample Identification	Sample Type (Please Specify Standing / Flushed)	Date Sampled	Time Sampled	Sampler Initials	Field Chlorine		No. of Bottles	Lead
					Total	Free		
St. Valentine								
Kitchen - Staffroom	Standing	7/17/08	7:15	TG			1	X
Kitchen - Staffroom	Flushed	7/17/08	7:50	TG			1	X

SIF : Sample Inspection

Resolved By: _____

Date: _____

In accordance with the Safe Drinking Water Act (2002), notification of adverse results must be reported. Failure to do so is an offence under the act. It is **IMPERATIVE** that the areas shaded in grey be filled out.

TAT (Turnaround Time)	Notification Information for School, Private Schools & Day Nurseries	LABORATORY USE ONLY
RUSH TAT MUST HAVE PRIOR APPROVAL	Facility Name: St. Valentine Facility Address: 5610 Heatherleigh Avenue Mississauga, ON L5V 2V7	Received By: <i>LOLA ZENITH</i> Date: <i>08/04/08</i> Time: <i>13:29</i> Comments:
<input checked="" type="checkbox"/> Normal (5-15 Working Days)	Tel: 905-890-0909 Fax: 905-890-6868	
<input type="checkbox"/> RUSH (Specify Below)	Tel #: _____ Fax #: _____	
Date Due:	E-mail: _____	
PN #		
Relinquished by (Sign Name): <i>K. Williams</i>	Date: <i>July 17/08</i>	Laboratory Prepared Container:
Relinquished by (Print Name): <i>Kim Williams</i>	Time: <i>2:28 pm</i>	<input type="checkbox"/> Yes <input type="checkbox"/> No

NOTE: Samples submitted to Maxxam Analytics must be received below 10°C.

It is the Sampler's responsibility to ensure adequate cooling is provided so that this receiving temperature is met. Please ensure that a separate COC document is used for each indiv

08 JUL 17 13:29
7/21/08