

Your P.O. #: BN500636
Your Project #: ST. VERONICA
Site:500019293
Your C.O.C. #: NA

Attention: Roland Lawton
Dufferin Peel Catholic District...
School Board
40 Matheson Blvd W
Mississauga, ON
L5R 1C5

Report Date: 2008/07/23

CERTIFICATE OF ANALYSIS

MAXXAM JOB #: A877966
Received: 2008/07/17, 14:17

Sample Matrix: Water
Samples Received: 2

Analyses	Quantity	Date Extracted	Date Analyzed	Laboratory Method	Method Reference
Metals Analysis by ICPMS (as received) 0	2	2008/07/22	2008/07/22	CAM SOP-00447	EPA 6020

* RPDs calculated using raw data. The rounding of final results may result in the apparent difference.

(1) Metals analysis was performed on the sample 'as received'.

Encryption Key

Please direct all questions regarding this Certificate of Analysis to your Project Manager.

JAMES ASPIN, Project Manager
Email: James.Aspin@maxxamAnalytics.com
Phone# (905) 817-5700 Ext:5771

=====
Maxxam has procedures in place to guard against improper use of the electronic signature and have the required "signatories", as per section 5.10.2 of ISO/IEC 17025:2005(E), signing the reports. SCC and CAEAL have approved this reporting process and electronic report format.

For Service Group specific validation please refer to the Validation Signature Page

Total cover pages: 1

Maxxam Job #: A877966
Report Date: 2008/07/23

Dufferin Peel Catholic District...
Client Project #: ST. VERONICA
Project name: 500019293
Your P.O. #: BN500636

ELEMENTS BY ATOMIC SPECTROSCOPY (WATER)

Maxxam ID			Z95416	Z95417		
Sampling Date			2008/07/17 07:00	2008/07/17 07:35		
COC Number			NA	NA		
	Units	Criteria	ST. VERONICA KITCHEN-STAFFROOM/STANDING	ST. VERONICA KITCHEN-STAFFROOM/FLUSHED	RDL	QC Batch

Metals						
Lead (Pb)	mg/L	0.01	0.0008	ND	0.0005	1566729

ND = Not detected
RDL = Reportable Detection Limit
QC Batch = Quality Control Batch
CRITERIA: Ontario Regulation 243/07 made under the Safe Drinking Water Act, 2002.

Released June 7, 2007

Maxxam Job #: A877966
Report Date: 2008/07/23

Dufferin Peel Catholic District...
Client Project #: ST. VERONICA
Project name: 500019293
Your P.O. #: BN500636

Package 1	10.0°C
-----------	--------

Each temperature is the average of up to three cooler temperatures taken at receipt

GENERAL COMMENTS

Results relate only to the items tested.

Dufferin Peel Catholic District...
Attention: Roland Lawton
Client Project #: ST. VERONICA
P.O. #: BN500636
Project name: 500019293

Quality Assurance Report
Maxxam Job Number: MA877966


QA/QC Batch	QC Type	Parameter	Date Analyzed yyyy/mm/dd	Value	Recovery	Units	QC Limits
1566729 HRE	MATRIX SPIKE	. Lead (Pb)	2008/07/22		99	%	80 - 120
	Spiked Blank	. Lead (Pb)	2008/07/22		102	%	85 - 115
	Method Blank	. Lead (Pb)	2008/07/22	ND, RDL=0.5		ug/L	
	RPD	. Lead (Pb)	2008/07/22	NC		%	25

ND = Not detected
NC = Non-calculable
RPD = Relative Percent Difference
SPIKE = Fortified sample

Validation Signature Page

Maxxam Job #: A877966

The analytical data and all QC contained in this report were reviewed and validated by the following individual(s).



TROY CARRIERE, B.Sc., C.Chem, Scientific Specialist

Maxxam has procedures in place to guard against improper use of the electronic signature and have the required "signatories", as per section 5.10.2 of ISO/IEC 17025:2005(E), signing the reports. SCC and CAEAL have approved this reporting process and electronic report format.



6740 Campobello Rd
Mississauga
Ontario L5N 2L8

REGULATION 243 DRINKING WATER SUPPLY
CHAIN OF CUSTODY RECORD

Tel: 905-817-5700
Fax: 905-817-5779
Toll Free: 1-800-563-6266

Samples are Regulated
Under Reg 243

17-Jul-08 14:17

JAMES ASPIN



A877966

FW

ENV-756

Maxxam Analytics Inc.
CAM FCD-00196/2

Report to:

Company Name:	Dufferin-Peel Catholic District School Board		
Client Contact:	Roland Lawton, General Manager of Physical Plant Facilities		
Address:	5685 Keaton Cres., Mississauga ON L5R 3H5		
E-Mail:	<u>roland.lawton@dpcdsb.org</u>	Tel:	905-890-0708 ext. 23204
Project:	Regulation 243	Fax:	905-890-5841
Quote #:	A83456	P.O.#:	BN500636
Lab Service Rep.:	James Aspin		

**DW METALS
PRESERVATION
CHECKED**

PAGE _____ OF _____	
ANALYSIS REQUESTED	
Specify School Type	M.O.E. Assigned Water System Number 500019293
School	
Private School	
Day nursery	

Sample Identification	Sample Type (Please Specify Standing / Flushed)	Date Sampled	Time Sampled	Sampler Initials	Field Chlorine		No. of Bottles	Lead	Specify School Type			
					Total	Free			School	Private School	Day nursery	
St. Veronica		17708	7:04 PM				1					
Kitchen - Staffroom	Standing	FIRST 7:08	7:35 PM				1	X	X			
Kitchen - Staffroom	Flushed	SECOND 7:37					1	X	X			

* In accordance with the Safe Drinking Water Act (2002), notification of adverse results must be reported to the SAC, MOH & Waterworks. Failure to do so is an offence under the act. It is **IMPERATIVE** that the areas shaded in grey be filled out completely before submitting to Maxxam Analytics.

TAT (Turnaround Time)	Notification Information for School, Private Schools & Day Nurseries		LABORATORY USE ONLY
RUSH TAT MUST HAVE PRIOR APPROVAL	Facility Name: St. Veronica	Medical Officer of Health	Received By: <i>J. J. J.</i>
	Facility Address: 680 Novo Star Drive	Region: Peel Region	Date: 08/07/17 Time: 14:17
<input checked="" type="checkbox"/> Normal (5-15 Working Days)	Mississauga, ON L5W 1C7		Comments:
<input type="checkbox"/> RUSH (Specify Below)		Tel #:	10/10/10
Date Due:	Tel: 905-696-6980 Fax: 905-696-6982	Fax #:	08 JUL 17 14:17
PN #	E-mail:	Email:	
Relinquished by (Sign Name): <i>Mladen Spudic</i>	Date: July 17, 2008	Laboratory Prepared Container:	
Relinquished by (Print Name): <i>MLADEN SPUDIC</i>	Time: FIRST TAK. SECOND 7:35 AM	<input type="checkbox"/> Yes <input type="checkbox"/> No	

NOTE: Samples submitted to Maxxam Analytics must be received below 10°C. It is the Sampler's responsibility to ensure adequate cooling is provided so that the receiving temperature is met. Please ensure that a separate COC document is used for each individual sample.