

The Dufferin-Peel Catholic District School Board

Water - Secondary Schools Lead Testing Results 2008

Maximum Allowable Lead	MG/L 0.01	MG/L 0.01
Results (ND=none detected)	Standing	Flushed
School		
Archbishop Romero-Miss Campus	0.0033	0.0015
Archbishop Romero Catholic SS	ND	0.0026
Archbishop Romero-New Directions	0.0039	NA
Ascension of Our Lord	ND	ND
Cardinal Leger SS	0.0087	0.0024
Fr. Michael Goetz SS	0.0016	0.0006
Holy Name of Mary SS	NA	NA
IONA SS	0.0007	ND
John Cabot Catholic SS	0.0008	ND
Loyola Catholic SS	0.00068	0.0009
Notre Dame Catholic SS	0.0042	0.0014
Our Lady of Mt.Carmel SS	0.0014	ND
Philip Pocock Catholic	0.0011	ND
Robert F. Hall Catholic	0.0005	0.0025
St. Aloysius Gonzaga SS	0.0015	0.0006
St. Augustine SS	ND	ND
St. Edmund Campion S.S.	ND	ND
St. Francis Xavier SS	ND	ND
St. Joseph SS	0.0005	ND
St. Joan of Arc Catholic	ND	ND
St. Marcellinus	0.0009	ND
St. Marguerite d'Youville SS	0.0007	0.0009
St. Martin SS	0.0007	ND
St. Paul SS	0.0038	0.0011
St. Thomas Aquinas SS	ND	ND