

**Dufferin-Peel Catholic District School Board
Regulated Water Testing Summary for Schools 2021**

School Name	DWIS Number	Municipal Address	Testing Dates	Testing Times	Sample ID	Sample Location Description	Results: Standing (mg/L)	Results: Flushed (mg/L)
Ascension of Our Lord	500019319	7640 Anaka Drive, Mississauga	16-Jul-21	7:24 am - 7:59 am	DF-01	Outside CR. 105	0.00116	0.00026
			16-Jul-21	7:24 am - 7:59 am	CAF		0.00460	0.00071
			16-Jul-21	7:33 am - 8:08 am	DF-02	Outside Mechanical Room	0.00010	0.00003
			16-Jul-21	7:34 am - 8:09 am	DF-03	Outside CR. 309	0.00051	0.00016
Bishop Francis Allen	500000469	325 McMurchy Avenue South, Brampton	20-Jul-21	6:11 am - 6:46 am	DF-01	Outside Staff Room	0.00121	0.00078
			20-Jul-21	6:23 am - 6:58 am	DF-02	Outside CR. 8	0.00125	0.00056
			19-Aug-21	7:04 am - 7:39 am	KG-1	Outside CR. 8	0.00244	0.00137
Cardinal Ambrozic	500198342	10 Castle Oaks Crossing, Brampton	10-Aug-21	6:13 am - 6:49 am	Caf Sink		0.00157	0.00038
			10-Aug-21	6:09 am - 6:44 am	DF 1st Floor	Outside Cosmo Room 128	0.00204	0.00090
			10-Aug-21	6:17 am - 6:52 am	DF 2nd Floor	Outside HPR 2-A	0.00040	0.00013
Cardinal Leger	500012676	75 Mary Street, Brampton	12-Aug-21	7:58 am - 8:33 am	Caf		0.00087	0.00030
			12-Aug-21	8:08 am - 8:43 am	DF-01	Outside Girls Change Room	0.00020	0.00016
			12-Aug-21	8:24 am - 8:59 am	DF-02	Outside Mechanical Room	0.00012	0.00049
Cardinal Newman	500012247	698 Balmoral Drive, Brampton	16-Jul-21	9:20 am - 9:55 am	KG-28		0.00124	0.00102
			16-Jul-21	9:22 am - 9:57 am	DF-01	Outside Boys Change Room	0.00714	0.00473
Father Clair Tipping	500012546	25 Mountain Berry Drive, Brampton	29-Jul-21	4:54 am - 5:29 am	KG101 (Small Sink)		0.00298	0.00136
			29-Jul-21	4:57 am - 5:32 am	DF 1st Floor	Across from KG Room 103	0.01860	0.00766
			29-Jul-21	5:06 am - 5:41 am	DF 2nd Floor	Outside CR. 204	0.01350	0.00561
Father CW Sullivan	500012533	62 Seaborn Road, Brampton	27-Jul-21	6:16 am - 6:55 am	DF-01	Outside CR. 115	0.00060	0.00078
			27-Jul-21	6:22 am - 6:57 am	DF-02	Outside CR. 208	0.01670	0.00669
			27-Jul-21	6:10 am - 6:45 am	KG-104		0.00116	0.00123
Father Francis McSpritt	500124645	55 Lexington Road, Brampton	5-Aug-21	7:08 am - 7:43 am	KG103		0.00041	0.00046
			5-Aug-21	7:30 am - 8:05 am	DF - 1st Floor	Outside Seminar & Across from Bathrooms	0.00057	0.00076
			5-Aug-21	7:23 am - 7:58 am	DF - 2nd Floor	Across from Mechanical Room	0.00019	0.00028
Fun School	500073776	44 Port Street, Mississauga	30-Jul-21	7:03 am - 7:38 am	CCC - Kitchen	Daycare	0.00045	0.00048
Georges Vanier	500012169	28 Finchgate Boulevard, Brampton	16-Jul-21	6:01 am - 6:36 am	KG-101		0.04950	0.00388
			16-Jul-21	6:07 am - 6:42 am	DF-01	Outside KG 102	0.00044	0.00018
			16-Jul-21	6:13 am - 6:48 am	DF-02	Boys Washroom	0.00002	0.00007
Good Shepherd	500012273	28 Red River Drive, Brampton	29-Jul-21	5:53 am - 6:28 am	KG101 (Small Sink)		0.00201	0.00086
			29-Jul-21	5:57 am - 6:32 am	DF 01	Across from KG 104	0.00072	0.00044
			29-Jul-21	6:04 am - 6:39 am	DF 02	Outside Custodian Storage Room	0.00017	0.00021
Guardian Angels	500012286	62 Heatherdale Drive, Brampton	4-Aug-21	6:14 am - 6:49 am	KG102	Tall Sink	0.00108	0.00105
			4-Aug-21	6:19 am - 6:54 am	DF1	Outside Custodian Storage Room	0.00174	0.00120
			4-Aug-21	6:26 am - 7:01 am	DF2	Outside Custodian Storage Room	0.00151	0.00097
Holy Cross	500018994	3615 Morningstar Drive, Mississauga	16-Jul-21	6:16 am - 6:51 am	KG-104		0.00060	0.00070
			16-Jul-21	6:14 am - 6:49 am	DF-01	Outside Custodian Office	0.00045	0.00020
			16-Jul-21	6:22 am - 6:57 am	DF-02	Outside CR. 203	0.00087	0.00034
Holy Family	500012728	61 Allan Drive, Bolton	28-Jul-21	7:17 am - 7:52 am	KG101 (Small Sink)		0.00151	0.00182
			28-Jul-21	7:11 am - 7:42 am	DF 1st Floor	Across from CR. 106	0.00006	0.00003
			28-Jul-21	7:24 am - 7:59 am	DF 2nd Floor	Across from CR. 207	0.00086	0.00113
Holy Spirit	500012104	25 Bloomsbury Avenue, Brampton	6-Aug-21	6:24 am - 6:59 am	KG101 (Small Sink)		0.00078	0.00041
			6-Aug-21	6:27 am - 7:02 am	DF 1st Floor (KG102)	Inside KG102	0.00099	0.00067
			6-Aug-21	6:30 am - 7:05 am	DF 2nd Floor	Across from CR. 202	0.00004	0.00006
Lester B. Pearson	500012195	140 Howden Boulevard, Brampton	4-Aug-21	5:47 am - 6:22 am	KG-101		0.00058	0.00017
			4-Aug-21	5:48 am - 6:23 am	DF-01	Outside Custodian Office	0.00172	0.00053
			4-Aug-21	5:53 am - 6:28 am	DF-02	Outside CR. 206	0.00059	0.00007
Notre Dame SS	500012156	2 Notre Dame Avenue, Brampton	4-Aug-21	7:35 am - 8:10 am	DF-01	Outside Food Services Shop	0.00303	0.00187
			4-Aug-21	7:40 am - 8:15 am	DF-02	Across CR. 214	0.00212	0.00119
			4-Aug-21	7:30 am - 8:05 am	CAF		0.00146	0.00071
Our Lady of Fatima	500012208	39 Sunset Boulevard, Brampton	21-Jul-21	7:08 am - 7:43 am	KG1	Small Sink	0.01240	0.00570
			21-Jul-21	7:14 am - 7:49 am	DF1	Outside Speech Practice Room	0.00316	0.00304
Our Lady of Lourdes	500269933	25 Mount Royal Circle, Brampton	3-Aug-21	6:23 am - 6:58 am	KG101 (Small Sink)		0.00014	0.00009
			3-Aug-21	6:30 am - 7:05 am	DF 1st Floor	Outside ACAD Storage	0.00012	0.00003
			3-Aug-21	6:38 am - 7:13 am	DF 2nd Floor	Outside CR. 209	0.00002	0.00004
Our Lady of Peace	500012117	15 Fincham Avenue, Brampton	19-Jul-21	6:31 am - 7:06 am	KG102	Small Sink	0.00290	0.00136
			19-Jul-21	7:10 am - 7:45 am	DF2	Across from CR. 205	0.00039	0.00008
Our Lady of Peace CCC	500072983		19-Jul-21	6:52 am - 7:27 am	CCC - Kitchen	CCC Kitchen Tub Sink	Tap rendered permanently inaccessible 0.00081	0.00036

**Dufferin-Peel Catholic District School Board
Regulated Water Testing Summary for Schools 2021**

School Name	DWIS Number	Municipal Address	Testing Dates	Testing Times	Sample ID	Sample Location Description	Results: Standing (mg/L)	Results: Flushed (mg/L)
Our Lady of Providence	500012299	35 Black Oak Drive, Brampton	6-Aug-21	5:02 am - 5:37 am	KG102 (Small Sink)	Outside KG 102 Across from CR. 211	0.00656	0.00168
			6-Aug-21	5:03 am - 5:38 am	DF 1st Floor		0.04840	0.00979
			6-Aug-21	5:07 am - 5:42 am	DF 2nd Floor		0.00019	0.00029
Our Lady of Providence CCC	500104612		6-Aug-21	5:04 am - 5:39 am	CCC Kitchen (Tall Sink)		0.00103	0.00044
Pauline Vanier	500012221	56 Oaklea Boulevard, Brampton	20-Jul-21	6:10 am - 6:45 am	KG102	Small Sink Across from CR. 106 Across from Special Ed 204 Tub Sink	0.00150	0.00054
			20-Jul-21	6:18 am - 6:53 am	DF1		0.00082	0.00066
			20-Jul-21	6:30 am - 7:05 am	DF2		0.00019	0.00014
Pauline Vanier CCC	500083500		20-Jul-21	6:25 am - 7:00 am	CCC - Kitchen		0.00063	0.00034
Robert F. Hall	500018630	6500 Old Church Road, Caledon East	27-Jul-21	8:07 am - 8:42 am	Caf Sink	Outside Lab Room 101 Outside Art Room 201	0.00832	0.00349
			27-Jul-21	8:22 am - 8:57 am	DF 1st Floor		0.00004	<0.00001
			27-Jul-21	8:29 am - 9:04 am	DF 2nd Floor		<0.00001	<0.00001
Sacred Heart	500012507	24 Kerwood Place, Brampton	22-Jul-21	5:03 am - 5:38 am	KG-2	Outside Girls Washroom Across CR. 7	0.00620	0.00220
			22-Jul-21	5:09 am - 5:44 am	DF-01		0.00661	0.00209
			22-Jul-21	5:16 am - 5:51 am	DF-02		0.00009	0.00003
St. Agnes	500012234	103 Richvale Drive South, Brampton	12-Aug-21	6:50 am - 7:25 am	DF-01	Across Life Skills Room Outside of CR. 205	0.00006	0.00002
			12-Aug-21	6:59 am - 7:34 am	DF-02		0.00002	0.00001
			12-Aug-21	6:43 am - 7:18 am	KG-112		0.00235	0.00164
St. Agnes CCC	500084813		12-Aug-21	6:35 am - 7:10 am	CCC - Kitchen		0.00025	0.00029
St. Aidan	500124528	32 Buick Boulevard, Brampton	19-Jul-21	6:00 am - 6:35 am	KG102	Tall Sink Across from CR. 105 Across from CR. 210	0.00082	0.00039
			19-Jul-21	6:06 am - 6:41 am	DF1		0.00022	0.00020
			19-Jul-21	6:12 am - 6:47 am	DF2		0.00029	0.00021
St. Alphonsa	500437217	60 Olivia Marie Road, Brampton	20-Jul-21	5:00 am - 5:35 am	KG104	Tall Sink Across from KG 103 Across from CR. 209	0.00058	0.00023
			20-Jul-21	5:07 am - 5:42 am	DF1		0.00013	0.00008
			20-Jul-21	5:15 am - 5:50 am	DF2		0.00040	0.00013
St. Andre Bessette	500344618	25 Riverstone Drive, Brampton	16-Jul-21	5:05 am - 5:40 am	KG-109	Outside Girls Change Room Outside Custodian Office	0.00080	0.00026
			16-Jul-21	5:08 am - 5:43 am	DF-01		0.00001	0.00018
			16-Jul-21	5:17 am - 5:52 am	DF-02		<0.00001	<0.00001
St. Andrew	500013833	50 Meadow Drive, Orangeville	3-Aug-21	5:51 am - 6:26 am	KG103 (Small Sink)	Outside Custodian Office Outside Custodian Storage	0.00261	0.00127
			3-Aug-21	5:52 am - 6:27 am	DF 1st Floor		0.00005	0.00001
			3-Aug-21	5:55 am - 6:30 am	DF 2nd Floor		0.00001	0.00004
St. Angela Meirci	500012390	83 Edenbrook Hill Drive, Brampton	21-Jul-21	4:56 am - 5:31 am	KG102	Tall Sink Outside KG 101 Outside Boys Washroom	0.00046	0.00063
			21-Jul-21	4:58 am - 5:33 am	DF1		0.00008	0.00005
			21-Jul-21	5:06 am - 5:41 am	DF2		0.00028	0.00006
St. Anne	500012663	124 Vodden Street, Brampton	23-Jul-21	7:00 am - 7:35 am	KG-100	Outside CR. 117 Outside Girls Washroom	0.00856	0.00182
			23-Jul-21	7:03 am - 7:38 am	DF-01		0.01000	0.00413
			23-Jul-21	7:08 am - 7:43 am	DF-02		0.00118	0.00083
St. Anthony	500012754	950 North Park Drive, Brampton	21-Jul-21	6:26 am - 7:01 am	KG-106	Outside CR. 111 Outside CR. 214	0.00030	0.00018
			21-Jul-21	6:34 am - 7:09 am	DF-01		0.00140	0.00034
			21-Jul-21	6:44 am - 7:19 am	DF-02		<0.00001	<0.00001
St. Augustine	500012611	27 Drinkwater Road, Brampton	26-Jul-21	5:18 am - 5:53 am	CAF Sink	Outside Girls/Boys Washroom Outside Girls/Boys Washroom Sink	0.00044	0.00118
			26-Jul-21	5:31 am - 6:06 am	DF1		0.00004	<0.00001
			26-Jul-21	5:44 am - 6:19 am	DF2		0.00170	0.00183
St. Augustine CCC	500089402		26-Jul-21	6:12 am - 6:47 am	CCC - Kitchen		0.00061	0.00104
St. Barbara	500018890	1455 Samuelson Circle, Mississauga	30-Jul-21	5:45 am - 6:20 am	KG101 (Small Sink)	Small Sink Outside CR. 113 Outside CR. 215 Handwash Sink	0.00135	0.00099
			30-Jul-21	5:47 am - 6:22 am	DF1		0.00113	0.00055
			30-Jul-21	5:57 am - 6:32 am	DF2		0.00052	0.00031
St. Barbara CCC	500091794		30-Jul-21	5:51 am - 6:26 am	CCC - Kitchen		0.00032	0.00017
St. Benedict	500013846	345 Blind Line, RR4, Orangeville	3-Aug-21	4:54 am - 5:29 am	KG102 (Small Sink)	Outside Boys Washroom & Across from Stairs DF 1st Floor Outside Boys Washroom & Across from Stairs	0.00608	0.00190
			3-Aug-21	5:01 am - 5:36 am	DF 1st Floor		0.00456	0.00224
			3-Aug-21	5:05 am - 5:40 am	DF Lower Level		0.00002	0.00006
St. Bonaventure	500124554	35 McCrimmon Drive, Brampton	4-Aug-21	5:12 am - 5:47 am	KG113	Sink Outside KG 101 Outside Boys/Girls Washroom	0.00044	0.00082
			4-Aug-21	5:18 am - 5:53 am	DF1		0.00128	0.00094
			4-Aug-21	5:26 am - 6:01 am	DF2		0.00010	0.00003
St. Brigid	500012715	81 Torrance Woods, Brampton	20-Jul-21	7:10 am - 7:45 am	KG101	Tall Sink Outside CR. 104 Outside CR. 211	0.00280	0.00130
			20-Jul-21	7:16 am - 7:51 am	DF1		0.00063	0.00048
			20-Jul-21	7:22 am - 7:57 am	DF2		0.00004	0.00010
St. Cecilia	500012702	10 Brickyard Way, Brampton	10-Aug-21	5:18 am - 5:53 am	KG102	Small Sink Outside KG 103 Across from CR. 225	0.00168	0.00158
			10-Aug-21	5:25 am - 6:00 am	DF1		0.00102	0.00082
			10-Aug-21	5:32 am - 6:07 am	DF2		0.00122	0.00072
St. Cornelius	500012780	16066 Innis Lake Road, Caledon East	5-Aug-21	5:45 am - 6:20 am	DF 1st Floor	Across from CR. 103 Outside Mechanical Room Classroom 113	0.01930	0.00469
			5-Aug-21	5:52 am - 6:27 am	DF 2nd Floor		0.00580	0.00210
			5-Aug-21	5:48 am - 6:23 am	Rm 113 (Small Sink)		0.00001	0.00002

**Dufferin-Peel Catholic District School Board
Regulated Water Testing Summary for Schools 2021**

School Name	DWIS Number	Municipal Address	Testing Dates	Testing Times	Sample ID	Sample Location Description	Results: Standing (mg/L)	Results: Flushed (mg/L)
St. Daniel Comboni	500437204	120 Veterans Drive, Brampton	19-Jul-21	5:02 am - 5:37 am	CCC	Left Toddler Sink	0.00021	0.00013
			19-Jul-21	5:04 am - 5:39 am	KG111	Tall Sink	0.00042	0.00023
			19-Jul-21	5:10 am - 5:45 am	DF2	Outside Staff Washroom	0.00032	0.00023
			19-Jul-21	5:17 am - 5:52 am	DF2	Outside Boys Change Room	0.00030	0.00022
St. Edmund Campion SS	500012468	275 Brisdale Drive, Brampton	19-Jul-21	7:01 am - 7:36 am	Caf Sink	Across from CAF Office	0.00026	0.00072
			19-Jul-21	7:07 am - 7:42 am	DF1	Outside CR. 105	0.00034	0.00007
			19-Jul-21	7:14 am - 7:49 am	DF2	Outside CR. 201	0.00138	0.00077
			19-Jul-21	7:22 am - 7:57 am	DF3	Outside CR. 316	0.00002	<0.00001
St. Evan	500443327	500 McDougall Avenue, Caledon	23-Jul-21	5:13 am - 5:47 am	KG109		0.00008	0.00002
			23-Jul-21	5:22 am - 5:57 am	Drinking Fountain 1st Floor	Across from CR. 104	0.00006	0.00002
St. Evan CCC	500442612		23-Jul-21	5:29 am - 6:04 am	Drinking Fountain 2nd Floor	Across from Workroom	0.00004	0.00002
			23-Jul-21	5:16 am - 5:51 am	Childcare Kitchen		0.00012	0.00005
St. Francis Xavier Elementary	500012494	111 Bartley Bull Parkway, Brampton	27-Jul-21	7:17 am - 7:52 am	KG101		0.00784	0.00544
			27-Jul-21	7:19 am - 7:55 am	DF-01	Outside Staff Workroom	0.00020	0.00020
			27-Jul-21	7:26 am - 8:01 am	DF-02	Outside CR. 208	0.00146	0.00033
St. Gabriel Adult EC	N/A	3750 Brandon Gate Drive, Mississauga	16-Jul-21	8:34 am - 9:09 am	DF-01	Across Office	0.00088	0.00042
			16-Jul-21	8:41 am - 9:16 am	DF-02	Outside Custodian Office	0.00420	0.00216
St. Isaac Jogues	500012403	300 Great Lakes Drive, Brampton	22-Jul-21	6:13 am - 6:48 am	KG-102		0.00138	0.00091
			22-Jul-21	6:23 am - 6:58 am	DF-02	Across Library Resource Centre	0.00119	0.00015
St. Jacinta Marto	500443353	40 Fallowfield Road, Brampton	19-Jul-21	8:19 am - 8:54 am	KG109	Sink	0.00043	0.00027
			19-Jul-21	8:34 am - 9:09 am	DF1	Outside Boys Change Room	0.00057	0.00013
			19-Jul-21	8:45 am - 9:20 am	DF2	Outside General-Purpose Room	0.00034	0.00012
			19-Jul-21	8:26 am - 9:01 am	Toddler Room Kitchen		0.00032	0.00030
St. Jean Brebeuf	500012559	63 Glenforest Road, Brampton	4-Aug-21	4:56 am - 5:31 am	KG-101		0.00246	0.00170
			4-Aug-21	5:04 am - 5:39 am	DF-01 DF-02	Outside Custodian Office Across CR. 206	0.01880	0.01050
St. Jean-Marie Vianney	500344605	75 Jordensen Drive, Brampton	4-Aug-21	7:19 am - 7:54 am	KG104	Tall Sink	0.00051	0.00309
			4-Aug-21	7:28 am - 8:03 am	DF1	Outside Change Room 4	0.00077	0.00062
			4-Aug-21	7:37 am - 8:12 am	DF2	Across from CR. 202	0.00070	0.00054
St. Joachim	500012520	435 Rutherford Road North, Brampton	22-Jul-21	7:19 am - 7:54 am	DF-01	Outside Custodian Office	0.00006	0.00004
			22-Jul-21	7:25 am - 8:00 am	DF-02	Outside CR. 30	0.01860	0.00692
			22-Jul-21	7:11 am - 7:46 am	KG2		0.01060	0.00512
St. John Bosco	500012312	1025 North Park Drive, Brampton	21-Jul-21	7:43 am - 8:18 am	KG-101		0.00842	0.00710
			21-Jul-21	7:50 am - 8:25 am	DF-01	Across CR. 104	0.00087	0.00077
			21-Jul-21	8:04 am - 8:39 am	DF-02	Outside CR. 202	0.02390	0.00975
St. John Fisher	500012325	330 Balmoral Drive, Brampton	16-Jul-21	5:04 am - 5:39 am	KG-12		0.00062	0.00029
			16-Jul-21	5:11 am - 5:46 am	DF-01	Outside CR. 17	0.00049	0.00019
St. John Paul II	500012767	9094 Bolton Heights Road, Bolton	27-Jul-21	5:21 am - 5:56 am	KG102		0.00591	0.00258
			27-Jul-21	5:29 am - 6:04 am	DF 1st Floor	Outside Special Ed Room 113	0.00343	0.00200
			27-Jul-21	5:37 am - 6:12 am	DF 2nd Floor	Across from CR. 206	0.00041	0.00020
St. John the Baptist	500018643	299 Landsbridge Street, Bolton	23-Jul-21	5:27 am - 6:02 am	KG-103		0.00024	0.00020
			23-Jul-21	5:34 am - 6:09 am	DF-01	Across from CR. 111	0.00032	0.00040
			23-Jul-21	5:43 am - 6:18 am	DF-02	Across from CR. 203	0.00146	0.00062
St. Joseph Elementary Brampton	500012130	8 Parkway Avenue, Brampton	19-Jul-21	5:19 am - 5:54 am	KG1	Small Sink	0.00439	0.00151
			19-Jul-21	5:27 am - 6:02 am	DF1	Across from General Office	0.00328	0.00151
St. Josephine Bakhita	500162202	430 Van Kirk Drive, Brampton	28-Jul-21	5:34 am - 6:09 am	KG102 (Small Sink)		0.00021	0.00021
			28-Jul-21	5:40 am - 6:15 am	DF 1st Floor	Across from Confer. Room	0.00041	0.00033
			28-Jul-21	5:47 am - 6:22 am	DF 2nd Floor	Across from CR. 203	0.00048	0.00021
St. Julia	500019722	6770 Historic Trail, Mississauga	30-Jul-21	4:50 am - 5:25 am	KG101	Small Sink	0.00033	0.00026
			30-Jul-21	4:54 am - 5:29 am	DF01	Outside KG 103	0.00058	0.00039
			30-Jul-21	4:56 am - 5:31 am	DF02	Outside Room 215	0.00044	0.00021
St. Kevin	500012143	103 Malta Avenue, Brampton	19-Aug-21	5:07 am - 5:42 am	KG101	Small Sink	0.00603	0.00262
			20-Jul-21	5:11 am - 5:46 am	DF1	Across from Special Ed 116	0.00022	0.00016
			20-Jul-21	5:17 am - 5:52 am	DF2	Across from CR. 205	0.00212	0.00073
			20-Jul-21	5:05 am - 5:40 am	CCC - Kitchen	Daycare	0.00318	0.00230
St. Kevin CCC	500086100		20-Jul-21	5:05 am - 5:40 am	CCC - Kitchen	Daycare	0.00318	0.00230
			20-Jul-21	5:05 am - 5:40 am	CCC - Kitchen	Daycare	0.00318	0.00230
			20-Jul-21	5:05 am - 5:40 am	CCC - Kitchen	Daycare	0.00318	0.00230
St. Lucy	500124658	25 Kanata Road, Brampton	28-Jul-21	6:55 am - 7:30 am	DF 1st Floor	Outside Boys Bathroom	0.00021	0.00010
			28-Jul-21	7:02 am - 7:37 am	DF 2nd Floor	Outside Staff Bathroom	0.00031	0.00010
			28-Jul-21	6:47 am - 7:22 am	KG102 (Small Sink)		0.00022	0.00011

**Dufferin-Peel Catholic District School Board
Regulated Water Testing Summary for Schools 2021**

School Name	DWIS Number	Municipal Address	Testing Dates	Testing Times	Sample ID	Sample Location Description	Results: Standing (mg/L)	Results: Flushed (mg/L)
St. Marguerite Bourgeoys	500012351	550 North Park Drive, Brampton	21-Jul-21	5:07 am - 5:42 am	KG101	Outside Academic Storage Outside Custodian Office	0.00816	0.00583
			21-Jul-21	5:19 am - 5:54 am	DF-01		0.00011	0.00002
			21-Jul-21	5:29 am - 6:04 am	DF-02		0.00011	0.00010
St. Marguerite d'Youville SS	500012624	10815 Dixie Road, Brampton	10-Aug-21	7:19 am - 7:54 am	CAF Sink	Across from Construction Technology CR. 123 Across from CR. 205 Across from CR. 305	0.00760	0.00196
			10-Aug-21	7:13 am - 7:48 am	DF 1st Floor		0.00115	0.00033
			10-Aug-21	7:27 am - 8:02 am	DF 2nd Floor		0.00250	0.00127
			10-Aug-21	7:31 am - 8:06 am	DF 3rd Floor		0.00086	0.00091
St. Maria Goretti	500012364	121 Royal Orchard Drive, Brampton	5-Aug-21	5:07 am - 5:42 am	KG103	Tall Sink	0.00157	0.00095
			5-Aug-21	5:16 am - 5:51 am	DF1	Across from CR. 109	0.00166	0.00098
St. Maria Goretti CCC	500103156		5-Aug-21	5:31 am - 6:06 am	DF2	Outside CR. 201	<0.00001	0.00003
St. Mary BR	500012689	66 Main Street South, Brampton	5-Aug-21	5:23 am - 5:58 am	CCC - Kitchen	Large Sink in Daycare	0.00063	0.00039
St. Mary BR	500012689	66 Main Street South, Brampton	26-Jul-21	8:40 am - 9:15 am	KG-1	Kindergarten-103	0.00248	0.00132
			26-Jul-21	8:57 am - 9:32 am	DF-01	Across Girls Washroom	0.00068	0.00058
			26-Jul-21	8:50 am - 9:25 am	DF-02	Outside Library	0.00875	0.00477
St. Michael SS	500218154	9130 Columbia Way, Bolton	27-Jul-21	6:30 am - 7:05 am	Caf Sink	Across from Boys Change Room Across from Computer Lab 201	0.00041	0.00012
			27-Jul-21	6:37 am - 7:12 am	DF 1st Floor		0.00020	0.00004
			27-Jul-21	6:45 am - 7:20 am	DF 2nd Floor		0.00014	0.00005
St. Monica	500012377	60 Sterrit Drive, Brampton	26-Jul-21	7:36 am - 8:11 am	Caf Sink	Cafeteria	0.00060	0.00061
			26-Jul-21	7:09 am - 7:44 am	DF-01	Across CR. 109	0.00040	0.00030
			26-Jul-21	7:24 am - 7:59 am	DF-02	Outside CR. 203	0.00263	0.00112
St. Nicholas	500012741	120 Harvest Moon Drive, Bolton	23-Jul-21	6:57 am - 7:32 am	KG101	Across from CR. 102 Across from CR. 207	0.00023	0.00008
			23-Jul-21	7:03 am - 7:38 am	DF-01		0.00021	0.00008
			23-Jul-21	7:11 am - 7:46 am	DF-02		0.00036	0.00019
St. Patrick	500012572	11873 The Gore Road, Brampton	3-Aug-21	5:14 am - 5:49 am	KG112	Across from CR. 102	0.01650	0.00371
			3-Aug-21	5:22 am - 5:57 am	DF 1st Floor		0.00129	0.00130
St. Peter	500013859	46 Dawson Road, Orangeville	10-Aug-21	4:45 am - 5:20 am	KG102		0.00282	0.00173
St. Peter CCC	500076415		2-Sep-21	5:57 am - 6:32 am	DF 1st Floor	Outside of CR. 115	0.00163	0.00067
			10-Aug-21	4:43 am - 5:18 am	CCC		0.00118	0.00050
St. Raphael	500019202	3470 Clara Drive, Mississauga	16-Jul-21	5:01 am - 5:36 am	DF-01	Outside of General Office	0.00542	0.00200
			19-Aug-21	8:05 am - 8:40 am	DF-02	Outside of CR. 210	0.00710	0.00480
			16-Jul-21	5:06 am - 5:41 am	KG-105		0.00542	0.00278
St. Raphael CCC	500267814		16-Jul-21	4:59 am - 5:34 am	CCC - Kitchen		0.00026	0.00037
St. Rita	500012416	30 Summer Valley Drive, Brampton	27-Jul-21	4:57 am - 5:32 am	KG101 (Small Sink)	Outside CR. 116 Outside CR. 218	0.00454	0.00099
			27-Jul-21	4:54 am - 5:34 am	DF 1st Floor		0.00030	0.00025
			27-Jul-21	5:04 am - 5:39 am	DF 2nd Floor		0.00063	0.00024
St. Roch SS	500198355	200 Valleyway Drive, Brampton	4-Aug-21	8:30 am - 9:05 am	Caf Sink	Kindergarten-101	0.00050	0.00031
			4-Aug-21	8:36 am - 9:11 am	DF1	Across from CR. 141	0.00165	0.00025
			4-Aug-21	8:43 am - 9:18 am	DF2	Across from CR. 248	0.00004	0.00001
St. Stephen	500012585	17 Colonel Bertram Road, Brampton	28-Jul-21	5:50 am - 6:25 am	KG101	Small Sink	0.00969	0.00419
			28-Jul-21	5:56 am - 6:31 am	DF 01	Across from CR. 107	0.00544	0.00297
St. Stephen CCC	500091235		28-Jul-21	5:54 am - 6:29 am	CCC Kitchen	Small Sink	0.00461	0.00478
St. Thomas Aquinas SS	500012455	25 Corporation Drive, Brampton	16-Jul-21	7:08 am - 7:43 am	CAF	Outside O.S.R Room Outside Digital Photography Room Outside Social Science History Room	0.00500	0.00236
			16-Jul-21	7:18 am - 7:53 am	DF-01		0.00793	0.00150
			16-Jul-21	7:19 am - 7:54 am	DF-02		0.00220	0.00050
			16-Jul-21	7:25 am - 8:00 am	DF-03		0.00205	0.00048
St. Ursula	500012598	11 Dwellers Road, Brampton	21-Jul-21	6:02 am - 6:37 am	KG101	Tall Sink	0.00161	0.00062
			21-Jul-21	6:08 am - 6:43 am	DF1	Across from CR. 108	0.00002	0.00002
			21-Jul-21	6:14 am - 6:49 am	DF2	Across from CR. 210	0.00046	0.00055
St. Veronica	500019293	680 Novo Star Drive, Mississauga	20-Jul-21	7:30 am - 8:05 am	KG104	Small Sink	0.00203	0.00058
			20-Jul-21	7:38 am - 8:13 am	DF1	Across from General Office	0.00022	0.00017
			20-Jul-21	7:45 am - 8:20 am	DF2	Across from CR. 213	0.00361	0.00130
Venerable Michael J. McGivney	500012260	450 Fernforest Drive, Brampton	5-Aug-21	6:58 am - 7:33 am	KG102	Small Sink	0.00369	0.00261
			5-Aug-21	7:00 am - 7:35 am	DF 1st Floor	Outside P.I.P. Room 101	0.00250	0.00281
			5-Aug-21	7:05 am - 7:40 am	DF 2nd Floor	Across from CR. 203	0.00182	0.00125